

ASME A18.1-2020
(Revision of ASME A18.1-2017)

Safety Standard for Platform Lifts and Stairway Chairlifts

ASMENORMDOC.COM : Click to view the full PDF of ASME A18.1 2020

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

ASME A18.1-2020
(Revision of ASME A18.1-2017)

Safety Standard for Platform Lifts and Stairway Chairlifts

ASMENORMDOC.COM : Click to view the full PDF of ASME A18.1-2020

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: February 26, 2021

The next edition of this Standard is scheduled for publication in 2023. This Standard will become effective 6 months after the Date of Issuance.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Standard. Periodically certain actions of the ASME A18 Committee may be published as Cases. Cases and interpretations are published on the ASME website under the Committee Pages at <http://cstools.asme.org/> as they are issued.

Errata to codes and standards may be posted on the ASME website under the Committee Pages to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The Committee Pages can be found at <http://cstools.asme.org/>. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting "Errata" in the "Publication Information" section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to ensure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2021 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

Foreword	iv
Committee Roster	v
Correspondence With the A18 Committee	vi
Summary of Changes	viii
1 Introduction	1
2 Vertical Platform Lifts	8
3 Inclined Platform Lifts	23
4 Inclined Stairway Chairlifts	31
5 Private Residence Vertical Platform Lifts	36
6 Private Residence Inclined Platform Lifts	44
7 Private Residence Inclined Stairway Chairlifts	51
8 Driving Means	55
9 Engineering Type Testing and Design	58
10 Acceptance and Periodic Inspections and Tests	64
11 Maintenance of Platform Lifts and Stairway Chairlifts	66
Nonmandatory Appendices	
A Performance Area Lifts	67
B Controls for Performance Area Lifts	68
Figures	
2.6.7 Platform Lift Corridor Call Station Pictograph	19
9.7 Minimum Loads to Sustain and Lower Based on Inside Net Platform Area	61
A-1 Performance Area Lift	67
B-1 Performance Area Lift Control Options	
Tables	
1.5-1 Reference Documents	6
1.5-2 Procurement Information	7

FOREWORD

The consensus committee that approved the Standard was balanced to ensure that individuals from competent and concerned interests have had an opportunity to participate.

This Standard is intended to serve as the basis for state, municipal, and other jurisdictional authorities in drafting regulations governing the installation, testing, inspection, maintenance, alteration, and repair of platform lifts and stairway chairlifts. It is also intended as a standard reference of safety requirements for the guidance of architects, engineers, insurance companies, manufacturers, and contractors, and as a standard of safety practices for owners and managers of structures where equipment covered in the scope of this Standard is used.

This Standard is available for public review on a continuing basis. This provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

Safety codes and standards are intended to enhance public health and safety. Revisions result from committee consideration of factors such as technological advances, new data, and changing environmental and industry needs. Revisions do not imply that previous editions were inadequate.

It should be pointed out that any governmental jurisdiction has authority over any particular installation. Inquiries dealing with problems of a local character should be directed to the proper authority of such jurisdiction. It is recommended that, prior to adoption, all pertinent state and local laws or ordinances be reviewed and where there is a conflict with any of the requirements of this Standard, an exception to such conflicting requirement be noted, quoting the section of the law that applies.

Equipment covered by this Standard was originally incorporated as a 1983 supplement to ANSI/ASME A17.1-1981, Safety Code for Elevators and Escalators. In ANSI/ASME A17.1b-1983, a new Part XXI covering private residence inclined stairway chairlifts and inclined and vertical wheelchair lifts was added. Part XX was added to cover these same devices installed in buildings other than private residences.

In 1996, as a result of the effort to harmonize the ASME A17.1 Code and the CAN/CSA-B44 Safety Code for Elevators, a new Main Committee on Platform Lifts and Stairway Chairlifts was established. The Committee developed the first edition, which incorporated Parts XX and XXI, as well as the applicable cross-references in ASME A17.1-1996, up to and including ASME A17.1a-1997.

The first edition of this Standard was approved by The American Society of Mechanical Engineers (ASME) Committee on Platform Lifts and Stairway Lifts, was approved and designated as an American National Standard by the American National Standards Institute (ANSI) on June 21, 1999, and issued on July 26, 1999. The ASME A18.1a-2001 Addenda was approved on January 30, 2001, and issued on March 26, 2001. The ASME A18.1b-2001 Addenda was approved on December 11, 2001, and issued on April 11, 2002.

The second edition of this Standard was approved by ANSI on July 29, 2003, and was issued on September 12, 2003.

The third edition of this Standard was approved by ANSI on May 6, 2005, and was issued on November 29, 2005.

The fourth edition of this Standard was approved by ANSI on July 3, 2008, and was issued on August 28, 2008.

The fifth edition of this Standard was approved by ANSI on August 31, 2011, and was issued on October 31, 2011.

The sixth edition of this Standard was approved by ANSI on July 10, 2014, and was issued on September 12, 2014.

The seventh edition of this Standard was approved by ANSI on August 3, 2017, and was issued on October 5, 2017.

The eighth edition of this Standard was approved by ANSI on June 18, 2020, and was issued on February 26, 2021.

ASME A18 COMMITTEE

Safety Standard for Platform Lifts and Stairway Chairlifts

(The following is the roster of the Committee at the time of approval of this Standard.)

STANDARDS COMMITTEE OFFICERS

W. Richardson, *Chair*
D. W. Boydston, *Vice Chair*
E. Dominguez, *Secretary*

STANDARDS COMMITTEE PERSONNEL

P. D. Barnhart, Underwriters Laboratories, Inc.
F. A. Belio, Jr., IUEC Local Number 18
D. W. Boydston, Handi-Lift, Inc.
K. L. Brinkman, National Elevator Industry, Inc.
P. Chance, Elevator Ready, Inc.
E. Dominguez, The American Society of Mechanical Engineers
P. Edwards, Soft Landings Vertical Services, Inc.
G. E. Hedman, University of Illinois at Chicago
J. T. Herrity, U.S. Department of the Navy, Naval Facilities Command
F. M. Hoch, Inclinator Company of America
R. S. Hultstrom, Elevator Industry Work Preservation Fund
P. M. Isaac, Gable Elevator
D. Kalgren, KONE
T. A. Kassens, Bruno Independent Living Aids, Inc.
S. Leathley, Stannah Stairlifts
M. W. McKinley, McKinley Elevator Corp.
S. J. Mehalko, Harmar Mobility, LLC
R. J. Munch, Hoveround Corp.
J. E. Newstrom, Arrow Lift
W. Richardson, Savaria Concord Lifts, Inc.
W. P. Rockhold, ACME Home Elevator
J. R. Runyan, State of Washington
S. Z. Sanossian, SZS Consulting Group, LLC
P. B. Seidel, Precision Lift Industries
M. Townsend, Garaventa Lift
R. B. Weber, Accessibility Systems, Inc.
L. Yang, CSA Group
E. Zuercher, Ascension, a Division of AGM
P. Brobeck, *Alternate*, Ascension, a Division of AGM
P. Clifton, *Alternate*, Stannah Lifts
A. DiGiovanni, *Alternate*, Hoveround Corp.
T. Evans, *Alternate*, Underwriters Laboratories of Canada
R. J. Murphy, *Alternate*, Garaventa Lift
T. E. O'Brien, *Alternate*, Bruno Independent Living Aids, Inc.
J. H. Burpee, *Contributing Member*, State of Maine
G. L. Harmon, *Contributing Member*, Retired
C. McDilda, *Contributing Member*, EEIS
S. Mercier, *Contributing Member*, Regie du Batiment du Quebec
J. L. Meyer, *Contributing Member*, National Elevator Inspection Services, a Bureau Veritas Co.
W. R. Page, *Contributing Member*, Bruno Independent Living Aids, Inc.
J. Rearick, *Contributing Member*, Rearick and Co., Inc.
C. D. Robinson, *Contributing Member*, Elevator Inspection, LLC

CORRESPONDENCE WITH THE A18 COMMITTEE

General. ASME Standards are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Standard may interact with the Committee by requesting interpretations, proposing revisions or a case, and attending Committee meetings. Correspondence should be addressed to:

Secretary, A18 Standards Committee
The American Society of Mechanical Engineers
Two Park Avenue
New York, NY 10016-5990
<http://go.asme.org/Inquiry>

Proposing Revisions. Revisions are made periodically to the Standard to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Standard. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent documentation.

Proposing a Case. Cases may be issued to provide alternative rules when justified, to permit early implementation of an approved revision when the need is urgent, or to provide rules not covered by existing provisions. Cases are effective immediately upon ASME approval and shall be posted on the ASME Committee web page.

Requests for Cases shall provide a Statement of Need and Background Information. The request should identify the Standard and the paragraph, figure, or table number(s), and be written as a Question and Reply in the same format as existing Cases. Requests for Cases should also indicate the applicable edition(s) of the Standard to which the proposed Case applies.

Interpretations. Upon request, the A18 Standards Committee will render an interpretation of any requirement of the Standard. Interpretations can only be rendered in response to a written request sent to the Secretary of the A18 Standards Committee.

Requests for interpretation should preferably be submitted through the online Interpretation Submittal Form. The form is accessible at <http://go.asme.org/InterpretationRequest>. Upon submittal of the form, the Inquirer will receive an automatic e-mail confirming receipt.

If the Inquirer is unable to use the online form, he/she may mail the request to the Secretary of the A18 Standards Committee at the above address. The request for an interpretation should be clear and unambiguous. It is further recommended that the Inquirer submit his/her request in the following format:

Subject:	Cite the applicable paragraph number(s) and the topic of the inquiry in one or two words.
Edition:	Cite the applicable edition of the Standard for which the interpretation is being requested.
Question:	Phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation. Please provide a condensed and precise question, composed in such a way that a "yes" or "no" reply is acceptable.
Proposed Reply(ies):	Provide a proposed reply(ies) in the form of "Yes" or "No," with explanation as needed. If entering replies to more than one question, please number the questions and replies.
Background Information:	Provide the Committee with any background information that will assist the Committee in understanding the inquiry. The Inquirer may also include any plans or drawings that are necessary to explain the question; however, they should not contain proprietary names or information.

Requests that are not in the format described above may be rewritten in the appropriate format by the Committee prior to being answered, which may inadvertently change the intent of the original request.

Moreover, ASME does not act as a consultant for specific engineering problems or for the general application or understanding of the Standard requirements. If, based on the inquiry information submitted, it is the opinion of the Committee that the Inquirer should seek assistance, the inquiry will be returned with the recommendation that such assistance be obtained.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee or Subcommittee. ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

Attending Committee Meetings. The A18 Standards Committee regularly holds meetings and/or telephone conferences that are open to the public. Persons wishing to attend any meeting and/or telephone conference should contact the Secretary of the A18 Standards Committee.

ASMENORMDOC.COM : Click to view the full PDF of ASME A18.1 2000

ASME A18.1-2020

SUMMARY OF CHANGES

Following approval by the ASME A18 Committee and ASME, and after public review, ASME A18.1-2020 was approved by the American National Standards Institute on June 18, 2020.

ASME A18.1-2020 includes the following changes identified by a margin note, **(20)**.

<i>Page</i>	<i>Location</i>	<i>Change</i>
1	1.3	(1) Definitions of <i>inspection and tests acceptance</i> , <i>periodic</i> , and <i>routine</i> deleted (2) Definitions of <i>performance area</i> and <i>Type A safeties</i> added (3) Definition of <i>inclined stairway chairlift</i> editorially revised
6	Table 1.5-1	(1) Entry for ANSI/ASSE A10.4 updated (2) Cross-references under "A18.1 References" updated to reflect revisions in text
7	Table 1.5-2	Revised
8	2.1	Revised
8	2.1.1.2	Revised in its entirety
9	2.1.2.7	Revised in its entirety
10	2.1.3.3	Revised in its entirety
12	2.1.4.4	Revised in its entirety
13	2.1.5.2	Revised
13	2.1.6	Added and former 2.1.6 through 2.1.10 redesignated
16	2.3.8	Revised
18	2.6.2	Revised
18	2.6.3	Editorially revised
18	2.6.5	Revised
18	2.6.9	Added
19	2.7.1	Revised
21	2.8.6	Revised
21	2.9.5	Revised
21	2.10.1	Revised
22	2.10.10	Revised in its entirety
23	2.11.1	Revised
23	2.11.2	Revised
23	2.12	Revised
25	3.3.1.7	Added
27	3.6.6	Revised
29	3.8.3.1	Revised
29	3.10.1	Revised
30	3.10.10	Revised in its entirety
31	3.11.1	Editorially revised

<i>Page</i>	<i>Location</i>	<i>Change</i>
31	3.11.2	Revised
31	3.11.3	Added
31	3.12	Revised
34	4.8.1.2	Revised
34	4.8.3.1	Revised
35	4.10.1	Revised
36	5.1.1.2	Revised in its entirety
39	5.3.8	Revised
40	5.6.3	Editorially revised
42	5.8.6	Revised
42	5.9.5	Revised
42	5.10.1	Revised
43	5.10.10	Revised in its entirety
44	5.12	Added
44	6.2.1.2	Revised
45	6.3.1.7	Added
45	6.3.5	Editorially revised
47	6.6.4.3	Editorially revised
48	6.8.1.2	Revised
48	6.8.4	Revised
49	6.10.1	Revised
50	6.10.10	Revised in its entirety
50	6.12	Added
53	7.8.1.2	Editorially revised
53	7.8.4	Revised
54	7.10.1	Revised
56	8.1.4.8	Subparagraph (c) editorially revised
57	8.1.7.2.1	Editorially revised
60	9.7	In the nomenclature, unit of measure for A revised
62	9.9	(1) Paragraph 9.9.1 deleted, subsequent paragraphs redesignated, and cross-references updated (2) Former paras. 9.9.2 and 9.9.3 revised
64	10	Revised in its entirety
66	11.1.2	Subparagraph (c) revised
67	Nonmandatory Appendix A	Added
68	Nonmandatory Appendix B	Added

INTENTIONALLY LEFT BLANK

SAFETY STANDARD FOR PLATFORM LIFTS AND STAIRWAY CHAIRLIFTS

1 INTRODUCTION

1.1 Scope

1.1.1 Equipment Covered by This Standard. This safety Standard covers the design, construction, installation, operation, inspection, testing, maintenance, and repair of inclined stairway chairlifts and inclined and vertical platform lifts intended for transportation of a mobility-impaired person only. The device shall have a limited vertical travel, operating speed, and platform area. Operation shall be under continuous control of the user/attendant. The device shall not penetrate more than one floor. A full passenger enclosure on the platform shall be prohibited.

1.1.2 Equipment Not Covered by This Standard. Equipment not covered by this Standard includes, but is not limited to, the following:

- (a) elevators, escalators, moving walkways, material lifts, and dumbwaiters within the scope of ASME A17.1-1997 and later editions
- (b) personnel hoists within the scope of ANSI/ASSE A10.4
- (c) manlifts within the scope of ASME A90.1
- (d) powered platforms and equipment for exterior and interior building maintenance within the scope of ASME A120.1
- (e) portable equipment
- (f) amusement devices
- (g) stage and orchestra lifts

1.1.3 Application. This Standard applies to new installations only, except [section 10](#), which applies to new and existing installations.

1.1.4 Effective Date. The requirements of this edition of the Standard are effective as of the date established by the local regulations of the authority having jurisdiction. Where the Standard has not been adopted by local regulation and a specific edition has not been stipulated by contractual agreement, compliance with this edition is recommended as of the effective date listed in the front of the document.

1.2 Purpose and Exceptions

The purpose of this Standard is to provide for the safety of life and limb, and to promote public welfare.

The provisions of this Standard are not intended to prevent the use of systems, methods, or devices of equivalent or superior quality, strength, fire resistance, effectiveness, durability, and safety to those prescribed by this Standard, provided that there is technical documentation to demonstrate the equivalency of the system, method, or device.

The specific requirements of this Standard shall be permitted to be modified by the authority having jurisdiction based on technical documentation or physical performance verification to allow alternative arrangements that will assure safety equivalent to that which would be provided by conformance to the corresponding requirements of this Standard.

1.3 Definitions

(20)

This section defines various terms used in this Standard.

alteration: any change to equipment other than maintenance, repair, or replacement.

approved: acceptable to the authority having jurisdiction.

authority having jurisdiction: organization, office, or individual responsible for approving equipment. Where compliance with this Standard has been mandated by law, the “authority having jurisdiction” is the federal, state, or local department or individual so designated in the enacting legislation or administrative regulation.

authorized personnel: persons who have been instructed in the operation of the equipment and designated by the owner to manage the use of the equipment.

building code: an ordinance that sets forth requirements for building design and construction, or where such an ordinance has not been enacted, the International Code Council (ICC), International Building Code (IBC), and International Residential Code (IRC) are the code standards.

cable, traveling: see *traveling cable*.

capacity: see *rated load*.

certified: a certification by a testing laboratory, a professional engineer, a manufacturer, or a contractor that a device or an assembly conforms to the requirements of this Standard.

combination mechanical lock and electric contact: a combination mechanical and electrical device with two related but entirely independent functions that are

(a) to prevent operation of the driving machine by the normal operating device, unless the door or gate is in the closed position

(b) to lock the door or gate in the closed position and prevent it from being opened from the landing side, unless the platform is within the specified distance from the landing

compensating-rope sheave switch: a device that automatically causes the electric power to be removed from the driving-machine motor and brake when the compensating sheave approaches its upper or lower limit of travel.

contacts: see *door or gate electric contact*.

control: the system governing the starting, stopping, direction of motion, acceleration, speed, and retardation of the moving member.

controller: a device or group of devices that serves to control in a predetermined manner the apparatus to which it is connected.

door or gate: the movable portion(s) of the platform or runway entrance that closes the opening providing access to the platform or landing. It consists of one or more panels that may be equipped with a vision panel.

door or gate, manually operated: door or gate that is opened and closed by hand.

door or gate, power-operated: a door or gate that is opened and closed by a door or gate power-operator.

door or gate, self-closing: a manually operated door or gate that closes when released or a power-operated door or gate.

door or gate closer: a device that closes a door or gate by means of a spring or gravity.

door or gate electric contact: an electrical device, the function of which is to prevent operation of the driving machine by the normal operating device unless the door or gate is in the closed position.

door or gate power-operator: a device or assembly of devices that opens a door or gate by power other than by hand, gravity, springs, or the movement of the platform; and that closes the door or gate by power other than by hand, gravity, or the movement of the platform.

driving machine: see *machine, driving*.

emergency stop switch: a device that, when manually operated, causes the lift to halt its motion.

enforcing authority: see *authority having jurisdiction*.

entrance hardware: all components of an entrance, exclusive of the frame, door panels, and locks, that are necessary to maintain the position of the panels within the assembly.

factor of safety: the ratio of the ultimate strength to the working stress of a member under maximum static loading, unless otherwise specified in a particular rule.

full passenger enclosure: an assembly inclusive of the platform top, minimum 2 000 mm (79 in.) tall walls, minimum 2 000 mm (79 in.) tall platform doors, and platform floor.

gate: see *door or gate*.

governor: see *speed governor*.

governor pull-retarding means: a mechanical means of developing a sufficient force in the governor rope to activate the platform or counterweight safeties or to trip the governor rope releasing carrier, where used. Such mechanical means include, but are not limited to, rope-gripping jaws, clutch mechanisms, and traction arrangements.

governor pull-through tension (force): the magnitude of the tensile load developed in the moving governor rope after the governor rope-retarding means is actuated.

inclined platform lift: a guided, powered hoisting and lowering mechanism equipped with a seat to transport seated passengers along stairways.

inclined stairway chairlift: a guided, powered hoisting and lowering mechanism, equipped with a seat to transport seated passengers along stairways.

installation: a complete platform lift or stairway chairlift, including all machinery and equipment necessary for its operation.

installation, existing: an installation that has been completed or is under construction prior to the effective date of this Standard.

installation, new: any installation not classified as an existing installation by definition, or an existing platform lift or stairway chairlift moved to a new location subsequent to the effective date of this Standard.

installation, placed out of service: an installation whose power feed lines have been disconnected from the machine disconnect switch.

labeled: equipment or materials to which has been attached a label, symbol, or other identifying mark of an independent certifying organization concerned with product evaluation, that maintains periodic inspection of production of labeled equipment or materials and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

landing: that portion of a floor, balcony, or platform used to receive and discharge passengers.

landing, bottom terminal: the lowest landing served.

landing, top terminal: the highest landing served.

landing, unenclosed: a landing that is open to the atmosphere or is open to an interior court of a building.

lever hydraulic driving machine: a hydraulic machine in which the plunger or cylinder is attached to the platform via levers.

lever screw driving machine: a screw machine in which the screw or nut is attached to the platform via levers.

lift personnel: persons who have been trained in the construction, maintenance, repair, inspection, or testing of the lift.

listed: equipment or materials included in a list published by an independent certifying organization concerned with product evaluation that maintains periodic inspection of production of listed equipment or materials and whose listing states whether that equipment or material meets appropriate standards or has been tested and found suitable for use in a specified manner.

machine, driving: the power unit that applies the energy necessary to raise and lower equipment covered by the scope of this Standard.

belt-drive machine: an indirect-drive machine equipped with a belt system as the connecting means.

chain-drive machine: an indirect-drive machine with a chain system as the connecting means.

direct-drive machine: an electric driving machine, the motor of which is directly connected mechanically to the driving sheave, drum, or shaft without the use of belts or chains, either with or without intermediate gears.

direct-plunger driving machine: a hydraulic driving machine in which the plunger or cylinder is directly attached to the platform.

electric driving machine: a driving machine where the energy is applied by an electric motor. It includes the motor, brake, and the driving sheave or drum together with its connecting gearing, belt, or chain, if any.

friction machine: a direct-drive machine in which the motion of the platform is obtained through friction between a guiding means and driving wheels or rollers.

geared-drive machine: a direct-drive machine in which the energy is transmitted from the motor to the driving sheave, drum, or shaft through gearing.

geared-traction machine: a geared-drive traction machine.

gearless-traction machine: a traction machine, without intermediate gearing, that has the traction sheave and the brake drum mounted directly on the motor shaft.

hydraulic driving machine: one in which the energy is applied by means of a liquid under pressure in a cylinder equipped with a plunger or piston.

indirect-drive machine: an electric driving machine, the motor of which is connected indirectly to the driving sheave, drum, gear reducer, or shaft by means of a belt drive or chain drive.

rack-and-pinion driving machine: an electric driving machine in which the motion of the platform lift or stairway chairlift is obtained by power-driven rotating

pinion(s) mounted on the platform, traveling on a stationary rack mounted in the runway.

rope sprocket drive: a driving means consisting of wire rope with fixed links at constant intervals throughout its length. The links engage in slots on a grooved drive cog to provide a positive drive force.

roped-hydraulic driving machine: a hydraulic driving machine in which the plunger or piston is connected to the platform with wire ropes or indirectly coupled to the platform by means of wire ropes and sheaves. It includes the cylinder, the plunger or piston, and multiplying sheaves, if any, and their guides.

screw machine: an electric driving machine, the motor of which drives a nut on a screw or rotates a screw to raise or lower a platform lift or stairway chairlift.

traction machine: a direct-drive machine in which the motion of a platform is obtained through traction between the suspension ropes and a traction sheave.

winding drum machine: a geared-drive machine in which the suspension ropes are fastened to and wind on a drum.

worm-gear machine: a direct-drive machine in which the energy from the motor is transmitted to the driving sheave or drum through worm gearing.

main floor: the floor providing normal egress from a building.

maintenance: a process of routine examination, lubrication, cleaning, adjustment, and replacement of parts for the purpose of ensuring performance in accordance with the applicable Standard requirements.

masonry: built-up construction or combination of building units or materials of clay, shale, concrete, glass, gypsum, stone, or other approved units bonded together with mortar or monolithic concrete. Reinforced concrete is not classed as masonry.

operating device: the switch, push-button, lever, or other device used to actuate the control.

operation: the method of actuating the control.

operation, continuous-pressure: operation by means of buttons or switches on the platform lift or stairway chairlift and on the platform, any one of which may be used to control the movement of the platform lift as long as the button or switch is manually maintained in the actuating position.

overhead structure: all of the structural members supporting the machinery, sheaves, and equipment at the top of the runway.

penetrate a floor: pass through or pierce a floor in such a way that the opening has a continuous perimeter and is provided only to allow the equipment to pass through the floor.

performance area: a raised, fixed platform in an assembly area used to provide clear sight lines for the audience to see and hear activities (examples include areas used for

entertainment, lecturers/speakers, the head table for special guests, and worship services).

piston: short cylindrical member that is provided with a sealing means that travels with the member within a hydraulic cylinder.

pit: that portion of a runway extending from the sill level of the lowest landing to the floor at the bottom of the runway.

platform: the load-carrying unit, including, but not limited to frame, floor, enclosure, seat, and door or gate.

platform frame: a structural frame composed of interconnecting members that supports the platform.

plunger (ram): a long cylindrical compression member that is directly or indirectly coupled to the platform frame. This member is not provided with a sealing means. Where used in assembly with a cylinder, the sealing means is provided on the cylinder head; in the case of telescopic plungers and cylinders, a sealing means may be used in the moving plunger that is also a cylinder.

portable equipment: a device that is used to transport those with mobility impairments, that is not permanently fastened in place, and is not a relocatable lift.

position indicator: a device that indicates the position of the platform in the runway. It is called a "hall position indicator" when placed at a landing, or a "platform position indicator" when placed in the platform.

private residence: a separate dwelling or a separate apartment in a multiple dwelling that is occupied only by the members of a single family unit.

rated load: the load that the equipment is designed and installed to lift at the rated speed.

rated load performance: the operation of the equipment with its rated load at rated speed.

rated speed: the speed at which the equipment is designed to operate in the up direction with rated load in the platform.

recycling operation, telescopic plunger: an operation for restoring the relative vertical positions of the multiple plungers in a telescoping plunger arrangement.

releasing carrier, governor rope: a mechanical device to which the governor rope may be fastened and calibrated to control the activation of a safety at a predetermined tripping force.

relocatable lift: a vertical or inclined platform lift, as defined by this Standard, that is designed to be moved from one location to another and is not designed to be permanently fastened in place.

repair: the process of rehabilitation or replacement of parts that are basically the same as the original for the purpose of ensuring performance in accordance with the applicable Standard requirements.

replacement: the substitution of a device or component in its entirety with a new unit that is basically the same as the original for the purpose of ensuring performance in accordance with applicable Standard requirements.

rise: see *travel*.

rope, compensating: wire rope used to counterbalance, or partially counterbalance, the weight of the suspension ropes.

rope, counterweight: wire rope used to raise and lower the counterweight on equipment having a winding drum machine or a hydraulic machine equipped with a counterweight.

rope, governor: wire rope with at least one end fastened to the safety activating means or governor rope releasing carrier, passing over and driving the governor sheave, and providing continuous information on the speed and direction of the platform or counterweight.

rope, suspension (hoisting): wire rope used to raise and lower a platform lift or its counterweight, or a stairway chairlift, or both.

rope equalizer, suspension: a device installed on a platform or counterweight to equalize automatically the tensions in the suspension wire ropes.

rope-fastening device, auxiliary: a device attached to the platform or counterweight or to the overhead dead-end rope-hitch support that will function automatically to support the platform or counterweight in case the regular wire-rope fastening fails at the point of connection to the platform or counterweight or at the overhead dead-end hitch.

runby, top, direct-plunger hydraulic: the distance the platform can run above its top terminal landing before the plunger strikes its mechanical stop.

runway: the space in which the platform or seat moves.

runway door or gate, locking device: a device that secures a runway door or gate in the closed position and prevents it from being opened from the landing side except under certain specified conditions.

safety bulkhead: a closure at the bottom of the cylinder located above the cylinder head and provided with an orifice for controlling the loss of fluid in the event of cylinder head failure.

safety, platform or counterweight: a mechanical device attached to the platform frame or to an auxiliary frame, or to the counterweight frame, to stop and hold the platform or counterweight under one or more of the following conditions: predetermined overspeed, free fall, or if the suspension ropes slacken.

safety, self-resetting: a platform or counterweight safety released and reset by movement in the up direction.

screw column: a structural member provided with screw threads that supports the platform on screw driving machines.

shall: indicates a mandatory requirement.

should: indicates a recommendation, not a mandatory requirement.

slack-rope switch: a device that automatically causes the electric power to be removed from the driving-machine motor and brake when the suspension ropes of a winding drum machine become slack.

sleeving (liner): the insertion of a smaller diameter cylinder inside the existing cylinder of a hydraulic driving machine.

solid state device: an element that can control current flow without moving parts.

speed governor: a continuously operating speed monitoring and detection device that, at predetermined speeds, provides signals to the controller and imparts a retarding force to activate the platform lift or counterweight safety, or stairway chairlift.

starter control panel: an assembly of devices by means of which the starter may control the manner in which a lift functions.

static switching: switching of circuits by means of solid state devices.

stop switch: see *emergency stop switch*.

supply piping: the piping for a hydraulic driving machine between the control valves and the driving member of the driving machine.

terminal landing: see *landing*.

terminal stopping device, final: a device that automatically causes the power to be removed from the driving-machine motor and brake, or from a hydraulic driving machine, independent of the functioning of the normal terminal stopping device, the operating device, or any emergency terminal speed-limiting device, after the platform lift or stairway chairlift has passed a terminal landing.

terminal stopping device, machine final (stop-motion switch): a final terminal stopping device operated directly by the driving machine.

terminal stopping device, normal: a device or devices to slow down and stop a platform lift or stairway chairlift automatically at or near a terminal landing independently of the functioning of the operating device.

travel (rise): the vertical distance between the bottom terminal landing and the top terminal landing.

traveling cable: a cable made up of electric conductors that provides electrical connection between a platform lift or stairway chairlift and a fixed outlet in the runway.

Type A safeties: safeties that develop a rapidly increasing pressure on the guide rails during the stopping interval, the stopping distance being very short due to the inherent design of the safety. The operating force is derived entirely from the mass and the motion of the car or the counterweight being stopped. These safeties apply pressure on the guide rails through eccentrics, rollers, or similar devices, without any flexible medium purposely introduced to limit the retarding force and increase the stopping distance.

valley break: a broken wire in a wire rope in which the outside wire of a strand breaks in the immediate vicinity of the point where it contacts a wire or wires of an adjacent strand, generally at a point not visible when the wire rope is examined externally. One end of the broken wire is long enough to reach from one valley to the next one and the other end of the broken wire generally cannot be seen.

vertical platform lift: a powered hoisting and lowering mechanism designed to transport mobility-impaired persons on a guided platform that travels vertically.

weatherproof: so constructed or protected that exposure to the weather will not interfere with successful operation.

window: an assembly consisting of a surrounding frame and one or more sashes, ventilators, or fixed lights, or a combination of these, designed to be installed in a wall opening for the purpose of admitting light or air, or both.

working pressure: the pressure measured at the cylinder of a hydraulic driving machine when the platform lift or stairway chairlift is lifting its rated load at rated speed.

1.4 Metric (SI) Units

This edition of the Standard uses hard metric (SI) units whenever practical. The acceptable equivalent U.S. Customary units are shown in parentheses. Information on the usage of SI units and conversion to U.S. Customary units is contained in IEEE/ASTM SI 10-1997, Standard for the Use of the International System of Units (SI): The Modern Metric System, or ASME Guide SI-1, Orientation and Guide for Use of SI (Metric) Units.

Requirements related to speed and load use the hard metric and hard U.S. Customary units in common practice, even though they are not exactly equivalent.

1.5 Reference Codes, Standards, and Specifications

This section covers the codes, standards, and specifications incorporated in this Standard by reference; the specific editions that are applicable; and the rules of this Standard that reference each document (see [Table 1.5-1](#)). This section also lists the names and addresses of the organizations from which these documents may be procured (see [Table 1.5-2](#)).

Only the portion of the code, standard, or specification specified by the rules in this Standard is applicable.

(20)

Table 1.5-1 Reference Documents

Designator	Standard	A18.1 References	Available From
16 CFR Part 1201-86	Architectural Glazing Standards and Related Materials	3.6.6.3 and 6.6.4.3	U.S. GPO
ANSI Z97.1-2004	Safety Glazing Material Used in Buildings — Safety Performance Specifications and Methods of Test	3.6.6.3, 3.6.6.4, 6.6.4.3, and 6.6.4.4	ANSI
ANSI/ASSE A10.4 [Note (1)]	Safety Requirements for Personnel Hoists and Employee Elevators for Construction and Demolition Sites	1.1.2	ANSI/ASSP
ANSI/ASTM E84	Test Method for Surface Burning Characteristics of Building Materials	2.6.7	ANSI
ICC/ANSI A117.1-2009	Accessible and Usable Buildings and Facilities	3.10.1	ANSI
IEEE/ASTM SI 10-1997	American National Standard for Use of the International System of Units (SI): The Modern Metric System	1.4	ANSI
ASME A17.1-1997 (and later editions)	Safety Code for Elevators and Escalators	1.1.2	ASME
ASME A90.1 [Note (1)]	Safety Standard for Belt Manlifts	1.1.2	ASME
ASME A120.1 [Note (1)]	Safety Requirements for Powered Platforms for Building Maintenance	1.1.2	ASME
ASME B1.20.1 [Note (1)]	Pipe Threads, General Purpose, Inch	8.1.7.3	ASME
ASME B29.1 [Note (1)]	Precision Power Transmission, Roller Chains, Attachments, and Sprockets	2.3.1.5, 2.3.9.1, 3.3.1.5, 3.3.6.1, 4.3.1.2, 4.3.6.1, 5.3.1.5, 5.3.9.1, 6.3.1.5, 6.3.6.1, 7.3.1.2, and 7.3.6.1	ASME
ASME SI-1	ASME Orientation and Guide for Use of SI-1 (Metric) Units	1.4	ASME
CAN/CSA-B44.1/ASME A17.5 [Note (1)]	Elevator and Escalator Electrical Equipment	2.1.8.2, 2.10.9.2, 3.1.6.2, 3.10.9.2, 4.1.4, 4.10.3.2, 5.1.4.2, 5.10.9.2, 6.1.5.2, 6.10.6.2, 7.1.3, and 7.10.3.2	ASME
ASME QEI-1 [Note (1)]	Standard for the Qualification of Elevator Inspectors	10.1.4	ASME
ASTM A307-04	Standard Specification for Carbon Steel Bolts and Studs, 60 000 psi Tensile	2.2.2.2, 3.2.1.1, 5.2.1.1, 6.2.1.1, and 8.1.2.2	ASTM
ASTM A502-03	Standard Specification for Rivets, Steel, Structural	2.2.2.3, 3.2.1.1, 5.2.1.1, and 6.2.1.1	ASTM
ASTM D2412-02(2008)	Standard Test Method for Determination of External Loading Characteristics of Plastic Pipe by Parallel-Plate Loading	8.1.4.8	ASTM
ASTM E8-04	Standard Test Methods for Tension Testing of Metallic Materials	2.6.7 and 9.5.1	ASTM
AWS D1.1/D1.1M:2004	Structural Welding Code — Steel	9.1.1 and 9.1.2	AWS
AWS D1.3:1998	Structural Welding Code — Sheet Steel	9.1.2	AWS
CSA B355-15	Lifts for Persons With Physical Disabilities	2.1.1.4.1	CSA
IBC-2015	International Building Code	1.3	ICC
IRC-2015	International Residential Code	1.3	ICC

Table 1.5-1 Reference Documents (Cont'd)

Designator	Standard	A18.1 References	Available From
NFPA 70-2014	National Electrical Code	2.1.8.1, 2.10.9.1, 3.1.6.1, 3.10.9.1, 4.1.3, 4.10.3.1, 5.1.4.1, 5.10.9.1, 6.1.5.1, 6.10.6.1, 7.1.2, and 7.10.3.1	NFPA
NFPA 99-2005	Standard for Health Care Facilities	2.11.3	NFPA
SAE AS100-1994	Fitting, Cross, Short Flareless	8.1.7.1	SAE
SAE J514-2004	Hydraulic Tube Fitting	8.1.7.2.1	SAE
SAE J517-2008	Hydraulic Hose	8.1.7.1	SAE
SAE J524-2007	Seamless Low-Carbon Steel Tubing Annealed for Bending and Flaring	8.1.7.2.1	SAE

NOTE: (1) The latest edition of this Standard shall apply.

Table 1.5-2 Procurement Information

(20)

Organization	Address and Phone Number	Organization	Address and Phone Number
ANSI	American National Standards Institute 25 West 43rd Street New York, NY 10036 Telephone: (212) 642-4900 www.ansi.org	CSA	Canadian Standards Association 178 Rexdale Boulevard Toronto, Ontario M9W 1R3, Canada Telephone: (416) 747-4044 www.csagroup.org
ASME	The American Society of Mechanical Engineers Two Park Avenue New York, NY 10016-5990 Telephone: (800) 843-2763 www.asme.org	ICC	International Code Council 500 New Jersey Avenue, NW Washington, DC 20001 Telephone: (888) 422-7233 www.iccsafe.org
ASSP	The American Society of Safety Professionals 520 N. Northwest Hwy Park Ridge, IL 60068 Telephone: 847-699-2929 www.assp.org	NFPA	National Fire Protection Association 1 Batterymarch Park Quincy, MA 02169-7471 Telephone: (617) 770-3000 www.nfpa.org
ASTM	American Society for Testing and Materials (ASTM International) 100 Barr Harbor Drive West Conshohocken, PA 19428-2959 Telephone: (610) 832-9585 www.astm.org	SAE	SAE International 400 Commonwealth Drive Warrendale, PA 15096-0001 Telephone: (724) 776-4841 www.sae.org
AWS	American Welding Society 8669 NW 36 Street, No. 130 Miami, FL 33166 Telephone: (800) 443-9353 www.aws.org	U.S. GPO	Superintendent of Documents U.S. Government Publishing Office 732 N. Capitol Street, NW Washington, DC 20401 (800) 512-1800 www.gpo.gov

2 VERTICAL PLATFORM LIFTS¹

Section 2 applies to vertical platform lifts installed in locations other than in or at a private residence for use by the mobility impaired.

(20) 2.1 Runways

Runways shall be installed in accordance with 2.1.1 through 2.1.4, or 2.1.6. Runway construction for lifts that penetrate a floor must comply with 2.1.1 and with the building code. Lifts conforming to 2.1.4 shall be located in courtroom areas not open to the public and under the supervision of court officials. Lifts conforming to 2.1.6 shall be located in performance areas only.

2.1.1 Runway Enclosure Provided

2.1.1.1 The runway shall be guarded by a solid enclosure extending from the lowest landing to a height of at least 1 100 mm (42 in.) above the uppermost landing. The enclosure shall withstand, without permanent deformation, a force of 550 N (125 lbf) applied on any 100 mm × 100 mm (4 in. × 4 in.) area. The interior of the runway enclosure shall present a smooth surface on all sides except where the platform enclosure walls extend to a minimum height of 2 000 mm (79 in.) above the platform floor.

(20) **2.1.1.2** The runway entrance shall be guarded at the upper landing by a door complying with the following:

- (a) The door shall be of unperforated construction.
- (b) The door shall be not wider than the platform plus 25 mm (1 in.).
- (c) The door shall be self-closing.
- (d) The door shall be a minimum of 1 100 mm (42 in.) high.
- (e) The lift side of the door and sill shall present a smooth surface.
- (f) The lift side of the door and sill shall be located not closer than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.) from the access edge of the platform floor.

2.1.1.3 The runway entrances at all but the uppermost landing shall be guarded by unperforated self-closing doors not wider than the platform plus 25 mm (1 in.). The openings created in the runway by these doors shall provide a minimum vertical clearance of 2 000 mm (79 in.). The doors shall guard the entire area of the openings except for space necessary for operation. Space necessary for operation shall reject a ball 12 mm (0.5 in.) in diameter. The lift side of the landing doors and sill shall present a smooth surface located not closer than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.) from the platform floor.

¹ See section 5 for the requirements for this equipment installed in or at a private residence.

2.1.1.4 All doors shall be provided with a combination mechanical lock and electric contact. Locking devices shall be protected against tampering from the landing side. The locking devices may permit a door to be opened only if the platform floor is within 50 mm (2 in.) of the respective landing. They shall permit the platform to move away from the landing under control of the normal operating device if the door is closed but not locked, provided that the device will cause the platform to stop if it moves away from the landing more than 50 mm (2 in.) before the door is locked. Doors shall withstand, without permanent deformation, a force of 550 N (125 lbf) applied on any 100 mm × 100 mm (4 in. × 4 in.) area.

2.1.1.4.1 The capability of door-locking devices to function as required shall be verified by an engineering test as described in 9.9.2. Door- and/or gate-locking devices that have been tested and certified to comply with ASME A17.1/CSA B44 (including locks for private residence elevators and locks tested to earlier editions of ASME A17.1 and CSA B44) or CSA B355 shall be considered as meeting the requirements of this section and no further testing or markings are required. A label that shall include the model number and date of testing shall be attached to the locking device.

2.1.1.5 No hardware shall project beyond the vertical line of travel of the platform, except for that required for door locks.

2.1.1.6 The running clearance between the entrance and exit sides of the platform floor and the interior of the runway enclosures shall be not less than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.).

2.1.1.7 A minimum of one platform side not used for entrance or exit shall be guarded by a platform enclosure wall of smooth construction to a height of at least 1 100 mm (42 in.) above the platform floor with no openings other than those necessary for operation. Openings necessary for operation shall reject a ball 12 mm (0.5 in.) in diameter. A grab rail extending the length of at least one sidewall shall be provided at a height of 850 mm (34 in.) to 1 000 mm (38 in.). The running clearance between platform enclosure walls that extend less than 2 000 mm (79 in.) above the platform floor and the runway enclosure walls, vertical face of the machine housing, or other rigid surfaces shall be not less than 50 mm (2 in.). The running clearance between platform enclosure wall(s) that extend a minimum of 2 000 mm (79 in.) above the platform floor and runway walls or other surfaces shall be not less than 20 mm (0.75 in.). Running clearance between enclosure wall ends and the entrance and exit side of the runway shall be not less than 10 mm (0.375 in.) nor more than 75 mm (3 in.).

2.1.1.7.1 Where the running clearance between the platform enclosure wall that extends less than 2 000 mm (79 in.) above the platform floor and the

runway enclosure wall is less than 50 mm (2 in.), edge protection is required at the top edge of the platform enclosure wall. When edge protection is used, the clearance between the platform enclosure wall and vertical face of the machine housing or other surfaces shall be not less than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.). Edge protection required shall be permitted to use mechanically operated, magnetically operated, optical, or static-type switches. When activated, the switch shall cause the electric power to be removed from the driving-machine motor and brake, if provided. When activated, the platform shall stop within 12 mm (0.5 in.) in the "UP" direction only.

2.1.1.8 If the runway enclosure extends to a minimum height of 2000 mm (79 in.) above the upper landing, consists of transparent walls, is exposed to direct sunlight, and is enclosed with a solid roof, forced ventilation with a minimum air-handling capacity of one air change per minute based on net inside enclosure volume shall be provided. The ventilation shall be thermostatically controlled. It shall be set to activate at a temperature not to exceed 32°C (90°F). An auxiliary power source capable of providing the minimum air-handling capacity for 1 h shall be provided. Ventilating fans or blowers, if used, shall be located outside the enclosure, or if inside the enclosure, provide a minimum headroom clearance of 2000 mm (79 in.).

2.1.2 Partial Runway Enclosure Provided

2.1.2.1 The area under the platform shall be fully enclosed by smooth guards, either telescoping or stationary, on all accessible platform sides. The guards shall withstand, without permanent deformation, a force of 550 N (125 lbf) applied on any 100 mm by 100 mm (4 in. by 4 in.) area. The height of stationary guards, if provided, shall be at least equal to the maximum upward travel of the platform floor plus 75 mm (3 in.). The running clearance between the platform enclosure walls and any stationary guard panel, vertical face of the machine housing, or other rigid surfaces shall be not less than 50 mm (2 in.). Shutter-type (telescoping) guards, if provided, shall be securely fastened to the lower landing level and to the platform. Openings necessary for operation of shutter-type (telescoping) guard panels shall reject a ball 12 mm (0.5 in.) in diameter.

2.1.2.1.1 Where stationary guards are used, the runway entrance at the lower landing shall be guarded by an unperforated self-closing door. The vertical opening created in the runway by this door shall provide a minimum clearance of 2000 mm (79 in.). The horizontal opening created when the door is in its open position shall not exceed the interior width of the runway. The door shall guard the entire area of the opening except for space necessary for operation. Space necessary for operation shall reject a ball 12

mm (0.5 in.) in diameter. The platform side of the landing door shall present a smooth surface located not less than 50 mm (2 in.) nor more than 75 mm (3 in.) from the platform door. The landing doorsill shall be located not closer than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.) from the platform floor.

2.1.2.2 The runway entrance shall be guarded at the uppermost landing by a door of unperforated construction not wider than the entrance to the platform plus 25 mm (1 in.). The door shall be self-closing and at least 1100 mm (42 in.) high. The lift side of the door and sill shall present a smooth surface located not closer than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.) from the access edge of the platform floor.

2.1.2.3 The runway entrance shall be guarded at any intermediate landing by a door of unperforated construction not wider than the entrance to the platform plus 25 mm (1 in.). The door shall be self-closing and extend to a height of at least 1100 mm (42 in.) above the top terminal landing. The lift side of the door and sill shall present a smooth surface located not closer than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.) from the access edge of the platform floor.

2.1.2.4 The side of the platform providing access to the lower landing shall be guarded by a platform door of unperforated construction. The door shall be self-closing and at least 1100 mm (42 in.) high.

2.1.2.5 All doors shall be provided with a combination mechanical lock and electric contact. Locking devices shall be protected against tampering from the landing side. The locking devices shall permit a door to be opened only if the platform floor is within 50 mm (2 in.) of the respective landing. The platform shall be permitted to move away from the landing under control of the normal operating device if the door is closed but not locked, provided that the device will cause the platform to stop if it moves more than 50 mm (2 in.) away from the landing before the door is locked.

2.1.2.5.1 Door-locking devices shall comply with 2.1.1.4.1.

2.1.2.6 The platform side of the landing doors and sills shall present a smooth surface and shall not project beyond the vertical line of travel of the platform. No hardware shall project beyond the vertical line of travel of the platform, except for that required for door locks and electric contacts. The doors shall withstand, without permanent deformation, a force of 550 N (125 lbf) applied on any 100 mm × 100 mm (4 in. × 4 in.) area.

2.1.2.7 A smooth vertical surface shall be provided (20) from the top terminal landing sill and any intermediate landing sill to not less than 25 mm (1 in.) below the level of the platform floor on the lower mechanical stop. Where a pit is provided and is less than 25 mm

(1 in.) in depth, the surface shall extend to the pit floor. Openings necessary for operation shall reject a ball 12 mm (0.5 in.) in diameter.

The surface shall be capable of withstanding a force of 330 N (75 lbf) on a 100 mm × 100 mm (4 in. × 4 in.) surface and have deflection less than 20 mm (0.75 in.) in any location. The surface shall not be permanently deformed when a force of 550 N (125 lbf) is applied on any 100 mm × 100 mm (4 in. × 4 in.) area.

Projections from the vertical surface shall not exceed 5 mm (0.20 in.); projections exceeding 2 mm (0.08 in.) shall be beveled at an angle of 15 deg or less to the line of travel. The clearance between the platform edge and the landing sill or any vertical surface of the hoistway shall be not less than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.).

2.1.2.8 The platform enclosure walls on the sides not used for entrance or exit shall be of smooth construction to a height of at least 1 100 mm (42 in.) above the platform floor with no openings, other than those necessary for operation. Openings necessary for operation shall reject a ball 12 mm (0.5 in.) in diameter. A grab rail extending the full length of either sidewall shall be provided at a height of 850 mm (34 in.) to 1 000 mm (38 in.). The running clearance between the platform enclosure wall and the vertical face of the machine housing shall be not less than 50 mm (2 in.). Where an obstruction or surface less than 1 100 mm (42 in.) above the top landing other than machine housing, stationary guard panels, shutter-type (telescoping) guard panels, or sides used for entering and exiting is within 300 mm (12 in.) of the platform enclosure walls and presents a pinching, shearing, or crushing hazard, a smooth continuous surface shall be provided extending from the lower landing to a height of not less than 1 100 mm (42 in.) above the top landing. Where an obstruction or surface is between 1 100 mm (42 in.) and 2 000 mm (79 in.) above the top landing, a smooth continuous surface shall be provided extending from the lower landing to a height of not less than 75 mm (3 in.) above the obstruction. The continuous surface shall be located on the lift side of the obstruction not closer than 50 mm (2 in.) to the platform enclosure walls.

2.1.3 Runway Enclosure Not Provided

2.1.3.1 The runway entrance shall be guarded at the upper landing by a door of unperforated construction. The door shall be self-closing, at least 1 100 mm (42 in.) high, and withstand, without permanent deformation, a force of 550 N (125 lbf) applied on a 100 mm × 100 mm (4 in. × 4 in.) area. The lift side of the door and sill shall present a smooth surface located not closer than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.) from the access edge of the platform floor.

2.1.3.2 The runway entrance shall be guarded at any intermediate landing by a door of unperforated construction not wider than the entrance to the platform plus 25 mm (1 in.). The door shall be self-closing and extend to a height of at least 1 100 mm (42 in.) above the top terminal landing. The lift side of the door and sill shall present a smooth surface located not closer than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.) from the access edge of the platform floor.

2.1.3.3 A smooth vertical surface shall be provided (20) from the top terminal landing sill and any intermediate landing sill to not less than 25 mm (1 in.) below the level of the platform floor on the lower mechanical stop. Where a pit is provided and is less than 25 mm (1 in.) in depth, the surface shall extend to the pit floor. Openings necessary for operation shall reject a ball 12 mm (0.5 in.) in diameter.

The surface shall be capable of withstanding a force 330 N (75 lbf) on a 100 mm × 100 mm (4 in. × 4 in.) surface and have deflection less than 20 mm (0.75 in.) in any location. The surface shall not be permanently deformed when a force of 550 N (125 lbf) is applied on any 100 mm × 100 mm (4 in. × 4 in.) area.

Projections from the vertical surface shall not exceed 5 mm (0.20 in.); projections exceeding 2 mm (0.08 in.) shall be beveled at an angle of 15 deg or less to the line of travel. The clearance between the platform edge and the landing sill or any vertical surface of the hoistway shall be not less than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.).

2.1.3.4 The side of the platform providing access to the lower landing shall be guarded in accordance with the requirements of 2.1.3.4.1 or 2.1.3.4.2.

2.1.3.4.1 The lower landing side of the platform shall be guarded by a platform door of unperforated construction. The door shall be self-closing, at least 1 100 mm (42 in.) high, and withstand, without permanent deformation, a force of 550 N (125 lbf) on a 100 mm × 100 mm (4 in. × 4 in.) area.

2.1.3.4.2 The lower landing side of the platform shall be guarded by a powered, retractable passenger restraining arm(s) conforming to the following:

(a) The arm(s) shall be located above the leading edge of the platform on the lower landing side at a height of not less than 800 mm (32 in.) or greater than 1 000 mm (38 in.). Gaps between the adjacent ends of arm sections or the end of arm sections and the lift sidewall shall not exceed 100 mm (4 in.) when the arms are in their guarding position.

(b) The arm(s) shall be of smooth construction with all edges rounded. They shall not be permanently deformed when a force of 300 N (66 lbf) is applied on any point along the length of the arms in any direction. In addition, they shall not be permanently deformed when a force of 1 000 N

(225 lbf) is applied in the horizontal direction along the centerline of the platform.

(c) Each retractable arm shall be mechanically locked and monitored by an electric contact, which shall stop the movement of the platform within 50 mm (2 in.) of travel away from any landing if the arm is not in its locked guarding position. Means shall be provided to manually unlock the retractable arm(s) for emergency evacuation purposes. The unlocking mechanism shall not be readily accessible to the passenger.

(d) Control shall be by means of a continuous-pressure device. The closing speed shall not exceed 0.3 m/s (1 ft/sec) as measured at the fastest point. The force necessary to prevent closing of the arm(s) shall not exceed 140 N (30 lbf) as measured at the midpoint across the arm at the boarding end of the platform. The arm(s) may operate in the direction away from an obstruction.

(e) A retractable ramp shall be provided in conformance with 2.1.8.2.

2.1.3.5 The sides of the platform not used for entrance or exit shall be guarded by walls of smooth construction with no openings, other than those necessary for the operation of the lift, to a height of at least 1 100 mm (42 in.). Those openings necessary for operation shall reject a ball 12 mm (0.5 in.) in diameter. A grab bar extending the full length of either side guard shall be provided at a height of 850 mm (34 in.) to 1 000 mm (38 in.).

The running clearance between the platform enclosure walls and the machine housing or any other rigid surface shall be not less than 50 mm (2 in.). Where an obstruction or surface less than 1 100 mm (42 in.) above the top landing other than the machine housing is within 300 mm (12 in.) of the platform enclosure walls and presents a pinching, shearing, or crushing hazard, a smooth continuous surface shall be provided extending from the lower landing to a height of not less than 1 100 mm (42 in.) above the top landing. Where an obstruction or surface is between 1 100 mm (42 in.) and 2 000 mm (80 in.) above the top landing, a smooth continuous surface shall be provided extending from the lower landing to a height of not less than 75 mm (3 in.) above the obstruction.

2.1.3.6 The underside of the platform shall be guarded in accordance with the requirements of 2.1.3.6.1, 2.1.3.6.2, or 2.1.3.6.3.

2.1.3.6.1 The underside of the platform shall be equipped with a device that, if the platform is obstructed anywhere on its underside in its downward travel, shall cause electric power to be removed from the driving-machine motor and brake, if provided, and cause the platform to stop its downward motion within 50 mm (2 in.). The stroke of the device shall be not less than the stopping distance of the platform. The force required to operate the device shall not exceed 70 N (15 lbf). The lift shall be

permitted to operate away from the obstruction. Downward motion shall be permitted to resume when the obstruction is removed.

2.1.3.6.2 The underside of the platform shall be equipped with a bellows or similar device that shall not be permanently deformed when a force of 550 N (125 lbf) is applied on any 100 mm × 100 mm (4 in. × 4 in.) area. Deflection of the bellows due to a force of 330 N (75 lbf) applied on any 100 mm × 100 mm (4 in. × 4 in.) area shall not exceed 75 mm (3 in.) or the distance to contact an internal moving component other than the bellows support mechanism, whichever is less. Deflection shall be measured with the platform at the uppermost landing.

(a) The upper attachment point of the bellows shall be permitted to be inset from the outer edge of the platform, provided that the exposed area of the underside of the platform is equipped with a device that conforms to 2.1.3.6.1.

(b) Deflection greater than that allowed by 2.1.3.6.2 shall be permitted, provided that any additional deflection actuates a sensing device that causes the electric power to be removed from the driving-machine motor and brake, if provided, and causes the platform to stop its downward motion within 50 mm (2 in.). Downward motion shall be permitted to resume when the bellows is returned to its normal condition.

2.1.3.6.3 A force-sensitive safety surface shall be provided covering the entire floor area directly under the moving platform plus 75 mm (3 in.) beyond any exposed platform edge. The device shall prevent downward motion of the platform when activated by a force not to exceed 70 N (15 lbf) applied anywhere on its surface. The lift shall be permitted to operate in the upward direction. Downward motion shall be permitted to resume when the force is removed.

2.1.3.7 The clearance between the platform floor and the upper landing sill shall be not less than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.).

2.1.3.8 All doors, except as provided in 2.1.3.9, shall be provided with a combination mechanical lock and electric contact. Locking devices shall be protected against tampering from the landing side. The locking devices shall permit a door to be opened only if the platform floor is within 50 mm (2 in.) of the respective landing. The platform shall be permitted to move away from the landing under control of the normal operating device if the door is closed but not locked, provided that the devices will cause the platform to stop if it moves away from the landing more than 50 mm (2 in.) before the door is locked.

2.1.3.8.1 Door-locking devices shall comply with 2.1.1.4.1.

2.1.3.9 Where the lift is installed at a location that does not have guard rails at the upper landing as allowed by building codes (see definition), the requirements of 2.1.3.1 through 2.1.3.3 shall be permitted to be omitted when platform gates are provided. They shall extend to a height at least equal to the top terminal landing height plus 150 mm (6 in.) measured when the platform is at its lowest position. The gates shall be of unperforated construction, be self-closing, and be provided with electric contacts to prevent movement of the platform if the gates are not closed. The gates shall not be permanently deformed when a force of 550 N (125 lbf) is applied on any 100 mm × 100 mm (4 in. × 4 in.) area.

2.1.3.10 The requirements of 2.1.3.7 shall be permitted to be increased to 75 mm (3 in.) if a platform gate complying with 2.1.3.9 and an automatically folding ramp to service the upper landing is provided. When deployed, the ramp shall have a minimum overlap at the upper landing sill of 50 mm (2 in.) and shall be substantially level. It shall be provided with an electric contact, which will stop the movement of the platform within 150 mm (6 in.) of travel away from the upper landing if the ramp has failed to rise to its retracted position.

2.1.4 Courtroom Lifts

2.1.4.1 The runway entrance shall be guarded at the uppermost landing by a door of unperforated construction. The door shall be self-closing or power operated, at a height not less than 900 mm (36 in.), and shall withstand, without permanent deformation, a force of 550 N (125 lbf) applied on any 100 mm × 100 mm (4 in. × 4 in.) area. The lift side of the door and sill shall present a smooth surface located not closer than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.) from the access edge of the platform floor.

2.1.4.2 Intermediate landing entrances shall be guarded in accordance with the requirements of 2.1.4.2.1 or 2.1.4.2.2.

2.1.4.2.1 The runway entrance at any intermediate landing entrance shall be guarded by a self-closing or power-operated door of unperforated construction not wider than the entrance to the platform plus 25 mm (1 in.). The door shall be a minimum height of 150 mm (6 in.) and extend to the top landing plus 75 mm (3 in.). The lift side of the door and sill shall present a smooth surface located not closer than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.) from the edge of the platform floor.

2.1.4.2.2 Any intermediate landing entrance shall be guarded by a self-closing or power-operated guard of smooth, solid construction not wider than the entrance to the platform plus 25 mm (1 in.) and of a height not less than 150 mm (6 in.). The side of the platform facing the intermediate landing shall be provided with a platform-mounted guard of smooth, solid construction, at least the

width of the landing entrance and of a height not less than 150 mm (6 in.).

2.1.4.3 The area under the platform shall be fully enclosed by smooth guards, either telescoping or stationary, on all accessible platform sides. The guards shall withstand, without permanent deformation, a force of 550 N (125 lbf) applied on any 100 mm × 100 mm (4 in. × 4 in.) area. Shutter-type (telescoping) guards, if provided, shall be securely fastened to the lower landing level and to the platform. Openings necessary for operation of guards shall reject a ball 12 mm (0.5 in.) in diameter.

2.1.4.4 A smooth vertical surface shall be provided (20) from the top terminal landing sill and any intermediate landing sill to not less than 25 mm (1 in.) below the level of the platform floor on the lower mechanical stop. Where a pit is provided and is less than 25 mm (1 in.) in depth, the surface shall extend to the pit floor. Openings necessary for operation shall reject a ball 12 mm (0.5 in.) in diameter.

The surface shall be capable of withstanding a force of 330 N (75 lbf) on a 100 mm × 100 mm (4 in. × 4 in.) surface and have deflection less than 20 mm (0.75 in.) in any location. The surface shall not be permanently deformed when a force of 550 N (125 lbf) is applied on any 100 mm × 100 mm (4 in. × 4 in.) area.

Projections from the vertical surface shall not exceed 5 mm (0.20 in.), and projections exceeding 2 mm (0.08 in.) shall be beveled at an angle of 15 deg or less to the line of travel. The clearance between the platform edge and landing sill or any vertical surface of the hoistway shall be not less than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.).

2.1.4.5 The runway entrance shall be guarded at the lower landing by a door of unperforated construction. The door shall be self-closing or power operated, at a height not less than 900 mm (36 in.), and shall withstand, without permanent deformation, a force of 550 N (125 lbf) on a 100 mm × 100 mm (4 in. × 4 in.) area. The clearance between the lower landing door and platform edge shall be not less than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.).

2.1.4.6 The sides of the platform not used for entrance or exit shall be guarded by stationary runway or platform-mounted sidewalls of solid construction with no openings, other than those necessary for the operation of the lift. Those openings necessary for operation shall reject a ball 12 mm (0.5 in.) in diameter. Platform-mounted sidewalls shall be at a height not less than 900 mm (36 in.). The running clearance between a platform-mounted sidewall and stationary surfaces shall be not less than 50 mm (2 in.) nor more than 75 mm (3 in.). Stationary runway sidewalls shall be at a height not less than 900 mm (36 in.) above the lower landing. The clearance between stationary runway sidewalls and the

platform shall be not less than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.).

2.1.4.7 All doors/guards shall be provided with a combination mechanical lock and electric contact. Locking devices shall be protected against tampering from the landing side. The locking devices shall permit a door/guard to be opened only if the platform floor is within 50 mm (2 in.) of the respective landing. The platform shall be permitted to move away from the landing under control of the normal operating device if the door/guard is closed but not locked, provided that the devices will cause the platform to stop if it moves away from the landing more than 50 mm (2 in.) before the door/guard is locked.

2.1.4.7.1 Door-locking devices shall comply with 2.1.1.4.1.

2.1.5 Relocatable Lifts

2.1.5.1 Relocatable lifts shall comply with section 2 and with 2.1.5.2 through 2.1.5.6.

- (20) **2.1.5.2 Level Surface.** A device shall be provided to prevent the lift from operating if it is out of level more than 1:20 (5%) in any direction.

2.1.5.3 Stability. When the relocatable lift is placed on an incline equal to 1:20 (5%) in any direction, the unsecured lift shall not tip over if a horizontal force of 550 N (125 lbf) is applied to the uppermost part of the lift in any direction, both with the full load centered in any of the four quadrants of the platform floor at maximum travel height and with no load.

2.1.5.4 Alignment. A sign shall be securely fastened to the lift in a location conspicuous to personnel setting up the relocatable lift stating: "Align lift with the upper landing edge per manufacturer's instructions."

2.1.5.5 Electrical Connection. A disconnecting means in accordance with ANSI/NFPA 70 shall be provided as part of the lift.

2.1.5.6 Wheels. Lifts that have wheels shall be operable only when the wheels are removed or retracted. The wheels shall not bear any load while the lift is in operation.

- (20) **2.1.6 Performance Area Lifts.** Performance area lifts shall be permitted only where the building codes do not require a railing at the upper level.

2.1.6.1 The lift platform shall be surrounded on three sides by the fixed upper level landing, vertical surface(s), or a wall.

A smooth vertical fascia shall be provided from the top terminal landing sill to the level of the bottom terminal landing sill. Intermediate landings shall not be permitted.

The vertical fascia shall be a bright, contrasting color. Openings necessary for operation shall reject a ball 12 mm (0.5 in.) in diameter.

The fascia shall fully guard the three fixed sides of the platform.

The surface shall not be permanently deformed when a force of 550 N (125 lbf) is applied on any 100 mm × 100 mm (4 in. × 4 in.) area.

The clearance between the vertical fascia and platform edge shall be not less than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.).

2.1.6.2 Each edge of the platform shall have an edge treatment with a 6 mm ± 1 mm (0.25 in. ± 0.04 in.) rise. This edge treatment shall have beveled edges on both sides, and shall be an anti-slip surface of a color in contrast to the platform surface.

2.1.6.3 The upper level landing shall have a distinctive marking stripe at each edge next to the opening created by the platform. Such stripe shall be not less than 25 mm (1 in.) nor more than 50 mm (2 in.) wide. The edge treatment shall be an anti-slip surface of a color in contrast to the surrounding surfaces.

The upper landing edges shall be equipped with LED warning lights that are activated when the platform is away from the upper landing. The lights shall be not more than 150 mm (6 in.) apart and shall not present a tripping hazard.

2.1.6.4 A beeping or voice-audible signal shall operate whenever the platform is in motion and shall sound 2 s before the platform begins to move. The audible signaling device shall have a rated sound pressure rating of not less than 50 dBA nor greater than 60 dBA at 1500 mm (60 in.) from the platform.

2.1.6.5 The area under the accessible platform side shall be fully enclosed on the lower landing access side by a smooth guard, either telescoping or stationary. The guard shall withstand, without permanent deformation, a force of 550 N (125 lbf) applied on any 100 mm × 100 mm (4 in. × 4 in.) area. A shutter-type (telescoping) guard, if provided, shall be securely fastened to the lower landing level and to the platform. Openings necessary for operation of guards shall reject a ball 12 mm (0.5 in.) in diameter.

2.1.7 Pipes in Runway Vicinity. Pipes conveying steam, gas, or liquids that, if discharged into the runway, would endanger life or health shall not be permitted.

2.1.8 Lower Level Access Ramps and Pits. Lifts shall be permitted to have a pit. Unenclosed pits shall not exceed 100 mm (4 in.) in depth. Where a pit is not provided, a floor-mounted or retractable platform floor-mounted ramp shall be provided in accordance with 2.1.8.1 or 2.1.8.2.

2.1.8.1 Ramping inclinations for floor-mounted ramps shall be not greater than

- (a) 1 in 8 for heights up to 75 mm (3 in.)
- (b) 1 in 10 for heights up to 100 mm (4 in.)

- (c) 1 in 12 for heights greater than 100 mm (4 in.)

2.1.8.2 Retractable ramps shall be automatically actuated to a position of 70 deg minimum from horizontal and shall remain in their elevated position until the platform returns to the landing. When in use, the inclination of the ramps shall be not greater than

- (a) 1 in 4 for heights up to 50 mm (2 in.)
- (b) 1 in 6 for heights up to 65 mm (2.5 in.)
- (c) 1 in 8 for heights up to 75 mm (3 in.)
- (d) 1 in 10 for heights up to 100 mm (4 in.)
- (e) 1 in 12 for heights greater than 100 mm (4 in.)

2.1.8.3 On lifts installed exterior to a building, permanent provisions shall be made to prevent accumulation of water in the pit.

2.1.8.4 Where the pit extends more than 150 mm (6 in.) below the sill of the lowest runway entrance door, there shall be installed within 600 mm (24 in.) of the pit floor

(a) a permanent, externally guarded lighting fixture, providing illumination of not less than 100 lx (10 fc) at the pit floor. The light switch shall be so located as to be accessible from the pit access door.

(b) at least one 125-V, single-phase GFI duplex receptacle.

2.1.8.5 For lifts conforming to the requirements of 2.1.1 or 2.1.2, access to pits shall be by means of the lowest runway entrance door or by means of a separate pit access door in accordance with 2.1.8.5.1 or 2.1.8.5.2. A stop switch meeting the requirements of 2.10.6 shall be installed within the runway enclosure where it is accessible from the pit access door.

2.1.8.5.1 Where access is through the lowest runway entrance door and the pit extends more than 900 mm (35 in.) below the sill of the lowest runway entrance door, a fixed vertical ladder of noncombustible material, located within reach of the access door, shall be installed in the pit. The ladder shall extend not less than 1 200 mm (48 in.) above the sill of the access door. The rungs, cleats, or steps shall be a minimum of 400 mm (16 in.) wide. When unavoidable obstructions are encountered, the width shall be permitted to be decreased to less than 400 mm (16 in.). The reduced width shall be as wide as the available space permits, but not less than 225 mm (9 in.). The rungs, cleats, or steps shall be spaced 300 mm (12 in.) on center. A clear distance of not less than 180 mm (7 in.) from the centerline of the rungs, cleats, or steps to the nearest permanent object in back of the ladder shall be provided. When unavoidable obstructions are encountered, the distance shall be permitted to be reduced to 115 mm (4.5 in.). Side rails, if provided, shall have a clear distance of not less than 115 mm (4.5 in.) from their centerline to the nearest permanent object. The nearest point of the ladder shall be within 1 000 mm (39 in.), measured horizontally from the means to unlock the egress door from the pit.

zontally from the means to unlock the egress door from the pit.

Pit access by a ladder shall not be permitted when the pit floor is more than 3 000 mm (120 in.) below the sill of the access door.

2.1.8.5.2 A separate pit access door, when provided, shall be subject to the following requirements:

(a) If the door swings into the pit, it shall be located so that it does not interfere with moving equipment.

(b) If the door swings out, and the lowest structural or mechanical part, equipment, or device installed beneath the platform, except guide shoes or rollers or safety jaw assemblies, projects below the top of the separate pit access door opening when the car is level with the bottom terminal landing

(1) an electric contact shall be provided to prevent operation of the lift when the door is open

(2) the door shall be provided with a vision panel(s) that is glazed with clear wired glass not less than 6 mm (0.25 in.) thick, will reject a ball 150 mm (6 in.) in diameter, and has an area not more than 0.03 m² (47 in.²)

(c) The door shall provide a minimum opening of 750 mm (29.5 in.) in width and 1 825 mm (72 in.) in height.

(d) The door sill shall be not more than 300 mm (12 in.) above the pit floor.

(e) The door shall be self-closing and provided with a spring-type lock arranged to permit the door to be opened from the inside of the pit without a key. Such doors shall be kept closed and locked.

2.1.8.6 Where the distance from the pit floor to the underside of the platform exceeds 2 100 mm (83 in.) with the platform at the lowest landing, a means shall be permanently installed or permanently stored in the pit to provide access to the equipment on the underside of the platform.

2.1.9 Electrical Equipment and Wiring

2.1.9.1 The installation of electrical equipment and wiring shall conform to the requirements of NFPA 70.

2.1.9.2 Electrical equipment shall be certified to the requirements of CAN/CSA-B44.1/ASME A17.5.

2.1.10 Structural Support. The structure on which the equipment is installed shall be capable of safely supporting the loads imposed.

2.1.11 Headroom Clearance. Headroom clearance throughout the range of travel shall be not less than 2 000 mm (79 in.) as measured vertically from the platform floor.

2.2 Guide Rails

Guide rails shall conform to the requirements of 2.2.1 through 2.2.7. Where tee rails are provided, they shall also conform to the requirements of 2.2.8 and 2.2.9. Rail joints shall be designed to maintain the accuracy of the rail

alignment and to withstand the stress and deflection limitations stipulated in 2.2.4.

2.2.1 Material. Guide rails, guide-rail brackets, rail clips, fishplates, and their fastenings shall be of steel or other metals conforming to the requirements of 2.2. Where steel may present an accident hazard, as in chemical or explosive plants, guide rails shall be permitted to be of selected wood or other suitable nonmetallic materials.

2.2.2 Requirements for Steel, Where Used

2.2.2.1 Rails, brackets, fishplates, and rail clips shall be made of open-hearth steel or its equivalent having a tensile strength of not less than 380 MPa (55,000 psi) and having an elongation of not less than 22% in a length of 50 mm (2 in.).

2.2.2.2 Bolts shall conform to ASTM A307.

2.2.2.3 Rivets shall conform to ASTM A502.

2.2.3 Requirements for Metals Other Than Steel. Metals other than steel shall be permitted to be used, provided the factor of safety is not less than, and the deflections are not more than, the values specified in this section, and provided that cast iron is not used.

2.2.4 Stresses and Deflections

2.2.4.1 Guide Rails. For steels conforming to the requirements of 2.2.2, the stresses in a guide rail or in the rail and its reinforcement, due to the horizontal forces imposed on the rail during loading, unloading, or running, calculated without impact, shall not exceed 100 MPa (15,000 psi), and the deflection shall not exceed 6 mm (0.25 in.).

Where steels of greater strength than those specified in 2.2.2 are used, the stresses specified shall be permitted to be increased proportionately based on the ratio of the ultimate strengths.

2.2.4.2 Brackets, Fastenings, and Supports. The guide-rail brackets, their fastenings, and supports, such as building beams and walls, shall be capable of resisting the horizontal forces imposed by rated load with a total deflection to the point of support not in excess of 3 mm (0.125 in.).

2.2.5 Guide-Rail Surfaces. Guide-rail surfaces used for guiding a platform or counterweight shall be sufficiently smooth and true to operate properly with the guiding members. Those surfaces that the platform or counterweight safeties engage shall be smooth and true within the tolerances required to ensure proper safety application without excessive retardation or excessive out-of-level platform floor conditions resulting.

2.2.6 Overall Length of Guide Rails. The platform and counterweight guide rails shall extend at the top and bottom to prevent the guiding members from disengaging

from the guide rails if either the platform or counterweight reaches its extreme limit of travel.

2.2.7 Design and Strength of Brackets and Supports.²

The building construction forming the supports for the guide rails, and the guide-rail brackets, shall be designed to safely withstand the application of the platform or counterweight safety when stopping the platform and its rated load or the counterweight; and shall withstand the forces specified in 2.2.4.2 within the deflection limits specified.

Where necessary, the building construction shall be reinforced to provide adequate support for the guide rails.

2.2.8 Bracket Fastenings. Guide-rail brackets shall be secured to their supporting structure by means of bolts or rivets, or by welding. Fastening bolts and bolt holes in brackets and their supporting beams shall conform to the requirements of 2.2.9. Welding, where used, shall conform to the requirements of 9.1.

2.2.9 Fastening of Guide Rails to Rail Brackets. Guide rails shall be secured to their brackets by clips, welds, or bolts. Bolts used for fastening shall be of such strength as to withstand the forces specified in 2.2.4.2 and 2.2.7.

Welding, where used, shall conform to the requirements of 9.1.

2.3 Driving Means and Sheaves

The driving means shall be one of the following:

- (a) winding drum
- (b) traction
- (c) roped sprocket
- (d) chain sprocket
- (e) screw
- (f) rack and pinion
- (g) direct-plunger hydraulic
- (h) roped-hydraulic
- (i) lever hydraulic
- (j) lever screw
- (k) friction

Driving means using a combination of two or more means shall conform to all applicable requirements of the respective means unless stated otherwise.

2.3.1 General Requirements

2.3.1.1 The factor of safety, based on the static load (the rated load plus the weight of the platform, ropes, counterweights, etc.), to be used in the design of driving machines and sheaves, including fasteners transmitting load, shall be not less than 8 for steel, bronze, or other metals having an elongation of less than 14% in a length of 50 mm (2 in.) or 10 for cast iron or other metals having an elongation of less than 14% in a length of 50 mm

² Runway enclosure walls of brick, terra cotta, and similar materials, used in buildings of steel and concrete construction, are usually insufficient in strength to form, by themselves, adequate supports for the guide rails.

(2 in.). Other factors of safety for specific driving means are further specified in [section 8](#).

2.3.1.2 Set screws or threaded portions located in the shear plane of bolts and screws shall not be used to transmit load.

Means shall be provided to ensure that there is no relative motion between rigidly joined components transmitting load.

Where flexible couplings are used to transmit load, means shall be provided to prevent disengagement of the coupling components in the event of failure or excessive motion in the flexible connection.

A fillet shall be provided at any point of change in the diameter of driving-machine shafts and sheave shafts to prevent excessive stress concentrations in the shafts.

Shafts that support drums, sheaves, gears, couplings, and other members, and which transmit torque, shall be provided with tight-fitting keys.

2.3.1.3 Friction gearing, clutch mechanisms, or couplings shall not be used to connect a driving-machine drum or sheave to the main driving mechanism.

2.3.1.4 Worm gearing having cast iron teeth shall not be used on the driving machine.

2.3.1.5 Driving-machine chains and sprockets shall be of steel and shall conform in design and dimensions to the requirements of ASME B29.1.

2.3.1.6 Winding drums, traction sheaves, overhead sheaves, and deflecting sheaves used with suspension and compensating ropes shall be of metal, shall be provided with finished grooves for ropes, or shall be permitted to be lined with nonmetallic groove material, and have a pitch diameter of not less than 30 times the diameter of the suspension ropes. Where 8×19 steel rope or 7×19 steel aircraft cable is used, the pitch diameter of the drums and sheaves shall be permitted to be reduced to 21 times the diameter of the rope or cable.

Where the grooves are used to transmit power, sufficient traction shall be provided between the rope and groove, and in the event of nonmetallic lining failure, between the rope and the remaining sheave groove, to safely stop and hold the platform with 125% of the rated load.

2.3.2 Hydraulic Driving Machines. Direct-plunger hydraulic driving machines, where used, shall conform to the requirements of [8.1](#), except [8.1.2](#). Roped-hydraulic and chain-hydraulic machines shall also conform to the requirements of [8.1](#) except for [8.1.1](#), [8.1.3](#), and [8.1.4.3](#).

2.3.3 Screw Machines. Screw machines, where used, shall conform to [8.2](#).

2.3.4 Friction Machines. Friction machines, where used, shall conform to [8.3](#).

2.3.5 Machine Framework and Base. The machine framework, base, and fastenings to the buildings, where used, shall be of metal construction, have a factor of safety of not less than 5 based on the rated load, and shall be secured in place with support provided to limit their deflections to 6 mm (0.25 in.) maximum in any direction under rated load. Cast iron shall not be used.

2.3.6 Guarding of Guiding Members. The guiding members shall be guarded to prevent accidental contact. Any opening necessary in guards for operation shall reject a ball 20 mm (0.75 in.) in diameter.

2.3.7 Machinery Beams and Supports

2.3.7.1 All machinery and sheaves shall be supported and secured to prevent any part becoming loose or displaced. Beams directly supporting machinery shall be of steel or reinforced concrete.

2.3.7.2 Overhead beams and sheaves shall be designed for not less than the total load on overhead beams, which shall be assumed to be equal to the weight of all apparatus resting on the beams plus twice the maximum load suspended from the beams. The load resting on the beams shall include the complete weights of the driving machine, sheaves, controller, etc. The load suspended from the beams shall include the sum of the tensions in all ropes suspended from the beams.

2.3.7.3 The driving machine or sheaves, except idlers or deflecting sheaves with their guards and frames, shall not be fastened to the underside of the supporting beams at the top of the runway.

2.3.7.4 Cast iron in tension shall not be used for supporting members for sheaves where they are hung beneath beams.

2.3.8 Guarding of Driving Machines and Suspension (20)

Means. The driving machine and suspension means shall be guarded to prevent accidental contact. Any opening required for operation shall reject a ball 20 mm (0.75 in.) in diameter. Access shall be provided for inspecting and servicing. Any guard(s) required to be removed for inspecting and servicing shall be secured in place using tamper-resistant fasteners or other tamper-resistant means.

2.3.9 Indirect-Drive Machines. Indirect-drive machines, using V-belt drives, tooth drive belts, or drive chains, shall conform to the requirements of [2.3.9.1](#) through [2.3.9.3](#), except that the requirements of [2.3.9.2](#) shall be permitted to be omitted if a self-locking drive meeting the requirements of [2.4.3](#) is provided. If multiple belts or chains are provided, they shall be preloaded and matched for length in sets.

2.3.9.1 General Requirements. Belt sets shall be selected on the basis of the manufacturer's rated breaking strength and a factor of safety of 10. Chain and sprocket

sets shall be selected on the basis of recommendations set forth in the Supplementary Information section of ASME B29.1, using a service factor of 2. Offset links in chain are not permitted.

Sprockets in a chain-drive set and also a driven set shall be assembled onto a common hub, with teeth cut in-line after assembly to ensure equal load distribution on all chains. Tooth sheaves for a belt drive shall be constructed in a manner to ensure equal load distribution on each belt in the set. Load determination for both the belt and chain sets shall be based on the maximum static loading on the platform, which is the full load in the platform at rest and at a position in the runway that creates the greatest load, including either the platform or counterweight resting on its buffer.

Chain drives and belt drives shall be guarded to protect against accidental contact and to prevent foreign objects from interfering with drives.

2.3.9.2 Monitoring and Brake Location. Each belt or chain in a set shall be continuously monitored by a broken belt or chain device that shall function to automatically interrupt power to the machine and apply the brake if any belt or chain in the set breaks or becomes excessively slack. The driving machine brake shall be located on the traction sheave or drum assembly side of the driving machine so as to be fully effective if the entire belt set or chain set should break.

2.3.9.3 Replacement of Belts or Chains. If one belt or chain of a set is worn, stretched, or damaged so as to require replacement, the entire set shall be replaced. Sprockets and toothed sheaves shall also be replaced if worn.

2.4 Driving-Machine Brakes

2.4.1 Driving machines, except hydraulic, shall be equipped with friction brakes directly attached to the driving means through a continuous shaft, mechanical coupling, or toothed gearing applied by springs, or by gravity, and released electrically.

2.4.2 A single ground or short circuit, a counter voltage, or a motor-field discharge shall not prevent the brake magnet from allowing the brake to set when the operating device is placed in the stop position.

2.4.3 A machine brake is not required if a self-locking drive using a lead screw, worm, or other positive gearing that will stop and hold the platform with the rated load within 100 mm (4 in.) of down travel after the power is removed is provided.

2.5 Suspension and Support Means

2.5.1 General Requirements

2.5.1.1 Suspension and support means shall be one or more of the following:

- (a) steel or iron wire rope
- (b) steel aircraft cable
- (c) chain
- (d) hydraulic
- (e) rack and pinion
- (f) screw
- (g) friction machine guides and rollers
- (h) lever

Suspension and support means using a combination of two or more means shall conform to all applicable requirements of the respective means unless stated otherwise.

2.5.1.2 Steel tapes or welded link chains shall not be used as suspension means.

2.5.1.3 Where ropes or chains are used, no fewer than two shall be provided.

2.5.1.4 For rated loads up to 230 kg (500 lb), ropes shall have a minimum diameter of 6 mm (0.25 in.) and chains shall have a minimum pitch of 12 mm (0.5 in.). For higher rated loads, ropes shall have a minimum diameter of 10 mm (0.375 in.) and chains shall have a minimum pitch of 15 mm (0.625 in.).

2.5.2 Factors of Safety. The suspension and support means shall have a factor of safety of not less than 7 based on the tension or forces exerted on the suspension and support means when raising the rated load. When the platform and counterweight are suspended by steel ropes and the driving means between the machine and the counterweight is an endless roller-type chain, the factor of safety of such chain shall be not less than 8, based on the rated load. See [section 8](#) for special requirements for particular drive systems.

2.5.3 Arc of Contact of Suspension Means on Sheaves and Sprockets. The arc of contact of a wire rope on a traction sheave shall be sufficient to produce adequate traction under all load conditions. The arc of contact of a chain on a driving sprocket shall be not less than 140 deg.

2.5.4 Spare Rope Turns on Winding Drums. All wire ropes of winding drum machines shall have not less than one full turn of the rope on the drum when the platform or counterweight has reached its limit of possible overtravel.

2.5.5 Securing Suspension Ropes to Winding Drums. The drum ends of wire ropes shall be secured on the inside of the drum of winding drum machines by clamps or by tapered babbitted sockets, or by other means approved by the authority having jurisdiction.

2.5.6 Lengthening, Splicing, Repairing, or Replacing Suspension Means. Suspension ropes shall not be lengthened or repaired by splicing. Broken or worn suspension chains shall not be repaired. If one rope or chain of a set is worn or damaged and requires replacement, the entire set of ropes or chains shall be replaced. If a chain or sprocket is

replaced due to wear, all chains and sprockets shall be replaced.

2.5.7 Fastening of Rope Suspension Means to Platform. The platform ends of wire ropes shall be fastened in a return loop by properly made individual tapered babbitted sockets or properly attached fittings as recommended by wire rope manufacturers. Clips of the U-bolt type shall not be used. Tapered babbitted rope sockets and the method of babbitting shall conform to the requirements of 9.8.

2.5.8 Guarding. All suspension means shall be guarded against accidental contact. Suspension means that operate within a guide or track and travel at the same speed and in the same direction as the platform shall be considered suitably guarded.

2.6 Platforms

2.6.1 Frame and Floor. The frame shall be of metal construction and have a factor of safety of not less than 5 based on the rated load. The floor shall be of metal or wood construction with a nonskid surface.

- (20) **2.6.2 Securing of Enclosures.** Enclosures are required on all platforms, except for lifts complying with 2.1.6. The enclosure shall be securely fastened to the floor and supported so that it cannot loosen or become displaced in ordinary service, on the application of the platform safety, or on buffer engagement. The enclosure shall be constructed so that removable portions cannot be dismantled from within the platform.

Enclosure linings, decorative panels, light fixtures, and other apparatus or equipment attached to the enclosure shall be securely fastened and supported so that they will not loosen or become displaced in ordinary service, on platform safety application, or on buffer engagement.

Panels attached to the enclosure for decorative or other purposes shall not be unfastened from inside the platform by the use of common tools. Panels with perforations that would reject a ball greater than 12 mm (0.5 in.) in diameter shall be removed from inside the platform. The enclosure used for panel hanging or support shall have permanent means to prevent straight-through passage beyond the running clearance.

- (20) **2.6.3 Strength and Deflection of Enclosure Walls.** The enclosure walls shall be designed and installed to withstand a force of 330 N (75 lbf) applied horizontally at any point on the walls of the enclosure without permanent deformation or causing the deflection to exceed 25 mm (1 in.).

2.6.4 Use of Cast Iron. Cast iron shall not be used in the construction of any load-bearing member of the platform frame or floor other than for guide shoes and guide shoe brackets.

2.6.5 Floor Area. The inside net floor area of lifts conforming to 2.1.1 through 2.1.3 and 2.1.6 shall not exceed 1.7 m² (18 ft²). The inside net floor area of lifts conforming to 2.1.4 shall not exceed 2.3 m² (25 ft²). (20)

2.6.6 Illumination

2.6.6.1 At the threshold of the floor, with the landing door open, the minimum illumination shall be not less than 50 lx (5 fc).

2.6.6.2 During operation, the minimum illumination on the floor and controls shall be not less than 50 lx (5 fc).

2.6.6.3 An auxiliary illumination source to provide general illumination of not less than 2.2 lx (0.2 fc) on the floor and controls shall be provided.

The auxiliary system shall be automatically activated when normal illumination power fails and shall be capable of maintaining the above illumination intensity for a period of not less than 4 h and shall use no fewer than two lamps of approximately equal wattage.

2.6.7 Protection of Platforms Against Fire. For lifts that penetrate a floor, and when fire-resistive runway enclosure construction is required by the building code, the platform enclosure, which includes the walls, top, and floor, shall be protected against fire. Where the materials used for the platform enclosure do not have a flame spread rating less than 75, the platform enclosure shall be protected against fire by one of the following methods:

(a) covering with sheet steel a minimum of 0.4 mm (0.0164 in.) in thickness or with equally fire-retardant material.

(b) painting with an approved fire-retardant paint having a flame spread rating of not over 75, applied in accordance with the instructions of the manufacturer. Such ratings shall be based on the test procedure specified in ASTM E8.

A pictograph as shown in Figure 2.6.7 should be posted over each platform lift corridor call station. The pictograph is 125 mm (5 in.) wide and 200 mm (8 in.) high.

2.6.7.1 Grab rails, operating devices, signal fixtures, and audio and visual communication devices and their housings are not required to conform to 2.6.7.

2.6.8 A full passenger enclosure shall not be permitted.

2.6.8.1 Platforms shall be permitted to have a top, provided the top is non-load-bearing and marked to indicate it cannot sustain a load.

2.6.9 Glass in Platform Enclosures and in Runway Enclosures. Glass shall be permitted to be used subject to the requirements of 2.6.9.1 through 2.6.9.4. (20)

2.6.9.1 Glass shall be installed and guarded to provide adequate protection for passengers in case the glass panels break or are dislodged.

Figure 2.6.7 Platform Lift Corridor Call Station Pictograph



2.6.9.2 Glass shall be mounted in the structure so that the structure, including the glass in place, shall withstand the required lift tests without damage.

2.6.9.3 Glass shall be laminated glass as defined by ANSI Z97.1 or 16 CFR, Part 1201, Section 1201.2 or be glass bonded to a nonpolymeric coating, sheeting, or film backing having the physical integrity to hold the fragments if the glass breaks. Glass shall be tested and conform to the acceptance criteria for laminated glass as specified in ANSI Z97.1 or 16 CFR, Part 1201, Section 1201.4. The glass shall be marked as required by ANSI Z97.1 or 16 CFR, Part 1201, Section 1201.5.

2.6.9.4 Markings as specified in 2.6.9.3 shall be on each separate piece of glass, and shall remain visible after installation.

2.7 Capacity, Speed, and Travel

2.7.1 Limitation of Load, Speed, and Travel. The rated (20) load shall be not less than 250 kg (550 lb) nor more than 475 kg (1,050 lb). Platforms with a floor greater than 1.4 m² (15 ft²) shall have a rated load of not less than 340 kg (750 lb). Platforms with a floor greater than 1.7 m² (18 ft²) shall have a rated load of not less than 475 kg (1,050 lb). The lift shall be capable of sustaining and lowering a load as specified in Figure 9.7. The rated speed shall not exceed 0.15 m/s (30 ft/min). The rated speed of lifts conforming to 2.1.6 shall not exceed 0.05 m/s (10 ft/min). Travel of lifts conforming to 2.1.1 and 2.1.2 shall not exceed 4 250 mm (168 in.). Travel of lifts conforming to 2.1.3 or shall not exceed 1 500 mm (60 in.). Travel of lifts conforming to 2.1.4 shall not exceed 600 mm (24 in.). Travel of lifts conforming to 2.1.6 shall not exceed 375 mm (15 in.).

2.7.2 Capacity Plates. A capacity plate stating the rated load shall be provided by the manufacturer and fastened in a conspicuous place. The letters and numerals used shall be not less than 6 mm (0.25 in.) in height.

2.7.3 Data Plates. A data plate shall be provided by the manufacturer and securely fastened to the machine. The plate shall state the rated speed, rated load, weight of platform, suspension and support means, date of manufacture, and manufacturer's name. Letters and numerals shall be not less than 6 mm (0.25 in.) in height.

2.7.4 Restriction Sign. A sign shall be securely fastened in a conspicuous place at each landing and on the platform. The sign shall state "No Freight" in letters not less than 6 mm (0.25 in.) high and shall include the international symbol of accessibility.

2.8 Safeties and Speed Governors

All platforms shall be provided with a safety, except as permitted in 2.8.8. The safety shall be actuated by the action of a speed governor or by the breakage or slackening of the suspension or support means. Where actuation is by a governor, the safety shall be set at a maximum speed of 0.4 m/s (75 ft/min). Where actuation is by breakage or slackening of the suspension or support means, the safety shall be set without delay, and independent of the speed governor, if provided.

Safety parts shall conform to the requirements of 2.8.2 and 2.8.3. Where hoisting ropes are used, the application of safeties shall conform to the requirements of 2.8.4.

The application and release of safeties shall conform to the requirements of 2.8.5 through 2.8.7.

2.8.1 Screw Drive Machines. When screw drive machines are used, safeties and speed governors conforming to 2.8.1 shall be permitted.

2.8.1.1 The down speed of the platform shall be limited, with rated load to not exceed 0.9 m/s (175 ft/min) in the event of failure of the driving means.

2.8.1.2 The fall of the platform in the event of failure of the driving nut shall be limited to a distance not exceeding 12 mm (0.5 in.), by using a safety nut or other equivalent means.

2.8.1.3 The capability of the alternate safety devices described in 2.8.1.1 and 2.8.1.2 to function as required shall be verified by engineering tests as described in 9.6.

2.8.2 Minimum Factors of Safety and Stresses of Safety Parts and Rope Connections

2.8.2.1 Parts of safeties, except springs, safety-rope drums, leading sheaves, and their supporting brackets and safety-jaw gibs, shall have a factor of safety of not less than 3.5, based on the ultimate strength of the material, and the materials used shall have an elongation of not less than

15% in a length of 50 mm (2 in.). Forged, cast, or welded parts shall be stress relieved.

2.8.2.2 Springs shall be permitted to be used in the operation of platform or counterweight safeties. Where used, and where partially loaded prior to safety operation, the loading on the spring shall not produce a fiber stress exceeding one-half the elastic limit of the material. During operation of the safety, the fiber stress shall not exceed 85% of the elastic limit of the material. Helical springs, where used, shall be in compression.

2.8.2.3 Safety-rope drums, leading sheaves, and their supporting brackets and safety-jaw gibs shall be permitted to be made of cast iron and other metals, provided such parts have a factor of safety of not less than 10.

2.8.2.4 Rope used as a connection from the safety to the governor rope, including rope wound on the safety-rope drum, shall be not less than 3 mm (0.125 in.) in diameter and shall be made of a corrosion-resistant metal. The factor of safety of the rope shall be not less than 5. Tiller-rope construction shall not be used.

2.8.2.5 The factors of safety shall be based on the maximum stresses developed in the parts during the operation of the safety when stopping rated load from governor tripping speed.

2.8.2.6 Safety-rope leading-sheave brackets and other safety operating parts shall not be attached to or supported by wood members.

2.8.3 Material and Factor of Safety. Governor ropes, where provided, shall be of iron, steel, monel metal, phosphor bronze, or stainless steel. They shall be of a regular-lay construction, and not less than 6 mm (0.25 in.) in diameter. The factor of safety of governor ropes shall be not less than 5. Tiller-rope construction shall not be used.

2.8.4 Type A (Instantaneous) Safeties. On the parting of the hoisting ropes (free fall), Type A governor-operated safeties, where provided, shall apply without appreciable delay, and their application shall be independent of the speed action of the governor and of the location of the break in the hoisting ropes (inertia application), and shall be permitted to be accomplished by the use of a governor and governor rigging having a sufficiently high value of inertia to apply the safety on free fall independently of the speed action of the governor.

2.8.5 Means of Application. Safeties shall be applied mechanically. Electric, hydraulic, or pneumatic devices shall not be used to apply the safeties required by section 2, nor to hold such safeties in the retracted position.

(20) 2.8.6 Level of Platform Floor on Safety Application.

The application of a Type A safety to stop the platform, with its rated load centered on each quarter of the floor symmetrically with relation to the centerline of the floor, shall not cause the floor to be out of level more than 30 mm/m (0.375 in./ft) in any direction.

2.8.7 Release. When platform safeties are applied, no decrease in tension in the governor rope nor motion of the platform in the down direction shall release the safeties, but such safeties shall be permitted to be released by the motion of the platform in the up direction.

2.8.8 Platform Safety Exceptions. Platform safeties are not required for lifts with the following driving means:

- (a) direct-plunger hydraulic
- (b) other drives that do not use a flexible suspension means, provided that the failure of a single drive component cannot result in the platform overspeeding or the floor going out of level more than 30 mm/m (0.375 in./ft) in any direction, and said failure would cause the platform to stop by application of a safety switch or equivalent means.

2.9 Terminal Stopping Devices

2.9.1 Normal terminal stopping devices required by 2.9.2 shall use mechanically operated, magnetically operated, optical, or static-type switches.

Final terminal stopping devices required by 2.9.3 shall use only mechanically operated switches.

Terminal stopping devices that are located on the platform or in the runway shall be of the enclosed type and securely mounted in such a manner so that horizontal movement of the platform shall not affect the operation of the device.

2.9.2 Except as specified in 2.9.7, normal stopping devices operated by the platform shall be provided, and shall be set to stop the platform floor within a tolerance of 12 mm (0.5 in.) of the landings under rated loading to zero loading conditions. The normal stopping devices shall be permitted to also serve as the upper and lower terminal stopping devices.

2.9.3 Upper and lower final terminal stopping devices operated by the platform shall be provided to remove power from the motor and brake if provided, except as specified in 2.9.6. They shall be set to stop the platform after it travels past the normal terminal stopping device and before striking an obstruction. A slack-rope device equipped with a slack-rope switch of the enclosed manually reset type, which shall cause the electric power to be removed from the driving-machine motor and brake, if provided, if any hoisting rope becomes slack, shall be permitted as the lower final terminal stopping device.

2.9.4 Final terminal stopping device switch contacts shall be directly opened mechanically. Arrangements that depend on a spring or gravity, or a combination thereof, to open the contacts shall not be used.

2.9.5 The final terminal stopping device shall not (20) control the same controller switches as the normal stopping device unless two or more separate and independent switches are provided, two of which shall be closed to complete the driving-machine motor-and-brake circuit in either direction of travel. Where a two- or three-phase alternating-current driving-machine motor is used, these switches shall be of the multipole type.

The control shall be so designed and installed that a single ground or short circuit shall be permitted to prevent either, but not prevent both, of the normal or final stopping device circuits from stopping the platform.

2.9.6 Final terminal stopping devices are not required for direct-plunger or roped-hydraulic driving machines. Lower final terminal stopping devices are not required where the limitations of the machine or runway limit the travel of the platform (e.g., a platform at rest on the bottom terminal landing).

2.9.7 A lower normal terminal stopping device is not required for direct-plunger driving machines where the platform rests on a physical stop at the bottom terminal landing and where the platform floor stops within a tolerance of 12 mm (0.5 in.) of the lower landing under rated loading to zero loading conditions.

2.10 Operating Devices and Control Equipment

2.10.1 Operation. Operation of the lift from the land- (20) ings and from the platform shall be controlled by control switches at all stations, and shall be by means of the continuous-pressure type. Controls shall be permanently accessible 1 220 mm (48 in.) maximum and 380 mm (15 in.) minimum above the platform floor or facility floor or ground level. Operating devices shall be designed so that both the "UP" and "DOWN" circuits cannot be operated at the same time.

2.10.2 Attendant Operation

2.10.2.1 Where applicable, and where approved by the authority having jurisdiction, the lift shall be permitted to be attendant operated. The attendant shall be summoned by means of a clearly labeled attendant-call device located at each landing.

2.10.2.2 The attendant shall operate the platform by means of a continuous-pressure switch so located that the attendant has full view of the floor area under the platform and full view of the platform throughout its travel. A manually reset emergency stop switch shall also be provided at that location.

2.10.2.3 No controls, other than an emergency stop switch, shall be provided in the platform.

2.10.3 Control and Operating Circuit Requirements. The design and installation of the control and operating circuits shall conform to 2.10.3.1 through 2.10.3.3.

2.10.3.1 Control systems that depend on the completion or maintenance of an electric circuit shall not be used for interruption of the power and application of the machine brake at terminal landings, or for stopping the machine when the safety applies.

2.10.3.2 If springs are used to actuate switches, contactors, or relays to break the circuit to stop the lift at the terminal landings, they shall be of the restrained compression type.

2.10.3.3 The failure of any single magnetically operated switch, relay, or contactor to release in the intended manner, or the failure of any solid state device to operate as intended, or the occurrence of a single accidental ground or combination of accidental grounds shall not permit the lift to start if this failure renders ineffective any electrical protective device.

2.10.4 Motor Reversal Protection. Where a non-instantaneous reversible motor is used, a protective circuit or device shall be provided to prevent the motor from continuing in the same direction if the reversal control is activated.

2.10.5 Phase Reversal and Failure Protection. Lifts having polyphase alternating-current power supply shall be provided with means to prevent the starting of the lift motor if the phase rotation is in the wrong direction, or if there is a failure of any phase.

This protection shall be considered to be provided if a reversal of phase of the incoming polyphase alternating-current power will not cause the lift driving-machine motor to operate in the wrong direction.

2.10.6 Emergency Stop Switch. An emergency stop switch shall be provided on the platform and located in or adjacent to each platform operating panel. When opened, this switch shall cause the electric power to be removed from the driving-machine motor and brake if provided.

Emergency stop switches shall be of the manually opened and closed type and have red operating handles or buttons.

They shall be conspicuously and permanently marked "STOP" and indicate the "STOP" and "RUN" positions. Switches shall be positively opened mechanically and their opening shall not be solely dependent on springs.

An emergency stop switch shall not be provided on any landing control, except as required by 2.10.2.2.

2.10.7 Slack-Rope and Slack-Chain Devices for Winding Drum and Roller-Chain-Type Driving Machines.

Winding drum driving machines with rope suspension shall be provided with a slack-rope device of the manually reset type that will remove power from the motor and brake if the platform is obstructed in its descent and the suspension ropes slacken. Lifts with roller-chain suspension means shall be provided with a slack-chain device that will remove power from the motor and brake if the platform is obstructed in its descent and the suspension means slacken. This device is not required to be of the manually reset type if the chain sprockets are guarded to prevent the chain from becoming disengaged from the sprockets.

2.10.8 Release and Application of Driving-Machine Brake.

Driving-machine brakes shall not be electrically released until power has been applied to the driving-machine motor. All power feed lines to the brake shall be opened and the brake shall apply automatically when any operating device in 2.10.1 or 2.10.2 is in the stop position, and when any electrical protective device functions.

2.10.9 Electrical Equipment and Wiring

2.10.9.1 All electrical equipment and wiring shall conform to the requirements of NFPA 70.

2.10.9.2 Electrical equipment shall be certified to the requirements of CAN/CSA-B44.1/ASME A17.5.

2.10.10 Emergency Operations. Means shall be provided to raise or lower the platform manually. This means shall only be accessible to lift personnel, emergency personnel, or authorized personnel. The means to raise or lower the platform shall be capable of moving the platform to a landing and of being accessed and operated without working directly above the platform. (20)

2.10.10.1 The means to manually raise or lower the lift shall provide for controlled ascent or descent not faster than the rated speed and shall be permitted to override operating devices and control equipment. The means shall be permitted to be

(a) an independent battery-operated system to manually raise or lower the lift

(b) a manual pump, lowering valve, or cable release device where a hydraulic drive system is used, or

(c) other suitable means

2.10.10.2 If an opening in the runway is required to access the means to manually raise or lower the platform, it shall be

(a) located to permit the required access.

(b) a maximum width of 300 mm (12 in.) and a maximum height of 300 mm (12 in.). The opening size shall be permitted to be increased, provided that any resultant opening into the runway shall reject a 300 mm (12 in.) ball.

(c) provided with a door that shall be kept closed and locked. Keys to unlock the access door to the lift runway shall be available only to lift personnel, emergency personnel, or other authorized personnel.

(d) attached so that it cannot fall when opened and shall not open into the runway.

(e) monitored so that the lift cannot be put back into normal operation without being in its closed and locked position.

2.11 Emergency Signals

Emergency signals shall comply with 2.11.1 through 2.11.3.

- (20) **2.11.1** The platform shall be provided with an audible signaling device that is located outside the platform area, but adjacent to the lift. The audible signaling device shall be operable from the emergency stop switch that is also marked with "ALARM" or from a separate switch marked "ALARM" that is located in or adjacent to each platform operating panel. The switch marked "ALARM" shall illuminate when actuated. The signaling device shall be audible outside the platform and outside the runway. The audible signaling device shall have a rated sound pressure rating of not less than 70 dBA nor greater than 80 dBA at 3 000 mm (120 in.) and respond without delay after the switch has been activated.

- (20) **2.11.2** Where the lift is installed in a location of a building that is not normally occupied when the site is in use, the lift shall be provided with a means of two-way conversation (telephone, intercom, etc.) between the platform and a readily accessible point outside the runway that is available to building or emergency personnel.

2.11.3 If the audible signaling device(s), or the means of two-way conversation, or both, are normally connected to the building power supply, they shall automatically transfer to a source of standby or emergency power as required by the applicable building code or, where applicable, NFPA 99 after the normal power supply fails. The power source shall be capable of providing for the operation of the audible signaling device and illumination of the alarm switch for at least 1 h, and the means of two-way conversation for at least 4 h.

(20) 2.12 Standby Emergency Power

Lifts shall be permitted to have standby emergency power to raise or lower the lift in the event of a main power failure. Where standby emergency power is required by the building code, it shall comply with 2.12.1 through 2.12.3.

2.12.1 Standby Power Source. The lift shall be powered by a standby power system from the building or from a rechargeable battery power system.

2.12.2 Operation. The standby power system shall be capable of cycling the lift under full load for five cycles minimum after building power is removed.

2.12.3 Transfer. The transfer between the normal and standby power systems shall be automatic.

2.13 Code Data Plate

A data plate shall be provided that indicates the A18.1 Standard to be used for inspections and tests. The data plate shall be in plain view, securely attached on the main line disconnect or on the controller. The data plate shall be of such material and construction that the letters and figures stamped, etched, cast, or otherwise applied to the face shall remain permanently and readily legible. The height of the letters and figures shall be not less than 3 mm (0.125 in.).

3 INCLINED PLATFORM LIFTS³

Section 3 applies to inclined platform lifts installed in locations other than in or at a private residence for use by the mobility impaired.

3.1 Runways

3.1.1 Means of Egress. Lifts shall be installed so that the means of egress is maintained as required by the authority having jurisdiction.

3.1.2 Clearances. Clearances between the platform and adjacent surfaces shall be not less than 20 mm (0.75 in.). At no point in its travel shall the edge of the platform floor facing the uppermost landing be more than 600 mm (24 in.) above a step or landing as measured vertically.

3.1.2.1 Headroom clearance where the platform is positioned for boarding shall be not less than 2 000 mm (79 in.) as measured vertically from all points on the surface of the platform floor.

3.1.2.2 Headroom clearance during travel shall be not less than 1 500 mm (60 in.) as measured vertically from any point on the surface of the platform floor.

3.1.2.3 If the headroom is less than 2 000 mm (79 in.) measured from all points on the platform floor surface throughout its travel, a caution sign shall be provided. The caution sign shall contain the words "CAUTION. LOW OVERHEAD" and "SEAT AND SEATBELT PROVIDED." The caution sign shall be securely fastened in a conspicuous place. Letters shall be not less than 6 mm (0.25 in.) high.

³ See section 6 for the requirements for this equipment installed in or at a private residence.

3.1.3 Pipes in Runway Vicinity. Pipes conveying steam, gas, or liquid that, if discharged into the runway, would endanger life or health shall not be permitted.

3.1.4 Lower Level Access Ramps and Pits. Lifts shall have a retractable platform floor-mounted ramp in accordance with 3.1.4.2, except that lifts installed in a dedicated inclined runway enclosure shall be permitted to have a pit or a floor-mounted ramp in accordance with 3.1.4.1.

3.1.4.1 Ramping inclinations for floor-mounted ramps shall be not greater than

- (a) 1 in 8 for heights up to 75 mm (3 in.)
- (b) 1 in 10 for heights up to 100 mm (4 in.)
- (c) 1 in 12 for heights greater than 100 mm (4 in.)

3.1.4.2 Retractable ramps shall be automatically actuated and shall remain in their elevated position until the platform returns to the landing. When in use, the inclination of the ramps shall be not greater than

- (a) 1 in 4 for heights up to 50 mm (2 in.)
- (b) 1 in 6 for heights up to 65 mm (2.5 in.)
- (c) 1 in 8 for heights up to 75 mm (3 in.)
- (d) 1 in 10 for heights up to 100 mm (4 in.)
- (e) 1 in 12 for heights greater than 100 mm (4 in.)

3.1.5 Structural Support. The structure on which the lift is installed shall be capable of safely supporting the loads imposed.

3.1.6 Electrical Equipment and Wiring

3.1.6.1 The installation of electrical equipment and wiring shall conform to the requirements of NFPA 70.

3.1.6.2 Electrical equipment shall be certified to the requirements of CAN/CSA-B44.1/ASME A17.5.

3.2 Guide Rails and Tracks

3.2.1 Material. Guide rails shall be of metal construction.

3.2.1.1 Requirements for Steel, Where Used. Rails, brackets, fishplates, and rail clips shall be made of open-hearth steel or its equivalent having a tensile strength of not less than 380 MPa (55,000 psi) and having an elongation of not less than 22% in a length of 50 mm (2 in.). Bolts shall conform to ASTM A307. Rivets shall conform to ASTM A502.

3.2.1.2 Requirements for Metals Other Than Steel. Metals other than steel shall be permitted to be used, provided the factor of safety is not less than, and the deflections are not more than, the values specified in section 3, and provided that cast iron is not used.

3.2.1.3 Guide-Rail Surfaces. Guide-rail surfaces used for guiding a platform or counterweight shall be sufficiently smooth and true to operate properly with the guiding members. Those surfaces that the platform or counterweight safeties engage shall be smooth and

true within the tolerances required to ensure proper safety application without excessive retardation or excessive out-of-level platform conditions resulting.

3.2.2 Location. The top and bottom ends of each run of guide rails shall be so located in relation to the extreme positions of travel of the platform that the platform guiding members cannot travel beyond the ends of the guide rails.

3.2.3 Stresses and Deflections of Guide Rails and Their Brackets

3.2.3.1 Guide Rails. For steels conforming to 3.2.1.1, the stresses in a guide rail or in the rail and its reinforcement, due to the horizontal forces imposed on the rail during loading, unloading, or running, calculated without impact, shall not exceed 100 MPa (15,000 psi), and the deflection shall not exceed 6 mm (0.25 in.).

Where steels of greater strength than those specified in 3.2.1.1 are used, the stresses specified shall be permitted to be increased proportionately based on the ratio of the ultimate strengths.

3.2.3.2 Brackets, Fastenings, and Supports. The guide-rail brackets, their fastenings, and supports, such as building beams and walls, shall be capable of resisting the horizontal forces imposed by the rated load with a total deflection at the point of support not in excess of 3 mm (0.125 in.).

3.2.4 Factor of Safety. The factor of safety used in the design of guide rails shall be not less than 5, based on the rated load.

3.2.5 Anchoring. The supporting tracks or guide rails shall be securely anchored to the stairs, floor surface, or sidewall.

3.3 Driving Means and Sheaves

The driving means shall be one of the following:

- (a) winding drum
- (b) traction
- (c) roped sprocket
- (d) chain sprocket
- (e) screw
- (f) rack and pinion
- (g) direct-plunger hydraulic
- (h) roped-hydraulic
- (i) lever hydraulic
- (j) lever screw
- (k) friction

3.3.1 General Requirements

3.3.1.1 The factor of safety, based on the static load (the rated load plus the weight of the platform, ropes, counterweights, etc.), to be used in the design of driving machines and sheaves including fasteners transmitting load, shall be not less than 8 for steel, bronze, or

other metals having an elongation of at least 14% in a length of 50 mm (2 in.) or 10 for cast iron or other metals having an elongation of less than 14% in a length of 50 mm (2 in.). Other factors of safety for specific driving means are further specified in [section 8](#).

3.3.1.2 Set screws or threaded portions located in the shear plane of bolts and screws shall not be used to transmit load.

Means shall be provided to ensure that there is no relative motion between rigidly joined components transmitting load.

Where flexible couplings are used to transmit load, means shall be provided to prevent disengagement of the coupling components in the event of failure or excessive motion in the flexible connection.

A fillet shall be provided at any point of change in the diameter of driving-machine shafts and sheave shafts to prevent excessive stress concentrations in the shafts.

Shafts that support drums, sheaves, gears, couplings, and other members, and that transmit torque, shall be provided with tight-fitting keys.

3.3.1.3 Friction gearing, clutch mechanisms, or couplings shall not be used to connect a driving-machine drum or sheave to the main driving mechanism.

3.3.1.4 Worm gearing having cast iron teeth shall not be used on the driving machine.

3.3.1.5 Driving-machine chains and sprockets shall be of steel and shall conform in design and dimensions to the requirements of ASME B29.1.

3.3.1.6 Winding drums, traction sheaves, overhead sheaves, and deflecting sheaves used with suspension and compensating ropes shall be of metal, be provided with finished grooves for ropes or shall be permitted to be lined with nonmetallic groove material, and have a pitch diameter of not less than 30 times the diameter of the suspension ropes. Where 8 × 19 steel rope or 7 × 19 steel aircraft cable is used, the pitch diameter of the drums and sheaves shall be permitted to be reduced to 21 times the diameter of the rope or cable.

Where the grooves are used to transmit power, sufficient traction shall be provided between the rope and groove, and in the event of nonmetallic lining failure, between the rope and the remaining sheave groove, to safely stop and hold the platform with 125% of the rated load.

- (20) **3.3.1.7 Guarding of Driving Machines.** The driving machine shall be guarded to prevent accidental contact. Any opening required for operation shall reject a ball 20 mm (0.75 in.) in diameter. Access shall be provided for inspecting and servicing. Any guard(s) required to be removed for inspecting and servicing shall be secured in place using tamper-resistant fasteners or other tamper-resistant means.

3.3.2 Hydraulic Driving Machines. Direct-plunger hydraulic driving machines, where used, shall conform to the requirements of [8.1](#), except [8.1.2](#).

Roped-hydraulic machines shall also conform to the requirements of [8.1](#), except for [8.1.1](#), [8.1.3](#), [8.1.4.3](#), and [8.1.4.7](#).

3.3.3 Screw Machines. Screw machines, where used, shall conform to [8.2](#).

3.3.4 Friction Machines. Friction machines, where used, shall conform to [8.3](#).

3.3.5 Location of Power Unit and Alignment and Guarding of Sheaves and Sprockets. The power unit shall be permitted to be mounted in the platform or placed at a remote location. If remotely located, all intervening sheaves and sprockets shall be so placed that the rope or chain travels in the proper alignment. All sheaves and sprockets shall be enclosed or guarded.

3.3.6 Indirect-Drive Machines. Indirect-drive machines, using V-belt drives, tooth drive belts, or drive chains, shall conform to the requirements of [3.3.6.1](#) and [3.3.6.2](#), except that the requirements of [3.3.6.2](#) shall be permitted to be omitted if a self-locking drive meeting the requirements of [3.4.2](#) is provided. If multiple belts or chains are provided, they shall be preloaded and matched for length in sets.

3.3.6.1 General Requirements. Belt sets shall be selected on the basis of the manufacturer's rated breaking strength and a factor of safety of 10. Chain and sprocket sets shall be selected on the basis of recommendations set forth in the Supplementary Information section of ASME B29.1, using a service factor of 2. Offset links in chain are not permitted.

Sprockets in a chain-drive set and also a driven set shall be assembled onto a common hub, with teeth cut in-line after assembly to ensure equal load distribution on all chains. Tooth sheaves for a belt drive shall be constructed in a manner to ensure equal load distribution on each belt in the set. Load determination for both the belt and chain sets shall be based on the maximum static loading on the platform, which is the full load in the platform at rest and at a position in the runway that creates the greatest load, including either the platform or counterweight resting on its buffer.

Chain drives and belt drives shall be guarded to protect against accidental contact and to prevent foreign objects from interfering with drives.

3.3.6.2 Monitoring and Brake Location. Each belt or chain in a set shall be continuously monitored by a broken belt or chain device that shall function to automatically interrupt power to the machine and apply the brake if any belt or chain in a set breaks or becomes excessively slack. The driving-machine brake shall be located on the traction sheave or drum assembly side of the driving

machine so as to be fully effective if the entire belt set or chain set should break.

3.4 Driving-Machine Brakes

3.4.1 Driving machines, except hydraulic, shall be equipped with electrically released spring-applied brakes directly attached to the driving means through a continuous shaft, mechanical coupling, or toothed gearing. A single ground or short circuit, a counter voltage, or a motor-field discharge shall not prevent the brake magnet from allowing the brake to set when the operating device is placed in the stop position.

3.4.2 A machine brake is not required if a self-locking drive using a lead screw, worm, or other positive gearing that will stop and hold the platform with the rated load within 100 mm (4 in.) of down travel after the power is removed is provided.

3.5 Suspension and Support Means

3.5.1 General Requirements

3.5.1.1 Suspension and support means shall be one of the following:

- (a) steel or iron wire rope
- (b) steel aircraft cable
- (c) roller chain
- (d) direct-plunger hydraulic
- (e) roped-hydraulic
- (f) rack and pinion
- (g) screw
- (h) friction machine guides and rollers

3.5.1.2 Steel tapes or welded link chains shall not be used as suspension means.

3.5.1.3 Where wire ropes are used, the diameter shall not be less than 6 mm (0.25 in.).

3.5.2 Factors of Safety. The suspension and support means shall have a factor of safety of not less than 7 based on the tension in the rope, cable, chain, or forces exerted on the hydraulic cylinder, screw drive, or rack and pinion when raising the rated load. When the platform and counterweight are suspended by steel ropes and the driving means between the machine and the counterweight is an endless roller-type chain, the factor of safety of such chain shall be not less than 8, based on the rated load. See [section 8](#) for special requirements for particular drive systems.

3.5.3 Arc of Contact of Suspension Means on Sheaves and Sprockets. The arc of contact of a wire rope on a traction sheave shall be sufficient to produce adequate traction under all load conditions. The arc of contact of a chain on a driving sprocket shall be not less than 140 deg.

3.5.4 Spare Rope Turns on Winding Drums. All wire ropes of winding drum machines shall have not less than one full turn of the rope on the drum when the platform or counterweight has reached its limit of possible overtravel.

3.5.5 Securing Suspension Ropes to Winding Drums. The drum ends of wire ropes shall be secured by clamps on the inside of the drum of winding drum machines, by tapered babbitted sockets, or by other means approved by the authority having jurisdiction.

3.5.6 Lengthening, Splicing, Repairing, or Replacing Suspension Means. Suspension wire ropes shall not be lengthened or repaired by splicing. Broken or worn suspension chains shall not be repaired. If one rope or chain of a set is worn or damaged and requires replacement, the entire set of ropes or chains shall be replaced. If a chain or sprocket is replaced due to wear, all chains and sprockets shall be replaced.

3.5.7 Fastening of Rope Suspension Means to Platform. The platform ends of wire ropes shall be fastened in a return loop by properly made individual tapered babbitted sockets or properly attached fittings as recommended by wire rope manufacturers. Clips of the U-bolt type shall not be used. Tapered babbitted rope sockets and the method of babbiting shall conform to the requirements of [9.8](#).

3.5.8 Guarding. All suspension means shall be guarded against accidental contact. Suspension means that operate within a guide or track and travel at the same speed and in the same direction as the platform shall be considered suitably guarded.

3.6 Platforms

3.6.1 Frame and Floor. The frame shall be of metal construction and have a factor of safety of not less than 5 based on the rated load. The floor shall be of metal or wood construction with a nonskid surface.

3.6.2 Securing of Enclosure. The enclosure shall be securely fastened to the floor and so supported that it cannot loosen or become displaced in ordinary service, on the application of the platform safety, or on buffer engagement. The platform enclosure shall be so constructed that removable portions cannot be dismantled from within the platform.

Enclosure linings, decorative panels, light fixtures, and other apparatus or equipment attached to the enclosure shall be securely fastened and so supported that they will not loosen or become displaced in ordinary service, on platform safety application, or on buffer engagement.

Panels attached to the enclosure for decorative or other purposes shall not be unfastened from inside the platform by the use of common tools or shall be permitted to be removed from inside the platform when perforations, exceeding that which would reject a ball 12 mm (0.5

in.) in diameter, in the enclosure used for panel hanging or support have permanent means to prevent straight-through passage beyond the running clearance.

3.6.3 Strength and Deflection of Enclosure Walls. The enclosure walls shall be designed and installed to withstand a force of 330 N (75 lbf) applied horizontally at any point on the walls of the enclosure without permanent deformation nor cause the deflection to exceed 25 mm (1 in.).

3.6.4 Floor Area. The inside floor area shall not exceed 1.7 m² (18 ft²).

3.6.5 Material. Metals having an elongation less than 20% in a length of 50 mm (2 in.) shall not be used in the construction of any member of the frame or floor.

- (20) **3.6.6 Glass in Platform Enclosures.** Glass shall be permitted to be used subject to the requirements of 3.6.6.1 through 3.6.6.4.

3.6.6.1 Glass shall be installed and guarded to provide adequate protection for passengers in case the glass panels break or are dislodged.

3.6.6.2 Glass shall be mounted in the structure so that the structure, including the glass in place, shall withstand the required lift tests without damage.

3.6.6.3 Glass shall be laminated glass as defined by ANSI Z97.1 or 16 CFR, Part 1201, Section 1201.2 or be glass bonded to a nonpolymeric coating, sheeting, or film backing having the physical integrity to hold the fragments if the glass breaks. Glass shall be tested and conform to the acceptance criteria for laminated glass as specified in ANSI Z97.1 or 16 CFR, Part 1201, Section 1201.4. The glass shall be marked as required by ANSI Z97.1 or 16 CFR, Part 1201, Section 1201.5.

3.6.6.4 Markings as specified in 3.6.6.3 shall be on each separate piece of glass, and shall remain visible after installation.

3.6.7 Platform Truck and Guides. The platform shall be securely anchored to a truck that supports it. The truck shall be retained in a track or on a guide-rail assembly.

3.6.8 Platform Guarding. Platform guarding shall be in accordance with 3.6.8.1 or 3.6.8.2.

3.6.8.1 Platform With Enclosure. The platform shall be equipped with a self-closing door at least 1 100 mm (42 in.) high on the sides of access to the bottom landing. The door shall be of solid construction and be provided with a combination mechanical lock and electric contact and shall only be operable within 50 mm (2 in.) of the bottom landing. It shall be permitted to allow the platform to move if the door or gate is in the closed position but not locked, provided the device will stop the platform if the door or gate fails to lock before the platform has moved more than 50 mm (2 in.) away from the bottom landing.

The platform enclosure walls on the sides not used for access or exit shall be of smooth construction to a height of 1 100 mm (42 in.) above the platform floor with no openings, other than those necessary for operation. Openings necessary for operation shall reject a ball 12 mm (0.5 in.) in diameter. A grab rail extending the full length of either wall shall be provided at a height not less than 850 mm (34 in.) or greater than 1 000 mm (38 in.) from the platform floor. The running clearance between the platform enclosure walls and any adjacent surface shall be not less than 50 mm (2 in.).

3.6.8.1.1 Door-locking devices shall comply with 2.1.1.4.1.

3.6.8.2 Platform With Passenger Restraining Arms. A grab rail shall be provided at a height not less than 850 mm (34 in.) or greater than 1 000 mm (38 in.) from the platform floor.

3.6.8.2.1 The side of the platform adjacent to the track or guide-rail assembly shall be provided with a guard of smooth, solid construction and of height that shall prevent a seated passenger from making accidental contact with moving suspension or driving means or moving platform trucks. The guard shall have no openings other than those necessary for operation. Such openings shall reject a ball 12 mm (0.5 in.) in diameter.

3.6.8.2.2 The nonboarding sides of the platform shall be provided with a guard of smooth, solid construction and of a height not less than 150 mm (6 in.).

3.6.8.2.3 The sides of the platform used for boarding shall be provided with retractable metal ramps of a minimum height of 150 mm (6 in.) measured vertically from the surface of the platform floor, locked in their guarding positions. At a landing, only the retractable ramp serving the landing shall be operable. It shall be operable only when the passenger restraining arm at the nonboarding end of the platform is in its locked guarding position. Retractable ramps shall be mechanically locked and monitored by an electric contact that shall stop the movement of the platform within 50 mm (2 in.) of travel away from the landing if the ramps have failed to rise to their elevated position. Retractable ramps, in their guarding position, shall withstand, without permanent deformation, a force of 550 N (125 lbf) applied on any 100 mm × 100 mm (4 in. × 4 in.) area. This force shall not cause the height of the ramp, at any point in its length, to be less than 150 mm (6 in.) measured vertically from the surface of the platform floor.

3.6.8.2.4 The platform shall be provided with retractable passenger restraining arms conforming to the following:

(a) The arms shall be located above the perimeter of the platform floor at not less than 800 mm (32 in.) or greater than 1 000 mm (38 in.). Gaps between the adjacent ends of

arm sections shall not exceed 100 mm (4 in.) when the arms are in their guarding positions.

(b) The arms shall be of smooth construction with all edges rounded. They shall not be permanently deformed when a force of 300 N (66 lbf) is applied on any point along the length of the arms in any direction. In addition, they shall not be permanently deformed when a force of 1 000 N (225 lbf) is applied in the horizontal direction along the centerline of the platform.

(c) The arms shall be provided in independent sections. At landings, the retractable ramp and arm at the boarding end of the platform shall be operable only when the arm at the nonboarding end of the platform is in its locked guarding position.

(d) Each retractable arm shall be mechanically locked and monitored by an electric contact that shall stop the movement of the platform within 50 mm (2 in.) of travel away from any landing if the arm is not in its locked guarding position. Means shall be provided to manually unlock the retractable arms for emergency evacuation purposes. The unlocking mechanism shall not be readily accessible to the passenger.

(e) Where the retractable arms are power operated, control shall be by means of a continuous-pressure device. The closing speed shall not exceed 0.3 m/s (1 ft/sec) as measured at the fastest point. The force necessary to prevent closing of power-operated arms shall not exceed 140 N (30 lbf) as measured from rest at the midpoint across the arm at the boarding end of the platform. The arms may operate in the direction away from an obstruction.

3.6.8.2.5 Means shall be provided to manually fold the platform and passenger restraining arms. The platform and passenger restraining arms shall remain in the folded position after being manually folded.

3.6.9 Obstruction Devices. The upward and downward facing edges of the platform floor and the entire underside shall be equipped with obstruction devices. The force required to operate the devices shall not exceed 70 N (15 lbf). The obstruction devices shall stop the platform lift from traveling in the direction of the obstruction within a distance of 50 mm (2 in.). The platform lift shall be permitted to operate in the direction away from the obstruction.

The underside obstruction device shall stop the platform lift only when the platform lift is obstructed while traveling in the down direction.

3.6.10 The lift shall be provided with a folding seat and seatbelt with a rated load of not less than 115 kg (250 lb).

3.7 Capacity, Load, Speed, and Angle of Inclination

3.7.1 Limitations of Capacity, Load, and Speed. The capacity shall be one person. The rated load shall be not less than 250 kg (550 lb) and not greater than 340

kg (750 lb). Platforms with a floor area greater than 1.4 m² (15 ft²) shall have a rated load of 340 kg (750 lb). The lift shall be capable of sustaining and lowering a load as specified in Figure 9.7. The rated speed measured along the incline shall not exceed 0.15 m/s (30 ft/min).

3.7.2 Limitation of Angle. No lift shall be installed to operate on an incline greater than 45 deg as measured on the mean.

3.7.3 Capacity Plate. A capacity plate stating the rated load in pounds shall be furnished by the manufacturer and fastened in a conspicuous place on the lift. Letters and numbers shall be not less than 6 mm (0.25 in.) in height.

3.7.4 Data Plates. A data plate shall be provided by the manufacturer and securely fastened in a conspicuous place. The plate shall state the rated speed, rated load, suspension or support means, date of manufacture, and manufacturer's name. Letters and numerals shall be not less than 6 mm (0.25 in.) in height.

3.7.5 Restriction Sign. A sign shall be provided at each landing and on the platform and shall be securely fastened in a conspicuous place. The sign shall state "No Freight" in letters not less than 6 mm (0.25 in.) high and shall include the international symbol of accessibility.

3.8 Safeties and Speed Governors

All platforms shall be provided with a safety, except platforms of direct-plunger hydraulic lifts. The safety shall be actuated by the action of a speed governor or by the breakage or slackening of the suspension or support means. Where actuation is by a governor, the safety shall be set at a maximum speed of 0.4 m/s (75 ft/min). Where actuation is by breakage or slackening of the suspension or support means, the safety shall be set without delay, and independent of the speed governor, if provided.

Safety parts shall conform to the requirements of 3.8.1. Governor ropes, where provided, shall conform to the requirements of 3.8.2. The application and release of safeties shall conform to the requirements of 3.8.3.

3.8.1 Minimum Factors of Safety and Stresses of Safety Parts and Rope Connections

3.8.1.1 Parts of safeties, except springs, safety-rope drums, leading sheaves, and their supporting brackets and safety-jaw gibs, shall have a factor of safety of not less than 3.5, based on the ultimate strength of the material, and the materials used shall have an elongation of not less than 15% in a length of 50 mm (2 in.). Forged, cast, or welded parts shall be stress relieved.

3.8.1.2 Springs shall be permitted to be used in the operation of platform or counterweight safeties. Where used, and where partially loaded prior to safety operation, the loading on the spring shall not produce a fiber stress

exceeding one-half the elastic limit of the material. During operation of the safety, the fiber stress shall not exceed 85% of the elastic limit of the material.

Helical springs, where used, shall be in compression.

3.8.1.3 Safety-rope drums, leading sheaves, and their supporting brackets and safety-jaw gibs shall be permitted to be made of cast iron and other metals, provided such parts have a factor of safety of not less than 10.

3.8.1.4 Rope used as a connection from the safety to the governor rope, including rope wound on the safety-rope drum, shall be not less than 3 mm (0.125 in.) in diameter and shall be made of a corrosion-resistant metal. The factor of safety of the rope shall be not less than 5. Tiller-rope construction shall not be used.

3.8.1.5 The factors of safety shall be based on the maximum stresses developed in the parts during the operation of the safety when stopping the rated load from the governor tripping speed.

3.8.1.6 Safety-rope leading-sheave brackets and other safety operating parts shall not be attached to or supported by wood platform members.

3.8.2 Material and Factor of Safety. Governor ropes shall be of iron, steel, monel metal, phosphor bronze, or stainless steel. They shall be of a regular-lay construction, and not less than 6 mm (0.25 in.) in diameter. The factor of safety of governor ropes shall be not less than 5. Tiller-rope construction shall not be used.

3.8.3 Means of Application. Safeties shall be applied mechanically. Electric, hydraulic, or pneumatic devices shall not be used to apply the safeties required by this section, nor to hold such safeties in the retracted position.

(20) **3.8.3.1 Level of Platform Floor on Safety Application.** The application of a Type A safety to stop the platform with its rated load centered on each quarter of the platform floor symmetrically with relation to the centerline of the platform floor shall not cause the platform floor to be out of level more than 30 mm/m (0.375 in./ft) in any direction.

3.8.3.2 Release. When platform safeties are applied, no decrease in tension in the governor rope nor motion of the platform in the down direction shall release the safeties, but such safeties shall be permitted to be released by the motion of the platform in the up direction.

3.9 Terminal Stopping Devices

3.9.1 Normal terminal stopping devices required by 3.9.2 shall be permitted to use mechanically operated, magnetically operated, optical, or static-type switches.

Final terminal stopping devices required by 3.9.3 shall use only mechanically operated switches for determining platform position.

Terminal stopping devices that are located on the platform or in the runway shall be securely mounted in such a manner that horizontal movement of the platform shall not affect the operation of the device.

3.9.2 Normal stopping devices operated by the platform shall be provided, and shall be set to stop the platform floor within a tolerance of 12 mm (0.5 in.) of the landings under rated loading to zero loading conditions.

3.9.3 Upper and lower final terminal stopping devices operated by the platform shall be provided to remove power from the motor and the brake if provided, except as specified in 3.9.6. They shall be set to stop the platform after it travels past the normal terminal stopping device and before striking an obstruction. A slack-rope device equipped with a slack-rope switch of the enclosed manually reset type that shall cause the electric power to be removed from the driving-machine motor and brake, if provided, if any hoisting rope becomes slack shall be permitted to be used as the lower final terminal stopping device.

3.9.4 Final terminal stopping devices shall be mechanically operated. The switch contacts shall be directly opened mechanically. Arrangements that depend on a spring or gravity, or a combination thereof, to open the contacts shall not be used.

3.9.5 The final terminal stopping device shall not control the same controller switches as the normal terminal stopping device unless two or more separate and independent switches are provided, two of which shall be closed to complete the driving-machine motor-and-brake circuit in either direction of travel. Where a two- or three-phase alternating-current driving-machine motor is used, these switches shall be of the multipole type.

The control shall be so designed and installed that a single ground or short circuit shall be permitted to allow either, but not prevent both, of the normal and final stopping device circuits from stopping the platform.

3.9.6 Final terminal stopping devices are not required for direct-plunger hydraulic driving machines. Lower final terminal stopping devices are not required where the limitations of the machine or runway limit the travel of the platform (e.g., a platform at rest on the bottom terminal landing).

3.10 Operating Devices and Control Equipment

3.10.1 Operation. Operation of the lift from the landings and from the platform shall be controlled by control switches at all stations, and shall be by means of the continuous-pressure type. Controls shall be permanently accessible 1 220 mm (48 in.) maximum and 380 mm (15 in.) minimum above the platform floor or facility floor or ground level. Operating devices shall be designed so that

both the “UP” and “DOWN” circuits cannot be operated at the same time.

3.10.2 Attendant Operation

3.10.2.1 Where applicable, and where approved by the authority having jurisdiction, the lift shall be permitted to be attendant operated. The attendant shall be summoned by means of clearly labeled attendant call stations placed at each landing.

3.10.2.2 The attendant shall operate the lift by means of a continuous-pressure switch located in a control box on the free end of a detachable, flexible cord not more than 1 500 mm (60 in.) in length. A manually reset emergency stop switch shall also be provided in the control box.

3.10.2.3 No controls, other than an emergency stop switch, shall be provided on the lift.

3.10.2.4 Where the lift operates on a straight flight of stairs, and where the platform is within sight during its entire travel, provisions shall be permitted to be made for the attendant to operate the lift from the top or bottom of the stairs. A manual-reset emergency stop switch shall be provided in each landing control station.

3.10.3 Control and Operating Circuit Requirements. The design and installation of the control and operating circuits shall conform to 3.10.3.1 through 3.10.3.3.

3.10.3.1 Control systems that depend on the completion or maintenance of an electric circuit shall not be used for interruption of the power and application of the machine brake at terminal landings or stopping the machine when the safety applies.

3.10.3.2 If springs are used to actuate switches, contactors, or relays to break the circuit to stop the lift at the terminal landing, they shall be of the restrained compression type.

3.10.3.3 The failure of any single magnetically operated switch, relay, or contactor to release in the intended manner, or the failure of any solid state device to operate as intended, or the occurrence of a single accidental ground or combination of accidental grounds shall not permit the lift to start if this failure renders ineffective any electrical protective device.

3.10.4 Motor Reversal Protection. Where a non-instantaneous reversible motor is used, a protective circuit or device shall be provided to prevent the motor from continuing in the same direction if the reversing control is activated.

3.10.5 Phase Reversal and Failure Protection. Lifts having polyphase alternating-current power supply shall be provided with means to prevent the starting of the lift motor if the phase rotation is in the wrong direction or if there is a failure of any phase. This protection

shall be considered to be provided if a reversal of phase of the incoming polyphase alternating-current power will not cause the driving-machine motor to operate in the wrong direction.

3.10.6 Emergency Stop Switch. An emergency stop switch shall be located within reach of the passenger whether sitting in a wheelchair or sitting on the folding seat and located 1 200 mm (48 in.) maximum and 380 mm (15 in.) minimum above the platform floor. When opened, this switch shall cause the electric power to be removed from the driving-machine motor and brake. Emergency stop switches shall be of the manually opened and closed type and have red operating handles or buttons. They shall be conspicuously and permanently marked “STOP” and shall indicate the “STOP” and “RUN” positions. Switches shall be positively opened mechanically and their opening shall not be solely dependent on springs.

An emergency stop switch shall not be provided on any landing control except as required by 3.10.2.

3.10.7 Slack-Rope and Slack-Chain Devices for Winding Drum and Roller-Chain-Type Driving Machines.

Winding drum driving machines with rope suspension shall be provided with a slack-rope device of the manually reset type that will remove power from the motor and brake if the platform is obstructed in its descent and the suspension ropes slacken. Lifts with roller-chain suspension means shall be provided with a slack-chain device, which will remove power from the motor and brake if the platform is obstructed in its descent and the suspension means slacken. This device is not required to be of the manually reset type if the chain sprockets are guarded to prevent the chain from becoming disengaged from the sprockets.

3.10.8 Release and Application of Driving-Machine Brake. Driving-machine brakes shall not be electrically released until power has been applied to the driving-machine motor. All power feed lines to the brake shall be opened, and the brake shall apply automatically when any operating device in 3.10.1 or 3.10.2 is in the stop position and when any electrical protective device functions.

3.10.9 Electrical Equipment and Wiring

3.10.9.1 All electrical equipment and wiring shall conform to the requirements of NFPA 70.

3.10.9.2 Electrical equipment shall be certified to the requirements of CAN/CSA-B44.1/ASME A17.5.

3.10.10 Emergency Operations. Means shall be provided to raise or lower the platform manually along the path of travel. This means shall only be accessible to lift personnel, emergency personnel, or authorized personnel. The means to raise or lower the platform shall be capable of moving the platform to a landing and of being

accessed and operated without working directly above the platform.

3.10.10.1 The means to manually raise or lower the lift shall provide for controlled ascent or descent not faster than the rated speed and shall be permitted to override operating devices and control equipment. The means shall be permitted to be

- (a) an independent battery-operated system to manually raise or lower the lift
- (b) a manual pump, lowering valve, or cable release device where a hydraulic drive system is used, or
- (c) other suitable means

3.10.10.2 If an opening in the runway is required to access the means to manually raise or lower the platform, it shall be

- (a) located to permit the required access.
- (b) a maximum width of 300 mm (12 in.) and a maximum height of 300 mm (12 in.). The opening size shall be permitted to be increased, provided that any resultant opening into the runway shall reject a 300 mm (12 in.) ball.
- (c) provided with a door that shall be kept closed and locked. Keys to unlock the access door to the lift runway shall be available only to lift personnel, emergency personnel, or other authorized personnel.
- (d) attached so that it cannot fall when opened and shall not open into the runway.
- (e) monitored so that the lift cannot be put back into normal operation without being in its closed and locked position.

3.11 Emergency Signal

If the lift is installed in an area not visible to personnel at all times, emergency signaling devices shall be provided in accordance with the requirements of 3.11.1 or 3.11.2.

- (20) **3.11.1** The lift shall be provided with an audible signaling device that is located outside the platform area, but adjacent to the lift. The audible signaling device shall be operable from the emergency stop switch that is also marked with "ALARM" or from a separate switch marked "ALARM" that is located in or adjacent to each platform operating panel. The switch marked "ALARM" shall illuminate when actuated. The signaling device shall be audible outside the platform and outside the runway. The audible signaling device shall have a rated sound pressure rating of not less than 70 dBA nor greater than 80 dBA at 3000 m (120 in.) and shall respond without delay after the switch has been activated.
- (20) **3.11.2** The lift shall be provided with a means of two-way conversation (telephone, intercom, etc.) between the platform and a readily accessible point outside the runway that is available to emergency personnel. The means to

activate the two-way conversation system does not have to be provided on the platform.

3.11.3 If the audible signaling device(s), or the means of two-way conversation, or both, are normally connected to the building power supply, they shall automatically transfer to a source of standby or emergency power as required by the applicable building code or, where applicable, NFPA 99 after the normal power supply fails. The power source shall be capable of providing for the operation of the audible signaling device and illumination of the alarm switch for at least 1 h, and the means of two-way conversation for at least 4 h. (20)

3.12 Standby Emergency Power

Lifts shall be permitted to have standby emergency power to raise or lower the lift in the event of main power failure. Where standby emergency power is required by the building code, it shall comply with 3.12.1 through 3.12.3.

3.12.1 Standby Power Source. The lift shall be powered by a standby power system from the building or from a rechargeable battery power system.

3.12.2 Operation. The standby power system shall be capable of cycling the lift under full load for five cycles minimum after building power is removed.

3.12.3 Transfer. The transfer between the normal and the standby power system shall be automatic.

3.13 Code Data Plate

A code data plate shall be provided that indicates the A18.1 Standard to be used for inspections and tests. The data plate shall be in plain view, securely attached on the main line disconnect or on the controller. The data plate shall be of such material and construction that the letters and figures stamped, etched, cast, or otherwise applied to the face shall remain permanently and readily legible. The height of the letters and figures shall be no less than 3 mm (0.125 in.).

4 INCLINED STAIRWAY CHAIRLIFTS⁴

Section 4 applies to inclined stairway chairlifts installed in locations other than in or at a private residence for use by the mobility impaired.

4.1 Runways

4.1.1 Lifts shall be installed so that a means of egress is maintained as required by the authority having jurisdiction.

⁴ See section 7 for the requirements for this equipment installed in or at a private residence.

4.1.2 The structure on which the equipment is installed shall be capable of safely supporting the loads imposed.

4.1.3 The installation of electrical equipment and wiring shall conform to the requirements of NFPA 70.

4.1.4 Electrical equipment shall be certified to the requirements of CAN/CSA-B44.1/ASME A17.5.

4.2 Guide Rails and Tracks

The supporting tracks or guide rails shall be securely anchored to the stairs, floor surface, or sidewall. The factor of safety used in the design of the guide rails and tracks shall be not less than 5 based on the rated load.

4.3 Driving Means and Sheaves

The driving means shall be one of the following:

- (a) winding drum
- (b) traction
- (c) roped sprocket
- (d) chain sprocket
- (e) screw
- (f) rack and pinion
- (g) direct-plunger hydraulic
- (h) roped-hydraulic
- (i) lever hydraulic
- (j) lever screw
- (k) friction

4.3.1 General Requirements

4.3.1.1 The factor of safety used in the design of the sprockets and sheaves shall be not less than 5 based on the rated load. See [section 8](#) for special requirements for particular drive systems.

4.3.1.2 Driving-machine chains and sprockets shall be of steel and shall conform in design and dimensions to the requirements of ASME B29.1.

4.3.1.3 Winding drums, traction sheaves, overhead sheaves, and deflecting sheaves used with suspension and compensating ropes shall be of metal and be provided with finished grooves for ropes or shall be permitted to be lined with nonmetallic groove material and have a pitch diameter of not less than 30 times the diameter of the suspension ropes. Where 8×19 steel rope or 7×19 steel aircraft cable is used, the pitch diameter of the drums and sheaves shall be permitted to be reduced to 21 times the diameter of the rope or cable.

Where the grooves are used to transmit power, sufficient traction shall be provided between the rope and groove, and in the event of nonmetallic lining failure, between the rope and the remaining sheave groove, to safely stop and hold the chair with 125% of the rated load.

4.3.2 Hydraulic Driving Machines. Direct-plunger hydraulic driving machines, where used, shall conform to the requirements of [8.1](#) except [8.1.2](#).

Roped-hydraulic machines shall also conform to the requirements of [8.1](#) except for [8.1.1](#), [8.1.3](#), [8.1.4.3](#), and [8.1.4.7](#).

4.3.3 Screw Machines. Screw machines, where used, shall conform to [8.2](#).

4.3.4 Friction Machines. Friction machines, where used, shall conform to [8.3](#).

4.3.5 Location of Power Unit and Alignment and Guarding of Sheaves and Sprockets. The power unit shall be permitted to be mounted on the carriage or placed at a remote location. If it is remotely located, all intervening sheaves and sprockets shall be so placed that the rope or chain travels in the proper alignment. All sheaves and sprockets shall be enclosed or guarded.

4.3.6 Indirect-Drive Machines. Indirect-drive machines using V-belt drives, tooth drive belts, or drive chains shall conform to the requirements of [4.3.6.1](#) through [4.3.6.3](#), except that the requirements of [4.3.6.2](#) shall be permitted to be omitted if a self-locking drive meeting the requirements of [4.4.2](#) is provided. If multiple belts or chains are provided, they shall be preloaded and matched for length in sets.

4.3.6.1 General Requirements. Belt sets shall be selected on the basis of the manufacturer's rated breaking strength and a factor of safety of 10. Chain and sprocket sets shall be selected on the basis of recommendations set forth in the Supplementary Information section of ASME B29.1, using a service factor of 2. Offset links in chain are not permitted.

Sprockets in a chain-drive set and also a driven set shall be assembled onto a common hub, with teeth cut in-line after assembly to ensure equal load distribution on all chains. Tooth sheaves for a belt drive shall be constructed in a manner to ensure equal load distribution on each belt in the set. Load determination for both the belt and chain sets shall be based on the maximum static loading on the carriage, which is the full load on the chair at rest and at a position in the runway that creates the greatest load, including either the carriage or counterweight resting on its buffer.

Chain drives and belt drives shall be guarded to protect against accidental contact and to prevent foreign objects from interfering with drives.

4.3.6.2 Monitoring and Brake Location. Each belt or chain in a set shall be continuously monitored by a broken belt or chain device that shall function to automatically interrupt power to the machine and apply the brake if any belt or chain in the set breaks or becomes excessively slack. The driving-machine brake shall be located on the traction sheave or drum assembly side of the driving

machine so as to be fully effective if the entire belt set or chain set should break.

4.3.6.3 Replacement of Belts or Chains. If one belt or chain of a set is worn, stretched, or damaged so as to require replacement, the entire set shall be replaced. Sprockets and toothed sheaves shall also be replaced if worn.

4.4 Driving-Machine Brakes

4.4.1 A driving-machine brake directly attached to the driving means through a continuous shaft, mechanical coupling, or toothed gearing of the electrically released spring-applied type shall be provided, except on lifts with hydraulic driving machines.

4.4.2 A machine brake is not required if a self-locking drive using a lead screw, worm, or other positive gearing that will stop and hold the carriage with the rated load within 100 mm (4 in.) of down travel after the power is removed is provided.

4.5 Suspension and Support Means

4.5.1 General Requirements

4.5.1.1 Suspension and support means shall be one of the following:

- (a) steel or iron wire rope
- (b) steel aircraft cable
- (c) roller chain
- (d) direct-plunger hydraulic
- (e) roped-hydraulic
- (f) rack and pinion
- (g) screw
- (h) friction machine guides and rollers.

4.5.1.2 Steel tapes or welded link chains shall not be used as suspension means. Where wire ropes are used, the diameter shall be not less than 6 mm (0.25 in.). Where aircraft cable is used, the diameter shall be not less than 3 mm (0.125 in.).

4.5.2 Factors of Safety. The suspension and support means shall have a factor of safety of not less than 7 based on the tension in the rope, cable, chain, or forces exerted on the hydraulic cylinder, screw drive, or rack and pinion when raising the rated load. When the carriage and counterweight are suspended by steel ropes and the driving means between the machine and the counterweight is an endless roller-type chain, the factor of safety of such chain shall be not less than 8, based on the rated load. See [section 8](#) for special requirements for particular drive systems.

4.5.3 Replacement of Chains and Sprockets. If two or more chains are used as a suspension or support means and a worn chain or sprocket is replaced, all chains and sprockets shall be replaced.

4.6 Chairs and Seats

Each chair shall have a foot platform and a seat with a backrest and a seat belt. Each chair shall be equipped with two hand grips or arms. If the chair stops less than 500 mm (20 in.) beyond the nose of the top landing, measured horizontally from the center of the seat, a swivel seat shall be provided. The swivel shall have a positive locking mechanism, and the seat shall have an electric contact that shall prevent the operation of the lift when the seat is not in the operating position.

4.6.1 Chair Truck and Guides. The chair shall be securely anchored to a truck that supports it. The truck shall be restrained in a track or on a guide-rail assembly.

4.6.2 Factors of Safety. The factor of safety used in the design of the carriage and truck shall be not less than 5 based on the rated load.

4.6.3 Footrest Obstruction Device. If the footrest is located so that it is within 150 mm (6 in.) of the step nosing or riser, a device shall be provided on the footrest to stop the upward motion of the carriage if it encounters an object between the footrest and step nosing or riser.

4.6.4 Footrest Clearance. At no point in its travel shall the edge of the footrest facing the upper landing be more than 600 mm (24 in.) above the step or landing as measured vertically.

4.7 Capacity, Speed, and Angle of Inclination

4.7.1 Limitations of Capacity, Load, and Speed. The capacity shall not exceed two persons. The rated load shall be not less than 115 kg (250 lb) for a one-seat lift and not less than 180 kg (400 lb) for a two-seat lift. The rated speed shall not exceed 0.2 m/s (40 ft/min).

4.7.2 Limitation of Angle. No lift shall be installed to operate on a greater incline than 45 deg as measured on the mean.

4.7.3 Capacity Plate. A capacity plate stating the rated load in pounds shall be furnished by the manufacturer and fastened in a conspicuous place on the device. Letters and numbers shall be not less than 6 mm (0.25 in.) in height.

4.7.4 Data Plates. A data plate shall be provided by the manufacturer and securely fastened in a conspicuous place. The plate shall state the rated speed, rated load, suspension or support means, date of manufacture, and manufacturer's name. Letters and numerals shall be not less than 6 mm (0.25 in.) in height.

4.8 Safeties and Speed Governors

All carriages shall be provided with a safety, except for carriages of direct-plunger hydraulic lifts or other drive systems that are designed so that the failure of any single

drive component cannot result in the platform over-speeding. The safety shall be actuated by the action of a speed governor or by the breakage or slackening of the suspension or support means. Where actuation is by a governor, the safety shall be set at a maximum speed of 0.4 m/s (75 ft/min). Where actuation is by breakage of the suspension or support means, the safety shall be set without delay, and independent of the speed governor, if provided. Safety parts shall conform to the requirements of 4.8.1. Governor ropes, where provided, shall conform to the requirements of 4.8.2. The application and release of safeties shall conform to the requirements of 4.8.3.

4.8.1 Minimum Factors of Safety and Stresses of Safety Parts and Rope Connections

4.8.1.1 Parts of safeties, except springs, safety-rope drums, leading sheaves, and their supporting brackets and safety-jaw gibs, shall have a factor of safety of not less than 3.5, based on the ultimate strength of the material, and the materials used shall have an elongation of not less than 15% in a length of 50 mm (2 in.). Forged, cast, or welded parts shall be stress relieved.

(20) **4.8.1.2** Springs shall be permitted to be used in the operation of carriage or counterweight safeties. Where springs are used and partially loaded prior to safety operation, the loading on the spring shall not produce a fiber stress exceeding one-half of the elastic limit of the material. During operation of the safety, the fiber stress shall not exceed 85% of the elastic limit of the material. Helical springs, where used, shall be in compression.

4.8.1.3 Safety-rope drums, leading sheaves, and their supporting brackets and safety-jaw gibs shall be permitted to be made of cast iron and other metals, provided such parts have a factor of safety of not less than 10.

4.8.1.4 Rope used as a connection from the safety to the governor rope, including rope wound on the safety-rope drum, shall be not less than 3 mm (0.125 in.) diameter and shall be made of a corrosion-resistant metal.

The factor of safety of the rope shall be not less than 5. Tiller-rope construction shall not be used.

4.8.1.5 The factors of safety shall be based on the maximum stresses developed in the parts during the operation of the safety when stopping the rated load from the governor tripping speed.

4.8.1.6 Safety-rope leading-sheave brackets and other safety operating parts shall not be attached to or supported by wood platform members.

4.8.2 Material and Factor of Safety. Governor ropes shall be of iron, steel, monel metal, phosphor bronze, or stainless steel. They shall be of a regular-lay construction, and not less than 6 mm (0.25 in.) in diameter. The factor of

safety of governor ropes shall be not less than 5. Tiller-rope construction shall not be used.

4.8.3 Means of Application. Safeties shall be applied mechanically. Electric, hydraulic, or pneumatic devices shall not be used to apply the safeties required by this section, nor to hold such safeties in the retracted position.

4.8.3.1 Level of Chair on Safety Application. The application of a Type A safety to stop the chair with its rated load shall not cause the chair to be out of level more than 30 mm/m (0.375 in./ft) in any direction. (20)

4.8.3.2 Release. When carriage safeties are applied, no decrease in tension in the governor rope nor motion of the carriage in the down direction shall release the safeties, but such safeties shall be permitted to be released by the motion of the chair in the up direction.

4.9 Terminal Stopping Devices

4.9.1 Normal terminal stopping devices required by 4.9.2 shall be permitted to use mechanically operated, magnetically operated, optical, or static-type switches.

Final terminal stopping devices required by 4.9.3 shall use only mechanically operated switches for determining platform position.

Terminal stopping devices that are located on the carriage or in the runway shall be of the enclosed type and securely mounted in such a manner that horizontal movement of the carriage shall not affect the operation of the device.

4.9.2 Upper and lower normal terminal stopping devices operated by the carriage shall be provided, and shall be set to stop the chair at or near the upper and lower terminal landings under rated loading to zero loading conditions.

4.9.3 Upper and lower final terminal stopping devices operated by the carriage to remove power from the motor and the brake shall be provided, except as specified in 4.9.6. They shall be set to stop the carriage after it travels past the normal terminal stopping device and before striking an obstruction.

A slack-rope device equipped with a slack-rope switch of the enclosed manually reset type that shall cause the electric power to be removed from the driving-machine motor and brake, if any hoisting rope becomes slack, shall be permitted to be used as the lower final terminal stopping device.

4.9.4 Final terminal stopping devices shall be mechanically operated. The switch contacts shall be directly opened mechanically. Arrangements that depend on a spring or gravity, or a combination thereof, to open the contacts shall not be used.

4.9.5 The final terminal stopping device shall not control the same controller switches as the normal terminal stopping device unless two or more separate and independent switches are provided, two of which shall be closed to complete the driving-machine motor-and-brake circuit in either direction of travel. Where a two- or three-phase alternating-current driving-machine motor is used, these switches shall be of the multipole type. The control shall be so designed and installed that a single ground or short circuit shall be permitted to allow either, but not prevent both, of the normal and final stopping device circuits from stopping the carriage.

4.9.6 Final terminal stopping devices are not required for direct-plunger hydraulic driving machines. Lower final terminal stopping devices are not required where the limitations of the machine or runway limit the travel of the carriage (e.g., a carriage at rest on the bottom terminal landing).

4.10 Operating Devices and Control Equipment

- (20) **4.10.1 Operation.** Operation of the lift from the landings and from the chair shall be controlled by control switches at all stations, and shall be by means of the continuous-pressure type. Controls shall be permanently accessible 1 220 mm (48 in.) maximum and 380 mm (15 in.) minimum above the platform floor or facility floor or ground level. Operating devices shall be designed so that both the “UP” and “DOWN” circuits cannot be operated at the same time.

4.10.2 Motor Reversal Protection. Where a non-instantaneous reversible motor is used, a protective circuit or device shall be provided to prevent the motor from continuing in the same direction if the reversing control is activated.

4.10.3 Electrical Equipment and Wiring

4.10.3.1 All electrical equipment and wiring shall conform to the requirements of NFPA 70.

4.10.3.2 Electrical equipment shall be certified to the requirements of CAN/CSA-B44.1/ASME A17.5.

4.10.3.3 The failure of any single magnetically operated switch, relay, or contractor to release in the intended manner, or the failure of any solid state device to operate as intended, or the occurrence of a single accidental ground or combination of accidental grounds shall not permit the lift to start if this failure renders ineffective any electrical protective device.

4.10.4 Phase Reversal and Failure Protection. Chairlifts having polyphase alternating-current power supply shall be provided with a means to prevent the starting of the motor if the phase rotation is in the wrong direction, or if there is a failure of any phase.

This protection shall be considered to be provided if a reversal of phase of the incoming polyphase alternating-current power will not cause the driving-machine motor to operate in the wrong direction.

4.10.5 Release and Application of Driving-Machine Brake. Driving-machine brakes shall not be electrically released until power has been applied to the driving-machine motor. All power feed lines to the brake shall be opened, and the brake shall apply automatically when any operating device in 4.10.1 or 4.10.2 is in the “STOP” position and when any electrical protective device functions.

4.10.6 Control and Operating Circuits. The design and installation of the control and operating circuits shall conform to 4.10.6.1 and 4.10.6.2.

4.10.6.1 Control systems that depend on the completion or maintenance of an electric circuit shall not be used for interruption of the power and application of the driving-machine brake at terminal landings or stopping the machine when the safety applies.

4.10.6.2 If springs are used to actuate switches, contactors, or relays to break the circuit to stop the lift at the terminal landing, they shall be of the restrained compression type.

4.10.7 Slack-Rope and Slack-Chain Devices for Winding Drum and Roller-Chain-Type Driving Machines. Winding drum driving machines with rope suspension shall be provided with a slack-rope device of the manually reset type that will remove power from the motor and brake if the platform is obstructed in its descent and the suspension ropes slacken. Lifts with roller-chain suspension means shall be provided with a slack-chain device that will remove power from the motor and brake if the platform is obstructed in its descent and the suspension means slacken. This device is not required to be of the manually reset type if the chain sprockets are guarded to prevent the chain from becoming disengaged from the sprockets.

4.11 Code Data Plate

A code data plate shall be provided that indicates the A18.1 Standard to be used for inspections and tests. The data plate shall be in plain view, securely attached on the main line disconnect or on the controller. The data plate shall be of such material and construction that the letters and figures stamped, etched, cast, or otherwise applied to the face shall remain permanently and readily legible. The height of the letters and figures shall be not less than 3 mm (0.125 in.).

5 PRIVATE RESIDENCE VERTICAL PLATFORM LIFTS⁵

Section 5 applies to vertical platform lifts where installed in or at a private residence for use by the mobility impaired.

5.1 Runways

Runways shall be installed in accordance with 2.1.1, 2.1.2, 2.1.3, or 5.1.1. Runway construction for lifts that penetrate a floor must comply with 2.1.1 and with the building code. Only lifts installed in conformance with 2.1.1 shall serve more than two landings.

5.1.1 Guarding

5.1.1.1 The runway shall be guarded at the upper landing by a door at least 900 mm (36 in.) high of solid construction and provided with a combination mechanical lock and electric contact. The door shall be permitted to be opened only if the platform floor is within 50 mm (2 in.) of that landing.

5.1.1.1.1 Door-locking devices shall comply with 2.1.1.4.1.

- (20) **5.1.1.2** A smooth vertical surface shall be provided from the top terminal landing sill and any intermediate landing sill to not less than 25 mm (1 in.) below the level of the platform floor on the lower mechanical stop. Where a pit is provided and is less than 25 mm (1 in.) in depth, the surface shall extend to the pit floor. Openings necessary for operation shall reject a ball 12 mm (0.5 in.) in diameter.

The surface shall be capable of withstanding a force of 330 N (75 lbf) on a 100 mm × 100 mm (4 in. × 4 in.) surface and have deflection less than 20 mm (0.75 in.) in any location. The surface shall not be permanently deformed when a force of 550 N (125 lbf) is applied on any 100 mm × 100 mm (4 in. × 4 in.) area.

Projections from the vertical surface shall not exceed 5 mm (0.20 in.), and projections exceeding 2 mm (0.08 in.) shall be beveled at an angle of 15 deg or less to the line of travel. The clearance between the platform edge and the landing sill or any vertical surface of the hoistway shall be not less than 10 mm (0.375 in.) nor more than 20 mm (0.75 in.).

5.1.1.3 A metal guard at least 150 mm (6 in.) in height and extending the full width of the platform shall be installed on the lower landing side of the platform to prevent a wheelchair from rolling off the platform. The guard shall be automatically actuated by the movement of the platform away from the lower landing, and it shall remain in the elevated position until the platform returns to the lower landing.

5.1.1.4 The guard shall be operated with positive cam action or provided with an electric contact that shall stop the platform if the guard is not fully elevated when the platform has traveled 150 mm (6 in.) away from the lower landing.

5.1.1.5 The guard shall withstand, without permanent deformation, a force of 550 N (125 lbf) applied on any 100 mm × 100 mm (4 in. × 4 in.) area. This force shall not cause the height of the ramp, at any point in its length, to be less than 150 mm (6 in.) measured vertically from the surface of the platform floor.

5.1.1.6 The sides of the platform not used for entrance or exit shall be guarded to a height of at least 900 mm (36 in.) by smooth construction with no openings, other than those necessary for the operation of the lift. Those openings necessary for operation shall reject a ball 12 mm (0.5 in.) in diameter.

5.1.1.7 The underside of the platform shall be guarded in accordance with the requirements of 5.1.1.7.1, 5.1.1.7.2, or 5.1.1.7.3.

5.1.1.7.1 The underside of the platform shall be equipped with a device that, if the platform is obstructed anywhere on its underside in its downward travel, shall cause electric power to be removed from the driving-machine motor and brake, if provided, and cause the platform to stop its downward motion within 50 mm (2 in.). The stroke of the device shall not be less than the stopping distance of the platform. The force required to operate the device shall not exceed 70 N (15 lbf). The lift shall be permitted to operate away from the obstruction. Downward motion shall be permitted to resume when the obstruction is removed. When the installation conforms to the requirements of 2.1.1 or 2.1.2, the sensing device on the underside of the platform is not required.

5.1.1.7.2 The underside of the platform shall be equipped with a bellows or similar device that shall not be permanently deformed when a force of 550 N (125 lbf) is applied on any 100 mm × 100 mm (4 in. × 4 in.) area. Deflection of the bellows due to a force of 330 N (75 lbf) applied on any 100 mm × 100 mm (4 in. × 4 in.) area shall not exceed 75 mm (3 in.) or the distance to contact an internal moving component other than the bellows support mechanism, whichever is less. Deflection shall be measured with the platform at the uppermost landing.

(a) The upper attachment point of the bellows shall be permitted to be inset from the outer edge of the platform, provided that the exposed area of the underside of the platform is equipped with a device that conforms to 5.1.1.7.1.

(b) Deflection greater than that allowed by 5.1.1.7.2 shall be permitted, provided that any additional deflection actuates a sensing device that causes the electric power to be removed from the driving-machine motor and brake, if

⁵ See section 2 for the requirements for this equipment installed in locations other than in or at a private residence.

provided, and causes the platform to stop its downward motion within 50 mm (2 in.). Downward motion shall be permitted to resume when the bellows is returned to its normal condition.

5.1.1.7.3 A force-sensitive safety surface shall be provided covering the entire floor area directly under the moving platform plus 75 mm (3 in.) beyond any exposed platform edge. The device shall prevent downward motion of the platform when activated by a force not to exceed 70 N (15 lbf) applied anywhere on its surface. The lift shall be permitted to operate in the upward direction. Downward motion shall be permitted to resume when the force is removed.

5.1.1.8 The platform floor-to-sill clearance at the upper landing shall not exceed 20 mm (0.75 in.).

5.1.2 Pipes in Runway Vicinity. Pipes conveying steam, gas, or liquids that, if discharged into the runway of the platform, would endanger life or health shall not be permitted.

5.1.3 Lower Level Access Ramps. A retractable ramp shall be permitted to be mounted on the platform floor, and the incline of the ramp shall be not greater than

- (a) 1 in 4 for heights up to 50 mm (2 in.)
- (b) 1 in 6 for heights up to 65 mm (2.5 in.)
- (c) 1 in 8 for heights up to 75 mm (3 in.)
- (d) 1 in 10 for heights up to 100 mm (4 in.)
- (e) 1 in 12 for heights greater than 100 mm (4 in.)

The ramp shall extend the full width of the platform floor. It shall be permitted to be actuated by the movement of the platform away from the lower landing and it shall remain retracted while the platform is away from the lower landing. The ramp shall be permitted to also be used as the guard specified in 5.1.1.3.

The ramp shall be operated by a positive mechanical action or shall be provided with an electric contact that will stop the movement of the platform within 150 mm (6 in.) of the lower landing if the ramp has failed to rise to its elevated position.

5.1.4 Electrical Equipment and Wiring

5.1.4.1 The installation of electrical equipment and wiring shall conform to the requirements of NFPA 70.

5.1.4.2 Electrical equipment shall be certified to the requirements of CAN/CSA-B44.1/ASME A17.5.

5.1.5 Structural Support. The structure on which the equipment is installed shall be capable of safely supporting the loads imposed.

5.1.6 Headroom Clearance. Headroom clearance throughout the range of travel shall be not less than 2000 mm (79 in.) as measured vertically from the platform floor.

5.2 Guide Rails

Guide rails shall conform to the requirements of 5.2.1 through 5.2.5. Where standard tee rails are provided they shall also conform to the requirements of 5.2.6 and 5.2.7. Rail joints shall be designed to maintain the accuracy of the rail alignment and to withstand the stress and deflection limitations stipulated in 5.2.2.

5.2.1 Material. Guide rails, guide-rail brackets, rail clips, fishplates, and their fastenings shall be of steel or other metals conforming to the requirements of 5.2, or, where steel may present an accident hazard, as in chemical or explosive plants, guide rails shall be permitted to be of selected wood or other suitable nonmetallic materials.

5.2.1.1 Requirements for Steel, Where Used. Rails, brackets, fishplates, and rail clips shall be made of open-hearth steel or its equivalent having a tensile strength of not less than 380 MPa (55,000 psi) and having an elongation of not less than 22% in a length of 50 mm (2 in.). Bolts shall conform to ASTM A307. Rivets shall conform to ASTM A502.

5.2.1.2 Requirements for Metals Other Than Steel. Metals other than steel shall be permitted to be used, provided the factor of safety is not less than, and the deflections are not more than, the values specified in section 5, and provided that cast iron is not used.

5.2.2 Stresses and Deflections

5.2.2.1 Guide Rails. For steels conforming to the requirements of 5.2.1.1, the stresses in a guide rail or in the rail and its reinforcement, due to the horizontal forces imposed on the rail during loading, unloading, or running, calculated without impact, shall not exceed 100 MPa (15,000 psi), and the deflection shall not exceed 6 mm (0.25 in.).

Where steels of greater strength than those specified in 5.2.1.1 are used, the stresses specified shall be permitted to be increased proportionately based on the ratio of the ultimate strengths.

5.2.2.2 Brackets, Fastenings, and Supports. The guide-rail brackets, their fastenings, and supports, such as building beams and walls, shall be capable of resisting the horizontal forces imposed by rated load with a total deflection at the point of support not in excess of 3 mm (0.125 in.).

5.2.3 Guide-Rail Surfaces. Guide-rail surfaces used for guiding a platform or counterweight shall be sufficiently smooth and true to operate properly with the guiding members. Those surfaces that the platform or counterweight safeties engage shall be smooth and true within the tolerances required to ensure proper safety application without excessive retardation or excessive out-of-level platform conditions resulting.

5.2.4 Overall Length of Guide Rails. The platform and counterweight guide rails shall extend at the top and bottom to prevent the guiding members from disengaging from the guide rails if either the platform or counterweight reaches its extreme limit of travel.

5.2.5 Design and Strength of Brackets and Supports. The building construction forming the supports for the guide rails, and the guide-rail brackets, shall be designed to safely withstand the application of the platform or counterweight safety when stopping the platform and its rated load or the counterweight, and shall withstand the forces specified in 5.2.2.2 within the deflection limits specified.

Where necessary, the building construction shall be reinforced to provide adequate supports for the guide rails.

5.2.6 Bracket Fastenings. Guide-rail brackets shall be secured to their supporting structure by means of bolts or rivets, or by welding. Fastening bolts and bolt holes in brackets and their supporting beams shall conform to the requirements of 5.2.7. Welding, where used, shall conform to the requirements of 9.1.

5.2.7 Type of Fastenings. Guide rails shall be secured to their brackets by clips, welds, or bolts. Bolts used for fastening shall be of such strength as to withstand the forces specified in 5.2.2.2 and 5.2.5.

Welding, where used, shall conform to the requirements of 9.1.

5.3 Driving Means and Sheaves

The driving means shall be one of the following:

- (a) winding drum
- (b) traction
- (c) roped sprocket
- (d) chain sprocket
- (e) screw
- (f) rack and pinion
- (g) direct-plunger hydraulic
- (h) roped-hydraulic
- (i) lever hydraulic
- (j) lever screw
- (k) friction

Driving means using a combination of two or more means shall conform to all applicable requirements of the respective means unless stated otherwise.

5.3.1 General Requirements

5.3.1.1 The factor of safety, based on the static load (the rated load plus the weight of the platform, ropes, counterweights, etc.), to be used in the design of driving machines and sheaves, including fasteners transmitting load, shall be not less than 8 for steel, bronze, or other metals having an elongation of at least 14% in a length of 50 mm (2 in.) or 10 for cast iron or other metals having an elongation of less than 14% in a

length of 50 mm (2 in.). See section 8 for special requirements for particular drive systems.

5.3.1.2 Set screws or threaded portions located in the shear plane of bolts and screws shall not be used to transmit load.

Means shall be provided to ensure that there is no relative motion between rigidly joined components transmitting load.

Where flexible couplings are used to transmit load, means shall be provided to prevent disengagement of the coupling components in the event of failure or excessive motion in the flexible connection.

A fillet shall be provided at any point of change in the diameter of driving-machine shafts and sheave shafts to prevent excessive stress concentrations in the shafts.

Shafts that support drums, sheaves, gears, couplings, and other members, and that transmit torque, shall be provided with tight-fitting keys.

5.3.1.3 Friction gearing, clutch mechanisms, or couplings shall not be used to connect a driving machine drum or sheave to the main driving mechanism.

5.3.1.4 Worm gearing having cast iron teeth shall not be used on the driving machine.

5.3.1.5 Driving-machine chains and sprockets shall be of steel and shall conform in design and dimensions to the requirements of ASME B29.1.

5.3.1.6 Winding drums, traction sheaves, overhead sheaves, and deflecting sheaves used with suspension and compensating ropes shall be of metal, be provided with finished grooves for ropes or shall be permitted to be lined with nonmetallic groove material, and have a pitch diameter of not less than 30 times the diameter of the suspension ropes. Where 8 × 19 steel rope or 7 × 19 steel aircraft cable is used, however, the pitch diameter of the drums and sheaves shall be permitted to be reduced to 21 times the diameter of the rope or cable.

Where the grooves are used to transmit power, sufficient traction shall be provided between the rope and groove, and in the event of nonmetallic lining failure, between the rope and the remaining sheave groove, to safely stop and hold the platform with 125% of the rated load.

5.3.2 Hydraulic Driving Machines. Direct-plunger hydraulic driving machines, where used, shall conform to the requirements of 8.1 except 8.1.2.

Roped-hydraulic machines shall also conform to the requirements of 8.1 except for 8.1.1, 8.1.3, 8.1.4.3, and 8.1.4.7.

5.3.3 Screw Machines. Screw machines, where used, shall conform to 8.2.

5.3.4 Friction Machines. Friction machines, where used, shall conform to 8.3.

5.3.5 Machine Framework and Base. The machine framework, base, and fastenings to the buildings, where used, shall be of metal construction, have a factor of safety of not less than 5 based on the rated load, and shall be secured in place with support provided to limit their deflections to 6 mm (0.25 in.) maximum in any direction under rated load. Cast iron shall not be used.

5.3.6 Guiding Member Enclosures. The guiding members shall be enclosed with a solid enclosure to prevent accidental contact. If openings are necessary in this enclosure for operation, they shall reject a ball 20 mm (0.75 in.) in diameter.

5.3.7 Machinery Beams and Supports

5.3.7.1 All machinery and sheaves shall be so supported and secured to prevent any part becoming loose or displaced. Beams directly supporting machinery shall be of steel or reinforced concrete.

5.3.7.2 Overhead beams and sheaves shall be designed for not less than the total load on overhead beams, which shall be assumed to be equal to the weight of all apparatus resting on the beams plus twice the maximum load suspended from the beams. The load resting on the beams shall include the complete weights of the driving machine, sheaves, controller, etc. The load suspended from the beams shall include the sum of the tensions in all ropes suspended from the beams.

5.3.7.3 The driving machine or sheaves, except idlers or deflecting sheaves with their guards and frames, shall not be fastened to the underside of the supporting beams at the top of the runway.

5.3.7.4 Cast iron in tension shall not be used for supporting members for sheaves where they are hung beneath beams.

(20) **5.3.8 Guarding of Driving Machines and Suspension Means.** The driving machine and suspension means shall be enclosed with a solid enclosure. Any opening required for operation shall reject a ball 20 mm (0.75 in.) in diameter. Access shall be provided by a removable panel for inspecting and servicing. The panel shall be secured in place using tamper-resistant fasteners or other tamper-resistant means.

5.3.9 Indirect-Drive Machines. Indirect-drive machines, using V-belt drives, tooth drive belts, or drive chains, shall conform to the requirements of 5.3.9.1 through 5.3.9.3, except that the requirements of 5.3.9.2 shall be permitted to be omitted if a self-locking drive meeting the requirements of 5.4.3 is provided. If multiple belts or chains are provided, they shall be preloaded and matched for length in sets.

5.3.9.1 General Requirements. Belt sets shall be selected on the basis of the manufacturer's rated breaking strength and a factor of safety of 10. Chain and sprocket

sets shall be selected on the basis of recommendations set forth in the Supplementary Information section of ASME B29.1, using a service factor of 2. Offset links in chain are not permitted.

Sprockets in a chain-drive set and also a driven set shall be assembled onto a common hub, with teeth cut in-line after assembly to ensure equal load distribution on all chains. Tooth sheaves for a belt drive shall be constructed in a manner to ensure equal load distribution on each belt in the set. Load determination for both the belt and chain sets shall be based on the maximum static loading on the platform, which is the full load in the platform at rest and at a position in the runway that creates the greatest load, including either the platform or counterweight resting on its buffer.

Chain drives and belt drives shall be guarded to protect against accidental contact and to prevent foreign objects from interfering with drives.

5.3.9.2 Monitoring and Brake Location. Each belt or chain in a set shall be continuously monitored by a broken belt or chain device that shall function to automatically interrupt power to the machine and apply the brake if any belt or chain in the set breaks or becomes excessively slack. The driving-machine brake shall be located on the traction sheave or drum assembly side of the driving machine so as to be fully effective if the entire belt set or chain set should break.

5.3.9.3 Replacement of Belts or Chains. If one belt or chain of a set is worn, stretched, or damaged so as to require replacement, the entire set shall be replaced. Sprockets and toothed sheaves shall also be replaced if worn.

5.4 Driving-Machine Brakes

5.4.1 Driving machines, except hydraulic, shall be equipped with friction brakes directly attached to the driving means through a continuous shaft, mechanical coupling, or toothed gearing applied by springs, or by gravity, and released electrically.

5.4.2 A single ground or short circuit, a counter-voltage, or a motor-field discharge shall not prevent the brake magnet from allowing the brake to set when the operating device is placed in the stop position.

5.4.3 A machine brake is not required if a self-locking drive using a lead screw, worm, or other positive gearing that will stop and hold the platform with the rated load within 100 mm (4 in.) of down travel after the power is removed is provided.

5.5 Suspension and Support Means

5.5.1 General Requirements

5.5.1.1 Suspension and support means shall be one or more of the following:

- (a) steel or iron wire rope
- (b) steel aircraft cable
- (c) chain
- (d) hydraulic
- (e) rack and pinion
- (f) screw
- (g) friction machine guides and rollers
- (h) lever

Suspension and support means using a combination of two or more means shall conform to all applicable requirements of the respective means unless stated otherwise.

5.5.1.2 Steel tapes or welded link chains shall not be used as suspension means.

5.5.1.3 Where ropes or chains are used, no fewer than two shall be provided.

5.5.1.4 For rated loads up to 230 kg (500 lb), ropes shall have a minimum diameter of 6 mm (0.25 in.) and chains shall have a minimum pitch of 12 mm (0.5 in.). For higher rated loads, ropes shall have a minimum diameter of 10 mm (0.375 in.) and chains shall have a minimum pitch of 15 mm (0.625 in.).

5.5.2 Factors of Safety. The suspension and support means shall have a factor of safety of not less than 7 based on the tension or forces exerted on the suspension means when raising the rated load. When the platform and counterweight are suspended by steel ropes and the driving means between the machine and the counterweight is an endless roller-type chain, the factor of safety of such chain shall be not less than 8, based on the rated load. See [section 8](#) for special requirements for particular drive means.

5.5.3 Arc of Contact of Suspension Means on Sheaves and Sprockets. The arc of contact of a wire rope on a traction sheave shall be sufficient to produce adequate traction under all load conditions. The arc of contact of a chain on a driving sprocket shall be not less than 140 deg.

5.5.4 Spare Rope Turns on Winding Drums. All wire ropes of winding drum machines shall have not less than one full turn of the rope on the drum when the platform or counterweight has reached its limit of possible overtravel.

5.5.5 Securing Suspension Ropes to Winding Drums. The drum ends of wire ropes shall be secured on the inside of the drum of winding drum machines by clamps, tapered babbitted sockets, or other means approved by the authority having jurisdiction.

5.5.6 Lengthening, Splicing, Repairing, or Replacing Suspension Means. Suspension wire rope shall not be lengthened or repaired by splicing. Broken or worn suspension chains shall not be repaired. If one rope or chain of a set is worn or damaged and requires replacement, the entire set of ropes or chains shall be replaced. If a

chain or sprocket is replaced due to wear, all chains and sprockets shall be replaced.

5.5.7 Fastening of Rope Suspension Means to Platform. The platform ends of wire ropes shall be fastened in a return loop by properly made individual tapered babbitted sockets or properly attached fittings as recommended by wire rope manufacturers. Clips of the U-bolt type shall not be used. Tapered babbitted rope sockets and the method of babbitting shall conform to the requirements of [9.8](#).

5.5.8 Guarding. All suspension means shall be guarded against accidental contact. Suspension means that operate within a guide or track and travel at the same speed and in the same direction as the platform shall be considered suitably guarded.

5.6 Platforms

5.6.1 Frame and Floor. The frame shall be of metal construction and have a factor of safety of not less than 5 based on the rated load. The floor shall be of metal or wood construction with a nonskid surface.

5.6.2 Securing of Enclosures. The enclosure shall be securely fastened to the floor and so supported that it cannot loosen or become displaced in ordinary service, on the application of the platform safety, or on buffer engagement.

The platform enclosure shall be so constructed that removable portions cannot be dismantled from within the platform. Enclosure linings, decorative panels, light fixtures, and other apparatus or equipment attached to the enclosure shall be securely fastened and so supported that they will not loosen or become displaced in ordinary service, on platform safety application, or on buffer engagement.

Panels attached to the enclosure for decorative or other purposes shall not be unfastened from inside the platform by the use of common tools or shall be permitted to be removed from inside the platform when perforations, exceeding that which would reject a ball 12 mm (0.5 in.) in diameter, in the enclosure used for panel hanging or support have permanent means to prevent straight-through passage beyond the running clearance.

5.6.3 Strength and Deflection of Enclosure Walls. The enclosure walls shall be designed and installed to withstand a force of 330 N (75 lbf) applied horizontally at any point on the walls of the enclosure without permanent deformation or causing the deflection to exceed 25 mm (1 in.). (20)

5.6.4 Use of Cast Iron. Cast iron shall not be used in the construction of any load-bearing member of the platform frame or floor other than for guide shoes and guide-shoe brackets.

5.6.5 Floor Size. The inside net floor area shall not exceed 1.7 m^2 (18 ft^2).

5.6.6 Illumination. The minimum illumination at the landing edge of the floor with the landing door open shall be not less than 50 lx (5 fc).

5.7 Capacity, Speed, and Travel

5.7.1 Limitation of Load, Speed, and Travel. The rated load shall be not less than 200 kg (450 lb) nor more than 340 kg (750 lb). Platforms with floor area greater than 1.4 m^2 (15 ft^2) shall have a rated load of not less than 340 kg (750 lb). The lift shall be capable of sustaining and lowering a load as specified in Figure 9.7.

The rated speed shall not exceed 0.15 m/s (30 ft/min). The travel shall not exceed $4\,250 \text{ mm}$ (168 in.).

5.7.2 Capacity Plates. A capacity plate stating the rated load shall be provided by the manufacturer and fastened in a conspicuous place. The letters and numerals used shall be not less than 6 mm (0.25 in.) in height.

5.7.3 Data Plates. A data plate shall be provided by the manufacturer and securely fastened to the machine. The plate shall state the rated speed, rated load, weight of platform, suspension and support means, date of manufacture, and manufacturer's name. Letters and numerals shall be not less than 6 mm (0.25 in.) in height.

5.8 Safeties and Speed Governors

All platforms shall be provided with a safety, except as permitted by 5.8.8. The safety shall be actuated by the action of a speed governor or by the breakage or slackening of the suspension or support means. Where actuation is by a governor, the safety shall be set at a maximum speed of 0.4 m/s (75 ft/min). Where actuation is by breakage or slackening of the suspension or support means, the safety shall be set without delay and independent of the speed governor, if provided. When screw drive machines are used, safeties and speed governors conforming to 5.8.1 shall be permitted. Safety parts shall conform to the requirements of 5.8.2. Governor ropes, where provided, shall conform to the requirements of 5.8.3. Where hoisting ropes are used, the application of safeties shall conform to the requirements of 5.8.4. The application and release of safeties shall conform to the requirements of 5.8.5 through 5.8.7.

5.8.1 Screw Drive Alternate Safety. The platform safety and governor shall be permitted to be omitted if another safety device is provided to either limit the down speed of the platform with rated load to not exceed 0.9 m/s (175 ft/min) in the event of failure of the driving means or to limit the fall of the platform in the event of failure of the driving nut to a distance not exceeding 12 mm (0.5 in.), by using a safety nut or other equivalent means.

The capability of the alternate safety devices to function as required shall be verified by engineering tests as described in 9.6.

5.8.2 Minimum Factors of Safety and Stresses of Safety Parts and Rope Connections

5.8.2.1 Parts of safeties, except springs, safety-rope drums, leading sheaves, and their supporting brackets and safety-jaw gibs, shall have a factor of safety of not less than 3.5, based on the ultimate strength of the material, and the materials used shall have an elongation of not less than 15% in a length of 50 mm (2 in.). Forged, cast, or welded parts shall be stress relieved.

5.8.2.2 Springs shall be permitted to be used in the operation of platform or counterweight safeties. Where springs are used and partially loaded prior to safety operation, the loading on the spring shall not produce a fiber stress exceeding one-half the elastic limit of the material. During operation of the safety, the fiber stress shall not exceed 85% of the elastic limit of the material. Helical springs, where used, shall be in compression.

5.8.2.3 Safety-rope drums, leading sheaves, and their supporting brackets and safety-jaw gibs shall be permitted to be made of cast iron and other metals, provided such parts have a factor of safety of not less than 10.

5.8.2.4 Rope used as a connection from the safety to the governor rope, including rope wound on the safety-rope drum, shall be not less than 3 mm (0.125 in.) in diameter and shall be made of corrosion-resistant metal. The factor of safety of the rope shall be not less than 5. Tiller-rope construction shall not be used.

5.8.2.5 The factors of safety shall be based on the maximum stresses developed in the parts during the operation of the safety when stopping the rated load from the governor tripping speed.

5.8.2.6 Safety-rope leading-sheave brackets and other safety operating parts shall not be attached to or supported by wood platform members.

5.8.3 Material and Factor of Safety. Governor ropes shall be of iron, steel, monel metal, phosphor bronze, or stainless steel. They shall be of a regular-lay construction, and not less than 6 mm (0.25 in.) in diameter. The factor of safety of governor ropes shall be not less than 5. Tiller-rope construction shall not be used.

5.8.4 Type A (Instantaneous) Safeties. When over-speed occurs, with the hoisting rope intact, such safeties shall be actuated by the governor. On the parting of the hoisting ropes (free fall), Type A governor-operated safeties shall apply without appreciable delay, and their application shall be independent of the speed action of the governor and of the location of the break in the hoisting ropes (inertia application), and shall be permitted to be

accomplished by the use of a governor and governor rigging having a sufficiently high value of inertia to apply the safety on free fall independently of the speed action of the governor.

5.8.5 Means of Application. Safeties shall be applied mechanically. Electric, hydraulic, or pneumatic devices shall not be used to apply the safeties required by [section 5](#), nor to hold such safeties in the retracted position.

- (20) **5.8.6 Level of Platform on Safety Application.** The application of a Type A safety to stop the platform, with its rated load centered on each quarter of the platform floor symmetrically with relation to the centerline of the platform floor, shall not cause the platform to be out of level more than 30 mm/m (0.375 in./ft) in any direction.

5.8.7 Release. When platform safeties are applied, no decrease in tension in the governor rope nor motion of the platform in the down direction shall release the safeties, but such safeties shall be permitted to be released by the motion of the platform in the up direction.

5.8.8 Platform Safety Exceptions. Platform safeties are not required for lifts with the following driving means:

- (a) direct-plunger hydraulic
- (b) other drives that do not use a flexible suspension means, provided that the failure of a single drive component cannot result in the platform overspeeding or the floor going out of level more than 30 mm/m (0.375 in./ft) in any direction, and said failure would cause the platform to stop by application of a safety switch or equivalent means

5.9 Terminal Stopping Devices

5.9.1 Normal terminal stopping devices required by [5.9.2](#) shall use mechanically operated, magnetically operated, optical, or static-type switches.

Final terminal stopping devices required by [5.9.3](#) shall use only mechanically operated switches for determining platform position. Terminal stopping devices that are located on the platform or in the runway shall be of the enclosed type and securely mounted in such a manner that horizontal movement of the platform shall not affect the operation of the device.

5.9.2 Except as specified in [5.9.7](#), normal stopping devices operated by the platform shall be provided, and shall be set to stop the platform floor within a tolerance of 12 mm (0.5 in.) of the landings under rated loading to zero loading conditions. The normal stopping devices shall be permitted to also serve as the upper and lower normal terminal stopping devices.

5.9.3 Upper and lower final terminal stopping devices operated by the platform shall be provided to remove power from the motor and the brake, if provided, except as specified in [5.9.6](#). They shall be set to stop

the platform after it travels past the normal terminal stopping device and before striking an obstruction. A slack-rope device equipped with a slack-rope switch of the enclosed manually reset type, which shall cause the electric power to be removed from the driving-machine motor and brake if any hoisting rope becomes slack, shall be permitted to be used as the lower final terminal stopping device.

5.9.4 Final terminal stopping devices shall be mechanically operated. The switch contacts shall be directly opened mechanically. Arrangements that depend on a spring or gravity, or a combination thereof, to open the contacts shall not be used.

5.9.5 The final terminal stopping device shall not (20) control the same controller switches as the normal terminal stopping devices unless two or more separate and independent switches are provided, two of which shall be closed to complete the driving-machine motor-and-brake circuit in either direction of travel. Where a two- or three-phase alternating-current driving-machine motor is used, these switches shall be of the multipole type.

The control shall be so designed and installed that a single ground or short circuit shall be permitted to allow either, but not prevent both, of the normal and final stopping device circuits from stopping the platform.

5.9.6 Final terminal stopping devices are not required for direct-plunger hydraulic driving machines. Lower final terminal stopping devices are not required where the limitations of the machine or runway limit the travel of the platform (e.g., a platform at rest on the bottom terminal landing).

5.9.7 A lower normal terminal stopping device is not required for direct-plunger driving machines where the platform rests on a physical stop at the bottom terminal landing and where the platform floor stops within a tolerance of 12 mm (0.5 in.) of the lower landing under rated loading to zero loading conditions.

5.10 Operating Devices and Control Equipment

5.10.1 Operation. Operation of the lift from the land- (20) ings and from the platform shall be controlled by control switches at all stations, and shall be by means of the continuous-pressure type. Controls shall be 1 220 mm (48 in.) maximum and 380 mm (15 in.) minimum above the platform floor or facility floor or ground level or made accessible to the user. Operating devices shall be designed so that both the "UP" and "DOWN" circuits cannot be operated at the same time.

5.10.2 Attendant Operation. Attendant operation shall be permitted to be provided. Where provided, it shall conform to the requirements of [paras 5.10.2.1](#) and [5.10.2.2](#).

5.10.2.1 The attendant shall operate the lift by means of a continuous-pressure control located at the lower landing. The control shall be so located that the attendant has full view of the floor area under the lift. A manually reset emergency stop switch shall also be provided at that location.

5.10.2.2 No controls, other than an emergency stop switch, shall be provided on the platform.

5.10.3 Control and Operating Circuit Requirements. The design and installation of the control and operating circuits shall conform to the requirements of 5.10.3.1 through 5.10.3.3.

5.10.3.1 Control systems that depend on the completion or maintenance of an electric circuit shall not be used for interruption of the power and application of the machine brake at terminal landings or for stopping the machine when the safety applies.

5.10.3.2 If springs are used to actuate switches, contactors, or relays to break the circuit to stop the lift at the terminal landings, they shall be of the restrained compression type.

5.10.3.3 The failure of any single magnetically operated switch, relay, or contactor to release in the intended manner, or the failure of any solid state device to operate as intended, or the occurrence of a single accidental ground or combination of accidental grounds shall not permit the lift to start if this failure renders ineffective any electrical protective device.

5.10.4 Motor Reversal Protection. Where a non-instantaneous reversible motor is used, a protective circuit or device shall be provided to prevent the motor from continuing in the same direction if the reversing control is activated.

5.10.5 Phase Reversal and Failure Protection. Lifts having polyphase alternating-current power supply shall be provided with means to prevent the starting of the lift motor if the phase rotation is in the wrong direction, or if there is a failure of any phase. This protection shall be considered to be provided if a reversal of phase of the incoming polyphase alternating-current power will not cause the driving-machine motor to operate in the wrong direction.

5.10.6 Emergency Stop Switch. An emergency stop switch shall be provided in the platform, and located in or adjacent to each platform operating panel. When opened, this switch shall cause the electric power to be removed from the driving-machine motor and brake.

Emergency stop switches shall be of the manually opened and closed type and have red operating handles or buttons. They shall be conspicuously and permanently marked "STOP" and shall indicate the "STOP" and "RUN" positions. Switches shall be positively

opened mechanically and their opening shall not be solely dependent on springs. An emergency stop switch shall not be provided on any landing control except as required by 5.10.2.1.

5.10.7 Slack-Rope and Slack-Chain Devices for Winding Drum and Roller-Chain-Type Driving Machines.

Winding drum driving machines with rope suspension shall be provided with a slack-rope device of the manually reset type that will remove power from the motor and brake if the platform is obstructed in its descent and the suspension ropes slacken. Lifts with roller-chain suspension means shall be provided with a slack-chain device that will remove power from the motor and brake if the platform is obstructed in its descent and the suspension means slacken. This device is not required to be of the manually reset type if the chain sprockets are guarded to prevent the chain from becoming disengaged from the sprockets.

5.10.8 Release and Application of Driving-Machine Brake. Driving-machine brakes shall not be electronically released until power has been applied to the driving-machine motor. All power feed lines to the brake shall be opened, and the brake shall apply automatically when any operating device in 5.10.1 or 5.10.2 is in the "STOP" position and when any electrical protective device functions.

5.10.9 Electrical Equipment and Wiring

5.10.9.1 All electrical equipment and wiring shall conform to the requirements of NFPA 70.

5.10.9.2 Electrical equipment shall be certified to the requirements of CAN/CSA-B44.1/ASME A17.5.

5.10.10 Emergency Operations. Means shall be provided to raise or lower the platform manually. This means shall only be accessible to lift personnel, emergency personnel, or authorized personnel. The means to raise or lower the platform shall be capable of moving the platform to a landing and of being accessed and operated without working directly above the platform. (20)

5.10.10.1 The means to manually raise or lower the lift shall provide for controlled ascent or descent no faster than the rated speed and shall be permitted to override operating devices and control equipment. The means shall be permitted to be

- (a) an independent battery-operated system to manually raise or lower the lift
- (b) a manual pump, lowering valve, or cable release device where a hydraulic drive system is used, or
- (c) other suitable means

5.10.10.2 If an opening in the runway is required to access the means to manually raise or lower the platform, it shall be

- (a) located to permit the required access.

(b) a maximum width of 300 mm (12 in.) and a maximum height of 300 mm (12 in.). The opening size shall be permitted to be increased, provided that any resultant opening into the runway shall reject a 300 mm (12 in.) ball.

(c) provided with a door that shall be kept closed and locked. Keys to unlock the access door to the lift runway shall be available only to lift personnel, emergency personnel, or other authorized personnel.

(d) attached so that it cannot fall when opened and shall not open into the runway.

(e) monitored so that the lift cannot be put back into normal operation without being in its closed and locked position.

5.11 Code Data Plate

A code data plate shall be provided that indicates the A18.1 Standard to be used for inspections and tests. The data plate shall be in plain view, securely attached on the main line disconnect or on the controller. The data plate shall be of such material and construction that the letters and figures stamped, etched, cast, or otherwise applied to the face shall remain permanently and readily legible. The height of the letters and figures shall be not less than 3 mm (0.125 in.).

(20) 5.12 Standby Emergency Power

Lifts shall be permitted to have standby emergency power to raise or lower the lift in the event of a main power failure.

6 PRIVATE RESIDENCE INCLINED PLATFORM LIFTS⁶

Section 6 applies to inclined platform lifts where installed in or at a private residence for use by the mobility impaired.

6.1 Runways

6.1.1 Clearances. Clearances between the platform and adjacent surfaces shall be not less than 20 mm (0.75 in.). At no point in its travel shall the edge of the platform facing the upper landing be more than 600 mm (24 in.) above a step or landing as measured vertically.

6.1.2 Pits and Ramps. A pit, floor-mounted ramp, or retractable platform-mounted ramp shall be provided. Floor-mounted ramps shall comply with the requirements of 3.1.4.1. Retractable ramps shall conform to the requirements of 6.6.6.

6.1.3 Pipes in Runway Vicinity. Pipes conveying steam, gas, or liquid that, if discharged into the runway, would endanger life or health shall not be permitted.

6.1.4 Structural Support. The structure on which the equipment is installed shall be capable of safely supporting the loads imposed.

6.1.5 Electrical Equipment and Wiring

6.1.5.1 The installation of electrical equipment and wiring shall conform to the requirements of NFPA 70.

6.1.5.2 Electrical equipment shall be certified to the requirements of CAN/CSA-B44.1/ASME A17.5.

6.2 Guide Rails and Tracks

6.2.1 Material. Platform guide rails shall be of metal construction. Steel construction shall conform to the requirements of 6.2.1.1. Metals other than steel shall conform to the requirements of 6.2.1.2. Guide-rail surfaces shall conform to the requirements of 6.2.1.3.

6.2.1.1 Requirements for Steel, Where Used. Rails, brackets, fishplates, and rail clips shall be made of open-hearth steel or its equivalent having a tensile strength of not less than 380 MPa (55,000 psi) and having an elongation of not less than 22% in a length of 50 mm (2 in.). Bolts shall conform to ASTM A307. Rivets shall conform to ASTM A502.

6.2.1.2 Requirements for Metals Other Than Steel. (20) Metals other than steel shall be permitted to be used, provided the factor of safety is not less than, and the deflections are not more than, the values specified in section 6, and cast iron is not used.

6.2.1.3 Guide-Rail Surfaces. Guide-rail surfaces used for guiding a platform or counterweight shall be sufficiently smooth and true to operate properly with the guiding members. Those surfaces that the platform or counterweight safeties engage shall be smooth and true within the tolerances required to ensure proper safety application without excessive retardation or excessive out-of-level platform conditions resulting.

6.2.2 Location. The top and bottom ends of each run of guide rails shall be so located in relation to the extreme positions of travel of the platform that the platform guiding members cannot travel beyond the ends of the guide rails.

6.2.3 Stresses and Deflections. The stresses and deflections in the guide rails and their brackets shall conform to the requirements of 6.2.3.1 and 6.2.3.2.

6.2.3.1 Guide Rails. For steels conforming to the requirements of 6.2.1, the stresses in a guide rail or in the rail and its reinforcement, due to the horizontal forces imposed on the rail during loading, unloading, or running, calculated without impact, shall not exceed 100 MPa (15,000 psi) and the deflection shall not exceed 6 mm (0.25 in.).

⁶See section 3 for the requirements for this equipment installed in locations other than in or at a private residence.

Where steels of greater strength than those specified in 6.2.1.1 are used, the stresses specified shall be permitted to be increased proportionately based on the ratio of the ultimate strengths.

6.2.3.2 Brackets, Fastening, and Supports. The guide-rail brackets, their fastenings, and supports, such as building beams and walls, shall be capable of resisting the horizontal forces imposed with a total deflection at the point of support not in excess of 3 mm (0.125 in.).

6.2.4 Factor of Safety. The factor of safety used in the design of guide rails shall be not less than 5, based on rated load.

6.2.5 Anchoring. The supporting tracks or guide rails shall be securely anchored to the stairs, floor surface, or sidewalls.

6.3 Driving Means and Sheaves

The driving means shall be one of the following:

- (a) winding drum
- (b) traction
- (c) roped sprocket
- (d) chain sprocket
- (e) screw
- (f) rack and pinion
- (g) direct-plunger hydraulic
- (h) roped-hydraulic
- (i) lever hydraulic
- (j) lever screw
- (k) friction

6.3.1 General Requirements

6.3.1.1 The factors of safety, based on the static load (the rated load plus the weight of the platform, ropes, counterweights, etc.) to be used in the design of driving machines and sheaves shall be not less than 8 for steel, bronze, or other metals having an elongation of at least 14% in a length of 50 mm (2 in.) or 10 for cast iron or other metals having an elongation of less than 14% in a length of 50 mm (2 in.). See section 8 for special requirements for particular drive systems.

6.3.1.2 Set screws or threaded portions located in the shear plane of bolts and screws shall not be used to transmit load.

Means shall be provided to ensure that there is no relative motion between rigidly joined components transmitting load.

Where flexible couplings are used to transmit load, means shall be provided to prevent disengagement of the coupling components in the event of failure or excessive motion in the flexible connection.

A fillet shall be provided at any point of change in the diameter of driving-machine shafts and sheave shafts to prevent excessive stress concentrations in the shafts.

Shafts that support drums, sheaves, gears, couplings, and other members, and that transmit torque, shall be provided with tight-fitting keys.

6.3.1.3 Friction gearing, clutch mechanisms, or couplings shall not be used to connect a driving-machine drum or sheave to the main driving mechanism.

6.3.1.4 Gearing having cast iron teeth shall not be used on the driving machine.

6.3.1.5 Driving-machine chains and sprockets shall be of steel and shall conform in design and dimensions to the requirements of ASME B29.1.

6.3.1.6 Winding drums, traction sheaves, overhead sheaves, and deflecting sheaves shall be of cast iron or steel, of a pitch diameter of not less than 30 times the diameter of the suspension ropes. Where 8 × 19 steel rope or 7 × 19 steel aircraft cable is used, the pitch diameter of drums and sheaves shall be permitted to be reduced to 21 times the diameter of the rope or cable. The rope grooves shall be machined.

6.3.1.7 Guarding of Driving Machines. The driving machine shall be guarded to prevent accidental contact. Any opening required for operation shall reject a ball 20 mm (0.75 in.) in diameter. Access shall be provided for inspecting and servicing. Any guard(s) required to be removed for inspecting and servicing shall be secured in place using tamper-resistant fasteners or other tamper-resistant means. (20)

6.3.2 Hydraulic Driving Machines. Direct-plunger hydraulic driving machines, where used, shall conform to the requirements of 8.1 except 8.1.2.

Roped-hydraulic machines shall conform to the requirements of 8.1, except for 8.1.1, 8.1.3, 8.1.4.3, and 8.1.4.7.

6.3.3 Screw Machines. Screw machines, where used, shall conform to 8.2.

6.3.4 Friction Machines. Friction machines, where used, shall conform to 8.3.

6.3.5 Location of Power Unit and Alignment and Guarding of Sheaves and Sprockets. The power unit shall be permitted to be mounted on the platform or placed at a remote location. If the power unit is remotely located, all intervening sheaves and sprockets shall be so placed that the rope or chain travels in the proper alignment. All sheaves and sprockets shall be enclosed or guarded. (20)

6.3.6 Indirect-Drive Machines. Indirect-drive machines, using V-belt drives, tooth drive belts, or drive chains, shall conform to the requirements of 6.3.6.1 and 6.3.6.2, except that the requirements of 6.3.6.2 shall be permitted to be omitted if a self-locking drive meeting the requirements of 6.4.2 is

provided. If multiple belts or chains are provided, they shall be preloaded and matched for length in sets.

6.3.6.1 General Requirements. Belt sets shall be selected on the basis of the manufacturer's rated breaking strength and a factor of safety of 10. Chain and sprocket sets shall be selected on the basis of recommendations set forth in the Supplementary Information section of ASME B29.1, using a service factor of 2. Offset links in chain are not permitted.

Sprockets in a chain-drive set and also a driven set shall be assembled onto a common hub, with teeth cut in-line after assembly to ensure equal load distribution on all chains. Tooth sheaves for a belt drive shall be constructed in a manner to ensure equal load distribution on each belt in the set. Load determination for both the belt and chain sets shall be based on the maximum static loading on the platform, which is the full load in the platform at rest and at a position in the runway that creates the greatest load, including either the platform or counterweight resting on its buffer.

Chain drives and belt drives shall be guarded to protect against accidental contact and to prevent foreign objects from interfering with drives.

6.3.6.2 Monitoring and Brake Location. Each belt or chain in a set shall be continuously monitored by a broken belt or chain device that shall function to automatically interrupt power to the machine and apply the brake if any belt or chain in the set breaks or becomes excessively slack. The driving-machine brake shall be located on the traction sheave or drum assembly side of the driving machine so as to be fully effective if the entire belt set or chain set should break.

6.4 Driving-Machine Brakes

6.4.1 Driving machines, except hydraulic, shall be equipped with electrically released spring-applied brakes directly attached to the driving means through a continuous shaft, mechanical coupling, or toothed gearing. A single ground or short circuit, a countervoltage, or a motor-field discharge shall not prevent the brake magnet from allowing the brake to set when the operating device is placed in the stop position.

6.4.2 A machine brake is not required if a self-locking drive using a lead screw, worm, or other positive gearing that will stop and hold the platform with the rated load within 100 mm (4 in.) of down travel after the power is removed is provided.

6.5 Suspension and Support Means

6.5.1 General Requirements

6.5.1.1 Suspension and support means shall be one of the following:

- (a) steel or iron wire rope
- (b) steel aircraft cable

- (c) roller chain
- (d) direct-plunger hydraulic
- (e) roped-hydraulic
- (f) rack and pinion
- (g) screw
- (h) friction machine guides and rollers

6.5.1.2 Steel tapes or welded link chains shall not be used as suspension means.

6.5.1.3 Where wire ropes are used, the diameter shall be not less than 6 mm (0.25 in.).

6.5.2 Factors of Safety. The suspension and support means shall have a factor of safety of not less than 7 based on the tension in the rope, cable, chain, or forces exerted on the hydraulic cylinder, screw drive, or rack and pinion when raising the rated load. When the platform and counterweight are suspended by steel ropes and the driving means between the machine and the counterweight is an endless roller-type chain, the factor of safety of such chain shall be not less than 8, based on the rated load. See [section 8](#) for special requirements of particular drive systems.

6.5.3 Arc of Contact of Suspension Means on Sheaves and Sprockets. The arc of contact of a wire rope on a traction sheave shall be sufficient to produce adequate traction under all load conditions. The arc of contact of a chain on a driving sprocket shall be not less than 140 deg.

6.5.4 Spare Rope Turns on Winding Drums. All wire ropes of winding drum machines shall have not less than one full turn of the rope on the drum when the platform or counterweight has reached its limit of possible overtravel.

6.5.5 Securing Suspension Ropes to Winding Drums. The drum ends of wire ropes shall be secured by clamps on the inside of the drum of winding drum machines, by tapered babbitted sockets, or by other means approved by the authority having jurisdiction.

6.5.6 Lengthening, Splicing, Repairing, or Replacing Suspension Means. Suspension wire ropes shall not be lengthened or repaired by splicing. Broken or worn suspension chains shall not be repaired. If one rope or chain of a set is worn or damaged and requires replacement, the entire set of ropes or chains shall be replaced. If a chain or sprocket is replaced due to wear, all chains and sprockets shall be replaced.

6.5.7 Fastening of Rope Suspension Means to Platform. The platform ends of wire ropes shall be fastened in a return loop by properly made individual tapered babbitted sockets or properly attached fittings as recommended by wire rope manufacturers. Clips of the U-bolt type shall not be used. Tapered babbitted rope sockets and the method of babbitting shall conform to the requirements of [9.8](#).

6.5.8 Guarding. All moving suspension means shall be guarded against accidental contact. Suspension means that operate within a guide or track and travel at the same speed and in the same direction as the platform shall be considered suitably guarded.

6.6 Platforms

6.6.1 Frame and Floor. The frame shall be of metal construction and have a factor of safety of not less than 5 based on the rated load. The floor shall be of metal or wood construction with a nonskid surface.

6.6.1.1 Securing of Enclosures. The enclosure shall be securely fastened to the platform and so supported that it cannot loosen or become displaced in ordinary service, on the application of the platform safety, or on buffer engagement.

The enclosure shall be so constructed that removable portions cannot be dismantled from within the platform.

Enclosure linings, decorative panels, light fixtures, and other apparatus or equipment attached within the enclosure shall be securely fastened and so supported that they will not loosen or become displaced in ordinary service, on platform safety application, or on buffer engagement.

Panels attached to the enclosure for decorative or other purposes shall not be unfastened from inside the platform by the use of common tools or shall be permitted to be removed from inside the platform when perforations, exceeding that which would reject a ball 12 mm (0.5 in.) in diameter, in the enclosure used for panel hanging or support have permanent means to prevent straight-through passage beyond the running clearance.

6.6.1.2 Strength and Deflection of Enclosure Walls.

The enclosure walls shall be designed and installed to withstand a force of 330 N (75 lbf) applied horizontally at any point on the walls of the enclosure without permanent deformation or cause the deflection to exceed 25 mm (1 in.).

6.6.2 Floor Area. The inside net floor area shall not exceed 1.7 m² (18 ft²).

6.6.3 Material. Metals having an elongation of less than 20% in a length of 50 mm (2 in.) shall not be used in the construction of any member of the frame or floor.

6.6.4 Glass on Platforms. Glass shall be permitted to be used on platforms subject to the requirements of 6.6.4.1 through 6.6.4.4.

6.6.4.1 It shall be installed and guarded so as to provide adequate protection for passengers in case the glass panels break or are dislodged.

6.6.4.2 It shall be so mounted in the structure so that the structure, including the glass in place, shall withstand the required lift tests without damage.

6.6.4.3 Glass greater than 0.1 m² (1 ft²) in area and abutting panels whose total area is greater than 0.1 m² (1 ft²) shall be laminated glass as defined by ANSI Z97.1 or 16 CFR, Part 1201, Section 1201.2 or shall be glass bonded to a nonpolymeric coating, sheeting, or film backing having the physical integrity to hold the fragments if the glass breaks. Glass shall be tested and conform to the acceptance criteria for laminated glass as specified in ANSI Z97.1 or 16 CFR, Part 1201, Section 1201.4. The glass shall be marked as required by ANSI Z97.1 or 16 CFR, Part 1201, Section 1201.5.

6.6.4.4 Markings as specified in ANSI Z97.1 shall be on each separate piece of glass, and shall remain visible after installation.

6.6.5 Platform Truck and Guides. The platform shall be securely anchored to a truck that supports it. The truck shall be retained in a track or on a guide-rail assembly.

6.6.6 Platform Guarding. A retractable metal guard at least 150 mm (6 in.) high shall be provided on the lower access end of the platform to prevent the wheelchair from rolling off that end of the platform. It shall be automatically actuated or manually activated and shall remain in its elevated position until the platform returns to the landing. It shall be operated by a positive cam action or it shall be provided with an electric contact that will stop the movement of the platform within 150 mm (6 in.) of travel away from the lower landing if the guard has failed to rise to its guarding position.

A retractable platform mounted ramp shall be permitted to be used in lieu of the retractable platform guard. Guards of at least 150 mm (6 in.) in height shall be provided on the sides of the platform not used for access. Guards and ramps, in their guarding position, shall withstand, without permanent deformation, a force of 550 N (125 lbf) applied on any 100 mm × 100 mm (4 in. × 4 in.) area. This force shall not cause the height of the ramp, at any point in its length, to be less than 150 mm (6 in.) measured vertically from the surface of the platform floor.

Means shall be provided to prevent the wheelchair from rolling off the platform floor at the upper access end. Retractable ramps are permitted to serve this function, and when in use, the incline of the ramp shall not be greater than

- (a) 1 in 4 for heights up to 50 mm (2 in.)
- (b) 1 in 6 for heights up to 60 mm (2.5 in.)
- (c) 1 in 8 for heights up to 75 mm (3 in.)
- (d) 1 in 10 for heights up to 100 mm (4 in.)
- (e) 1 in 12 for heights greater than 100 mm (4 in.)

6.6.7 Seats. A lift shall be permitted to be provided with a folding seat and seat belt to accommodate a person not in a wheelchair.

6.6.8 Obstruction Devices. The entire underside and the edges of the platform floor facing the upper and lower landings shall be equipped with a device that will stop the platform traveling within a distance of 50 mm (2 in.) or less if it is obstructed in its travel in either direction. The force required to operate the device shall not exceed 70 N (15 lbf).

6.7 Capacity, Load, and Speed

6.7.1 Limitations of Capacity, Load, and Speed. The capacity shall be one person. The rated load shall be not less than 200 kg (450 lb) and not greater than 340 kg (750 lb). Platforms with a floor area greater than 1.4 m² (15 ft²) shall have a rated load of 340 kg (750 lb). The lift shall be capable of sustaining and lowering a load as specified in Figure 9.7. The rated speed measured along the incline shall not exceed 0.15 m/s (30 ft/min).

6.7.2 Capacity Plate. A capacity plate stating the capacity and rated load shall be furnished by the manufacturer and fastened in a conspicuous place on the device. Letters and numbers shall be not less than 6 mm (0.25 in.) in height.

6.7.3 Data Plates. A data plate shall be provided by the manufacturer and securely fastened in a conspicuous place. The plate shall state the rated speed, rated load, weight of platform, suspension or support means, date of manufacture, and manufacturer's name. Letters and numerals shall be not less than 6 mm (0.25 in.) in height.

6.8 Safeties and Governors

All platforms shall be provided with a safety, except for platforms of direct-plunger hydraulic lifts or self-locking drives using a lead screw or other positive gearing that will stop and hold the carriage with rated load within 100 mm (4 in.) of down travel after power is removed.

The safety shall be actuated by the action of a speed governor or by the breakage or slackening of the suspension or support means. Where actuation is by a governor, the safety shall be set at a maximum speed of 0.4 m/s (75 ft/min). Where actuation is by breakage or slacking of the suspension or support means, the safety shall be set without delay, and independent of the speed governor, if provided.

Safety parts shall conform to the requirements of 6.8.1. Governor ropes, where provided, shall conform to the requirements of 6.8.2.

The application and release of safeties shall conform to the requirements of 6.8.3 through 6.8.5.

6.8.1 Minimum Factors of Safety and Stresses of Safety Parts and Rope Connections

6.8.1.1 Parts of safeties, except springs, safety-rope drums, leading sheaves, and their supporting brackets and safety-jaw gibs, shall have a factor of safety of not less than 3.5, based on the ultimate strength of the material, and the

materials used shall have an elongation of not less than 15% in a length of 50 mm (2 in.). Forged, cast, or welded parts shall be stress relieved.

6.8.1.2 Springs shall be permitted to be used in the operation of platform or counterweight safeties. Where springs are used and partially loaded prior to safety operation, the loading on the spring shall not produce a fiber stress exceeding one-half the elastic limit of the material. During operation of the safety, the fiber stress shall not exceed 85% of the elastic limit of the material. Helical springs, where used, shall be in compression. (20)

6.8.1.3 Safety-rope drums, leading sheaves, and their supporting brackets and safety-jaw gibs shall be permitted to be made of cast iron and other metals, provided such parts have a factor of safety of not less than 10.

6.8.1.4 Rope used as a connection from the safety to the governor rope, including rope wound on the safety-rope drum, shall be not less than 3 mm (0.125 in.) in diameter and shall be made of a corrosion-resistant metal. The factor of safety of the rope shall be not less than 5. Tiller-rope construction shall not be used.

6.8.1.5 The factors of safety shall be based on the maximum stresses developed in the parts during the operation of the safety when stopping the rated load from the governor tripping speed.

6.8.1.6 Safety-rope leading-sheave brackets and other safety operating parts shall not be attached to or supported by wood members.

6.8.2 Material and Factor of Safety. Governor ropes shall be of iron, steel, monel metal, phosphor bronze, or stainless steel. They shall be of a regular-lay construction, and not less than 6 mm (0.25 in.) in diameter. The factor of safety of governor ropes shall be not less than 5. Tiller-rope construction shall not be used.

6.8.3 Means of Application. Safeties shall be applied mechanically. Electric, hydraulic, or pneumatic devices shall not be used to apply the safeties required by section 6, nor to hold such safeties in the retracted position.

6.8.4 Level of Platform on Safety Application. The application of a Type A safety to stop the platform with its rated load centered on each quarter of the platform floor symmetrically with relation to the centerline of the platform floor shall not cause the platform floor to be out of level more than 30 mm/m (0.375 in./ft) in any direction. (20)

6.8.5 Release. When platform safeties are applied, no decrease in tension in the governor rope nor motion of the platform in the down direction shall release the safeties, but such safeties shall be permitted to be released by the motion of the platform in the up direction.

6.9 Terminal Stopping Devices

6.9.1 Normal terminal stopping devices required by 6.9.2 shall be permitted to use mechanically operated, magnetically operated, optical, or static-type switches. Final terminal stopping devices required by 6.9.3 shall use only mechanically operated switches for determining platform position. Terminal stopping devices that are located on the platform or in the runway shall be of the enclosed type and securely mounted in such a manner so that horizontal movement of the platform shall not affect the operation of the device.

6.9.2 Upper and lower normal terminal stopping devices operated by the platform shall be provided, and shall be set to stop the platform within a tolerance of 12 mm (0.5 in.) of the upper and lower terminal landings under rated loading to zero loading conditions.

6.9.3 Upper and lower final terminal stopping devices operated by the platform to remove power from the motor and the brake shall be provided, except as specified in 6.9.6. They shall be set to stop the platform after it travels past the normal terminal stopping device and before striking an obstruction. A slack-rope device equipped with a slack-rope switch of the enclosed manually reset type that shall cause the electric power to be removed from the driving-machine motor and brake if any hoisting rope becomes slack shall be permitted to be used as the lower final terminal stopping device.

6.9.4 Final terminal stopping devices shall be mechanically operated. The switch contacts shall be directly opened mechanically. Arrangements that depend on a spring or gravity, or a combination thereof, to open the contacts shall not be used.

6.9.5 The final terminal stopping device shall not control the same controller switches as the normal terminal stopping devices unless two or more separate and independent switches are provided, two of which shall be closed to complete the driving-machine motor-and-brake circuit in either direction of travel. Where a two- or three-phase alternating-current driving-machine motor is used, these switches shall be of the multipole type. The control shall be so designed and installed that a single ground or short circuit shall be permitted to allow either, but not prevent both, the normal and final stopping device circuits from stopping the platform.

6.9.6 Final terminal stopping devices are not required for direct-plunger hydraulic driving machines. Lower final terminal stopping devices are not required where the limitations of the machine or runway limit the travel of the platform (e.g., a platform at rest on the bottom terminal landing).

6.10 Operating Devices and Control Equipment

6.10.1 Operation. Operation of the chairlift from the landings and from the platform shall be controlled by control switches at all stations, and shall be by means of the continuous-pressure type. Controls shall be 1 220 mm (48 in.) maximum and 380 mm (15 in.) minimum above the platform floor or facility floor or ground level or made accessible to the user. Operating devices shall be designed so that both the "UP" and "DOWN" circuits cannot be operated at the same time. (20)

6.10.2 Attendant Operation. Attendant operation shall be permitted to be provided. Where provided, it shall conform to the requirements of 6.10.2.1 through 6.10.2.3.

6.10.2.1 The attendant shall operate the lift by means of a continuous-pressure switch located on a control box on the free end of a detachable, flexible cord not more than 1 500 mm (60 in.) in length. A manually reset emergency stop switch shall also be provided in the control box.

6.10.2.2 No controls, other than an emergency stop switch, shall be provided on the lift.

6.10.2.3 Where the equipment operates on a straight flight of stairs, and where the platform is within sight during its entire travel, provisions shall be permitted to be made for the attendant to operate the lift from the top or bottom of the stairs.

6.10.3 Control and Operating Circuit Requirements. The design and installation of the control and operating circuits shall conform to the requirements of 6.10.3.1 through 6.10.3.3.

6.10.3.1 Control systems that depend on the completion or maintenance of an electric circuit shall not be used for interruption of the power and application of the machine brake at terminal landings or for stopping the machine when the safety applies.

6.10.3.2 If springs are used to actuate switches, contactors, or relays to break the circuit to stop the lift at the terminal landing, they shall be of the restrained compression type.

6.10.3.3 The failure of any single magnetically operated switch, relay, or contactor to release in the intended manner, or the failure of any solid state device to operate as intended, or the occurrence of a single accidental ground or combination of accidental grounds shall not permit the lift to start if this failure renders ineffective any electrical protective device.

6.10.4 Motor Reversal Protection. Where a non-instantaneous reversible motor is used, a protective circuit or device shall be provided to prevent the motor from continuing in the same direction if the reversing control is activated.

6.10.5 Phase Reversal and Failure Protection. Lifts having polyphase alternating-current power supply shall be provided with means to prevent the starting of the lift motor if the phase rotation is in the wrong direction or if there is a failure of any phase.

This protection shall be considered to be provided if a reversal of phase of the incoming polyphase alternating-current power will not cause the driving-machine motor to operate in the wrong direction.

6.10.6 Electrical Equipment and Wiring

6.10.6.1 All electrical equipment and wiring shall conform to the requirements of NFPA 70.

6.10.6.2 Electrical equipment shall be certified to the requirements of CAN/CSA-B44.1/ASME A17.5.

6.10.7 Slack-Rope and Slack-Chain Devices for Winding Drum and Roller-Chain-Type Driving Machines.

Winding drum driving machines with rope suspension shall be provided with a slack-rope device of the manually reset type that will remove power from the motor and brake if the platform is obstructed in its descent and the suspension ropes slacken. Lifts with roller chain suspension means shall be provided with a slack-chain device, which will remove power from the motor and brake if the platform is obstructed in its descent and the suspension means slacken. This device is not required to be of the manually reset type if the chain sprockets are guarded to prevent the chain from becoming disengaged from the sprockets.

6.10.8 Emergency Stop Switch. An emergency stop switch shall be provided in the platform and located within reach of the passenger whether sitting in a wheelchair or sitting on the folding seat and located 1 200 mm (48 in.) maximum and 380 mm (15 in.) minimum above the platform floor.

When opened, this switch shall cause the electric power to be removed from the lift driving-machine motor and brake. Emergency stop switches shall be of the manually opened and closed type and have red operating handles or buttons. They shall be conspicuously and permanently marked "STOP" and shall indicate the "STOP" and "RUN" positions. Switches shall be positively opened mechanically and their opening shall not be solely dependent on springs.

An emergency stop switch shall not be provided on any landing control except as required by 6.10.2.

6.10.9 Release and Application of Driving-Machine Brake. Driving-machine brakes shall not be electrically released until power has been applied to the driving-machine motor. All power feed lines to the brake shall be opened, and the brake shall apply automatically when any operating device in 6.10.1 or 6.10.2 is in the stop position and when any electrical protective device functions.

6.10.10 Emergency Operations. Means shall be provided to raise or lower the platform manually along the path of travel. This means shall only be accessible to lift personnel, emergency personnel, or authorized personnel. The means to raise or lower the platform shall be capable of moving the platform to a landing and of being accessed and operated without working directly above the platform.

6.10.10.1 The means to manually raise or lower the lift shall provide for controlled ascent or descent not faster than the rated speed and shall be permitted to override operating devices and control equipment. The means shall be permitted to be

(a) an independent battery-operated system to manually raise or lower the lift

(b) a manual pump, lowering valve, or cable release device where a hydraulic drive system is used, or

(c) other suitable means

6.10.10.2 If an opening in the runway is required to access the means to manually raise or lower the platform, it shall be

(a) located to permit the required access.

(b) a maximum width of 300 mm (12 in.) and a maximum height of 300 mm (12 in.). The opening size shall be permitted to be increased, provided that any resultant opening into the runway shall reject a 300 mm (12 in.) ball.

(c) provided with a door that shall be kept closed and locked. Keys to unlock the access door to the lift runway shall be available only to lift personnel, emergency personnel, or other authorized personnel.

(d) attached so that it cannot fall when opened and shall not open into the runway.

(e) monitored so that the lift cannot be put back into normal operation without being in its closed and locked position.

6.11 Code Data Plate

A code data plate shall be provided that indicates the A18.1 Standard to be used for inspections and tests. The data plate shall be in plain view, securely attached on the main line disconnect or on the controller. The data plate shall be of such material and construction that the letters and figures stamped, etched, cast, or otherwise applied to the face shall remain permanently and readily legible. The height of the letters and figures shall be not less than 3 mm (0.125 in.).

6.12 Standby Emergency Power

Lifts shall be permitted to have standby emergency power to raise or lower the lift in the event of a main power failure.

7 PRIVATE RESIDENCE INCLINED STAIRWAY CHAIRLIFTS⁷

Section 7 applies to inclined stairway chairlifts where installed in or at a private residence for use by the mobility impaired.

7.1 Runways

7.1.1 The structure on which the equipment is installed shall be capable of safely supporting the loads imposed.

7.1.2 The installation of electrical equipment and wiring shall conform to the requirements of NFPA 70.

7.1.3 Electrical equipment shall be certified to the requirements of CAN/CSA-B44.1/ASME A17.5.

7.2 Guide Rails and Tracks

The supporting tracks or guide rails shall be securely anchored to the stairs, floor surface, or sidewall.

The factor of safety used in the design of the guide rails and tracks shall be not less than 5 based on the rated load.

7.3 Driving Means and Sheaves

The driving means shall be one of the following:

- (a) winding drum
- (b) traction
- (c) roped sprocket
- (d) chain sprocket
- (e) screw
- (f) rack and pinion
- (g) direct-plunger hydraulic
- (h) roped-hydraulic
- (i) lever hydraulic
- (j) lever screw
- (k) friction

7.3.1 General Requirements

7.3.1.1 The factor of safety used in the design of the sprockets and sheaves shall be not less than 5 based on the rated load. See section 8 for special requirements of particular drive systems.

7.3.1.2 Driving-machine chains and sprockets shall be of steel and shall conform in design and dimensions to the requirements of ASME B29.1.

7.3.1.3 Winding drums, traction sheaves, overhead sheaves, and deflecting sheaves used with suspension and compensating ropes shall be of metal and provided with finished grooves for ropes or shall be permitted to be lined with nonmetallic groove material, and shall have a pitch diameter of not less than 30 times the diameter of the suspension ropes. Where 8 × 19 steel rope or 7 × 19 steel aircraft cable is used, the pitch diameter of the

drums and sheaves shall be permitted to be reduced to 21 times the diameter of the rope or cable.

Where the grooves are used to transmit power, sufficient traction shall be provided between the rope and groove, and in the event of nonmetallic lining failure, between the rope and the remaining sheave groove, to safely stop and hold the chair with 125% of the rated load.

7.3.2 Hydraulic Driving Machines. Direct-plunger hydraulic driving machines, where used, shall conform to the requirements of 8.1, except 8.1.2.

Roped-hydraulic machines shall conform to the requirements of 8.1 except for 8.1.1, 8.1.3, 8.1.4.3, and 8.1.4.7.

7.3.3 Screw Machines. Screw machines, where used, shall conform to 8.2.

7.3.4 Friction Machines. Friction machines, where used, shall conform to 8.3.

7.3.5 Location of Power Unit and Alignment and Guarding of Sheaves and Sprockets. The power unit shall be permitted to be mounted on the carriage or placed at a remote location. If remotely located, all sheaves and sprockets shall be so placed that the rope or chain travels in the proper alignment. All sheaves and sprockets shall be enclosed or guarded.

7.3.6 Indirect-Drive Machines. Indirect-drive machines, using V-belt drives, tooth drive belts, or drive chains, shall conform to the requirements of 7.3.6.1 through 7.3.6.3, except that the requirements of 7.3.6.2 shall be permitted to be omitted if a self-locking drive meeting the requirements of 7.4.2 is provided. If multiple belts or chains are provided, they shall be preloaded and matched for length in sets.

7.3.6.1 General Requirements. Belt sets shall be selected on the basis of the manufacturer's rated breaking strength and a factor of safety of 10. Chain and sprocket sets shall be selected on the basis of recommendations set forth in the Supplementary Information section of ASME B29.1, using a service factor of 2. Offset links in chain are not permitted. Sprockets in a chain-drive set shall be assembled onto a common hub, with teeth cut in-line after assembly to ensure equal load distribution on all chains. Tooth sheaves for a belt drive shall be constructed in a manner to ensure equal load distribution on each belt in the set. Load determination for both the belt and chain sets shall be based on the maximum static loading on the carriage, which is the full load on the chair at rest and at a position in the runway that creates the greatest load, including either the carriage or counterweight resting on its buffer.

Chain drives and belt drives shall be guarded to protect against accidental contact and to prevent foreign objects from interfering with drives.

⁷ See section 4 for the requirements for this equipment installed in locations other than in or at a private residence.

7.3.6.2 Monitoring and Brake Location. Each belt or chain in a set shall be continuously monitored by a broken belt or chain device that shall function to automatically interrupt power to the machine and apply the brake if any belt or chain in the set breaks or becomes excessively slack. The driving-machine brake shall be located on the traction sheaves or drum assembly side of the driving machines so as to be fully effective if the entire belt set or chain set should break.

7.3.6.3 Replacement of Belts or Chains. If one belt or chain of a set is worn, stretched, or damaged so as to require replacement, the entire set shall be replaced. Sprockets and toothed sheaves shall also be replaced if worn.

7.4 Driving-Machine Brakes

7.4.1 A driving-machine brake directly attached to the driving means through a continuous shaft, mechanical coupling, or toothed gearing of the electrically released spring-applied type shall be provided, except on lifts with hydraulic driving machines.

7.4.2 A machine brake is not required if a self-locking drive using a lead screw, worm, or other positive gearing that will stop and hold the carriage with the rated load within 100 mm (4 in.) of down travel after the power is removed is provided.

7.5 Suspension and Support Means

7.5.1 General Requirements

7.5.1.1 Suspension and support means shall be one of the following:

- (a) steel or iron wire rope
- (b) steel aircraft cable
- (c) roller chain
- (d) direct-plunger hydraulic
- (e) roped-hydraulic
- (f) rack and pinion
- (g) screw
- (h) friction machine guides and rollers

7.5.1.2 Steel tapes or welded link chains shall not be used as suspension means. Where wire ropes are used, the diameter shall be not less than 6 mm (0.25 in.). Where aircraft cable is used, the diameter shall be not less than 3 mm (0.125 in.).

7.5.2 Factors of Safety. The suspension and support means shall have a factor of safety of not less than 7 based on the tension in the rope, cable, chain, or forces exerted on the hydraulic cylinder, screw drive, or rack and pinion when raising the rated load. When the carriage and counterweight are suspended by steel ropes and the driving means between the machine and the counterweight is an endless roller-type chain, the factor of safety of such chain shall be not less than 8, based on the rated

load. See [section 8](#) for special requirements for particular drive systems.

7.5.3 Replacement of Chains and Sprockets. If two or more chains are used as a suspension or support means and a worn chain or sprocket is replaced, all chains and sprockets must be replaced.

7.6 Chairs and Seats

Each chair shall be provided with a foot platform, seat, and seat belt. At least one handgrip shall be provided.

7.6.1 Chair Truck and Guides. The chair shall be securely anchored to a truck that supports it. The truck shall be restrained in a track or on a guide-rail assembly.

7.6.2 Factors of Safety. The factor of safety used in the design of the carriage and truck shall be not less than 5 based on the rated load.

7.6.3 Footrest Obstruction Device. If the footrest is located so that it is within 150 mm (6 in.) of the step nosing or riser, a device shall be provided on the footrest to stop the upward motion of the carriage if it encounters an object between the footrest and step nosing or riser.

7.6.4 Footrest Clearance. At no point in its travel shall the edge of the footrest facing the upper landing be more than 600 mm (24 in.) above the step or landing as measured vertically.

7.7 Capacity, Speed, and Angle of Inclination

7.7.1 Limitations of Capacity, Load, and Speed. The capacity shall not exceed two persons. The rated load shall be not less than 115 kg (250 lb) for a one-seat lift and not less than 180 kg (400 lb) for a two-seat lift. The speed, as measured along the incline, shall not exceed 0.2 m/s (40 ft/min).

7.7.2 Limitation of Angle of Inclination. No lift shall be installed to operate on a greater incline than 45 deg as measured on the mean.

7.7.3 Capacity Plate. A capacity plate stating the rated load in pounds shall be furnished by the manufacturer and fastened in a conspicuous place on the device. Letters and numbers shall be not less than 6 mm (0.25 in.) in height.

7.7.4 Data Plates. A data plate shall be provided by the manufacturer and securely fastened in a conspicuous place. It shall state the rated speed, rated load, suspension or support means, date of manufacture, and manufacturer's name. Letters and numerals shall be not less than 6 mm (0.25 in.) in height.

7.8 Safeties and Governors

All carriages shall be provided with a safety, except for platforms of direct-plunger hydraulic lifts or other drive systems that are designed so that the failure of any single drive component cannot result in the platform over-speeding.

The safety shall be actuated by the action of a speed governor or by the breakage or slackening of the suspension or support means. Where actuation is by a governor, the safety shall be set at a maximum speed of 0.4 m/s (75 ft/min). Where actuation is by breakage or slackening of the suspension or support means, the safety shall be set without delay, and independent of the speed governor, if provided.

Safety parts shall conform to the requirements of 7.8.1. Governor ropes, where provided, shall conform to the requirements of 7.8.2.

The application and release of safeties shall conform to the requirements of 7.8.3 through 7.8.5.

7.8.1 Minimum Factors of Safety and Stresses of Safety Parts and Rope Connections

7.8.1.1 Parts of safeties, except springs, safety-rope drums, leading sheaves, and their supporting brackets and safety-jaw gibs, shall have a factor of safety of not less than 3.5, based on the ultimate strength of the material, and the materials used shall have an elongation of not less than 15% in a length of 50 mm (2 in.). Forged, cast, or welded parts shall be stress relieved.

(20) **7.8.1.2** Springs shall be permitted to be used in the operation of chair or counterweight safeties. Where springs are used and partially loaded prior to safety operation, the loading on the spring shall not produce a fiber stress exceeding one-half the elastic limit of the material. During operation of the safety, the fiber stress shall not exceed 85% of the elastic limit of the material. Helical springs, where used, shall be in compression.

7.8.1.3 Safety-rope drums, leading sheaves, and their supporting brackets and safety-jaw gibs shall be permitted to be made of cast iron and other metals, provided such parts have a factor of safety of not less than 10.

7.8.1.4 Rope used as a connection from the safety to the governor rope, including rope wound on the safety-rope drum, shall be not less than 3 mm (0.125 in.) in diameter and shall be made of a corrosion-resistant metal. The factor of safety of the rope shall be not less than 5. Tiller-rope construction shall not be used.

7.8.1.5 The factors of safety shall be based on the maximum stresses developed in the parts during the operation of the safety when stopping the rated load from the governor tripping speed.

7.8.1.6 Safety-rope leading-sheaves brackets and other safety operating parts shall not be attached to or supported by wood platform members.

7.8.2 Material and Factor of Safety. Governor ropes shall be of iron, steel, monel metal, phosphor bronze, or stainless steel. They shall be of a regular-lay construction, and not less than 6 mm (0.25 in.) in diameter. The factor of safety of governor ropes shall be not less than 5. Tiller-rope construction shall not be used.

7.8.3 Means of Application. Safeties shall be applied mechanically. Electric, hydraulic, or pneumatic devices shall not be used to apply the safeties required by section 7, nor to hold such safeties in the retracted position.

7.8.4 Level of Chair on Safety Application. The application of a Type A safety to stop the chair, with its rated load, shall not cause the chair to be out of level more than 30 mm/m (0.375 in./ft) in any direction. (20)

7.8.5 Release. When chair safeties are applied, no decrease in tension in the governor rope nor motion of the chair in the down direction shall release the safeties, but such safeties shall be permitted to be released by the motion of the chair in the up direction.

7.9 Terminal Stopping Devices

7.9.1 Normal terminal stopping devices required by 7.9.2 shall be permitted to use mechanically operated, magnetically operated, optical, or static-type switches.

Final terminal stopping devices required by 7.9.3 shall use only mechanically operated switches for determining chair position.

Terminal stopping devices that are located on the chair or in the runway shall be of the enclosed type and securely mounted in such a manner that horizontal movement of the chair shall not affect the operation of the device.

7.9.2 Upper and lower normal terminal stopping devices operated by the chair shall be provided, and shall be set to stop the chair at or near the upper and lower terminal landings under rated loading to zero loading conditions.

7.9.3 Upper and lower final terminal stopping devices operated by the chair to remove power from the motor and the brake shall be provided, except as specified in 7.9.6. They shall be set to stop the chair after it travels past the normal terminal stopping device and before striking an obstruction. A slack-rope device equipped with a slack-rope switch of the enclosed manually reset type that shall cause the electric power to be removed from the driving-machine motor and brake if any hoisting rope becomes slack shall be permitted to be used as the lower final terminal stopping device.