

NFPA 102

Assembly Seating, Tents and Membrane Structures 1986



NOTICE

All questions or other communications relating to this document should be sent only to NFPA Headquarters, addressed to the attention of the Committee responsible for the document.

For information on the procedures for requesting Technical Committees to issue Formal Interpretations, proposing Tentative Interim Amendments, proposing amendments for Committee consideration, and appeals on matters relating to the content of the document, write to the Secretary, Standards Council, National Fire Protection Association, Batterymarch Park, Quincy, MA 02269.

A statement, written or oral, that is not processed in accordance with Section 16 of the Regulations Governing Committee Projects shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Users of this document should consult applicable Federal, State and local laws and regulations. NFPA does not, by the publication of this document, intend to urge action which is not in compliance with applicable laws and this document may not be construed as doing so.

Policy Adopted by NFPA Board of Directors on December 3, 1982

The Board of Directors reaffirms that the National Fire Protection Association recognizes that the toxicity of the products of combustion is an important factor in the loss of life from fire. NFPA has dealt with that subject in its technical committee documents for many years.

There is a concern that the growing use of synthetic materials may produce more or additional toxic products of combustion in a fire environment. The Board has, therefore, asked all NFPA technical committees to review the documents for which they are responsible to be sure that the documents respond to this current concern. To assist the committees in meeting this request, the Board has appointed an advisory committee to provide specific guidance to the technical committees on questions relating to assessing the hazards of the products of combustion.

Licensing Provision — This document is copyrighted by the National Fire Protection Association (NFPA).

1. Adoption by Reference — Public authorities and others are urged to reference this document in laws, ordinances, regulations, administrative orders or similar instruments. Any deletions, additions and changes desired by the adopting authority must be noted separately. Those using this method are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. The term "adoption by reference" means the citing of title and publishing information only.

2. Adoption by Transcription — **A.** Public authorities with lawmaking or rule-making powers only, upon written notice to the NFPA (Attention: Secretary, Standards Council), will be granted a royalty-free license to print and republish this document in whole or in part, with changes and additions, if any, noted separately, in laws, ordinances, regulations, administrative orders or similar instruments having the force of law, provided that: (1) due notice of NFPA's copyright is contained in each law and in each copy thereof; and, (2) that such printing and republication is limited to numbers sufficient to satisfy the jurisdiction's lawmaking or rulemaking process. **B.** Once this NFPA Code or Standard has been adopted into law, all printings of this document by public authorities with lawmaking or rulemaking powers or any other persons desiring to reproduce this document or its contents as adopted by the jurisdiction in whole or in part, in any form, upon written request to NFPA (Attention: Secretary, Standards Council), will be granted a nonexclusive license to print, republish, and vend this document in whole or in part, with changes and additions, if any, noted separately provided that due notice of NFPA's copyright is contained in each copy. Such license shall be granted only upon agreement to pay NFPA a royalty. This royalty is required to provide funds for the research and development necessary to continue the work of NFPA and its volunteers in continually updating and revising NFPA standards. Under certain circumstances, public authorities with lawmaking or rulemaking powers may apply for and may receive a special royalty when the public interest will be served thereby.

3. Scope of License Grant — The terms and conditions set forth above do not extend to the index to this document.

(For further explanation, see the Policy Concerning the Adoption, Printing and Publication of NFPA Documents which is available upon request from the NFPA.)

Statement on NFPA Procedures

This material has been developed under the published procedures of the National Fire Protection Association, which are designed to assure the appointment of technically competent Committees having balanced representation. While these procedures assure the highest degree of care, neither the National Fire Protection Association, its members, nor those participating in its activities accepts any liability resulting from compliance or noncompliance with the provisions given herein, for any restrictions imposed on materials or processes, or for the completeness of the text.

NFPA has no power or authority to police or enforce compliance with the contents of this document and any certification of products stating compliance with requirements of this document is made at the peril of the certifier.

Errata

NFPA 102

Assembly Seating, Tents and Membrane Structures

1986 Edition

Reference: 3-3.2.1

The Committee on Safety to Life notes the following error in NFPA 102-1986:

1. Insert the word "**Not**" into the boldface title of 3-3.2.1:

3-3.2.1 Capacity per Unit of Exit Width for Enclosed Stadiums, Grandstands, and Arenas **Not** Subject to 3-1.2.

Copyright © 1987 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION, INC.

**CHARLES S. MORGAN LIBRARY
NATIONAL FIRE PROTECTION ASSOCIATION
1 BATTERYMARCH PARK
QUINCY, MA 02269-9101**

© 1986 NFPA. All Rights Reserved

MORGAN TECHNICAL LIBRARY
 NATIONAL FIRE PROTECTION ASSN.
 BATTERY MARCH PARK
 QUINCY, MA 02269

NFPA 102

Standard for

Assembly Seating, Tents and Membrane Structures

1986 Edition

This edition of NFPA 102, *Standard for Assembly Seating, Tents and Membrane Structures*, was prepared by the Technical Committee on Safety to Life and acted on by the National Fire Protection Association, Inc. at its Annual Meeting held May 19-22, 1986, in Atlanta, Georgia. It was issued by the Standards Council on June 11, 1986, with an effective date of July 1, 1986, and supersedes all previous editions.

The 1986 edition of this standard has been approved by the American National Standards Institute.

Origin and Development of NFPA 102

This standard is the result of a committee project inaugurated shortly after the circus fire in Hartford, Conn., on July 6, 1944, in which 168 lives were lost.

A committee was organized under the joint sponsorship of the Building Officials Conference of America and the National Fire Protection Association under the procedure of the American Standards Association. As a result of extensive deliberation during the winter of 1944-1945, this committee prepared a draft of a proposed standard which was submitted at the annual meeting of the National Fire Protection Association in June, 1945. This was then printed and sent to all of the members of the Association, to a representative group of leaders in the outdoor amusement industry, and to all others who filed requests for copies. As a result, numerous constructive suggestions were received, all duly considered by the committee in several meetings, and the 1946 standard was completed by the committee. It was then adopted by the sponsoring organizations, the National Fire Protection Association, and the Building Officials Conference of America, and approved by the American Standards Association as an American Standard on May 22, 1946.

As a result of circulation and use of the 1946 standard, various proposals were made for revision in the interest of clarification. These were considered by the committee and revisions recommended by the committee and circulated to all concerned for comment, further amended, and adopted by the National Fire Protection Association and the Building Officials Conference of America in 1948; the American Standards Association approved the 1948 edition as an American Standard on January 5, 1949.

In 1949 the committee recommended further changes to include the essential features of an earlier standard on grandstands, Z20.1, which covered certain types of grandstands not covered in the 1946-1948 standard, Z20.2, thus making the continuance of the earlier separate standard unnecessary. The 1949 revision, Z20.3, also made the standard applicable to foldable grandstands in buildings that had not been previously covered. After the usual circulation for comment the revisions were adopted in 1949 by the sponsors, and the revised text was approved by the American Standards Association as an American Standard, April 5, 1950.

Revised editions of the standard have been prepared by the committee and adopted by the sponsors in 1957, 1966, and 1967. The 1972 edition was a reconfirmation of the 1967 edition.

The 1978 edition was prepared by the Committee on Tents, Grandstands, and Air-Supported Structures and represented a complete revision of the 1972 edition, complete with a new title, *Standard for Assembly Seating, Tents, and Air-Supported Structures*. The means of egress section was coordinated with the provisions of NFPA 101®, *Life Safety Code*®.

This 1986 edition further coordinates with the *Life Safety Code*. It was prepared by the Technical Committee on Safety to Life through its Subcommittee on Tents and Membrane Structures. Its scope was extended beyond assembly occupancies to include tents and membrane structures used for any occupancy.

Committee on Safety to Life

J. Armand Burgun, *Chairman*
Rogers Burgun Shahine & Deschler Architects

John F. Behrens, *Vice Chairman*
Huntington Beach, CA
Rep. Int'l. Conference of Bldg. Officials

James K. Lathrop, *Secretary*
National Fire Protection Association
(Nonvoting)

Irwin A. Benjamin, Benjamin/Clarke Assoc. Inc.

J. F. Berndt, Nat'l. Research Council of Canada

John L. Bryan, University of Maryland, MD

Wendell H. Couch, Holiday Inns Inc.
Rep. American Hotel & Motel Assn.

John G. Degenkolb, Carson City, NV
Rep. AMP & TVP

Ernest A. Emerson, Texas State Fire Marshal
Rep. FMANA

Russell P. Fleming, Nat'l. Fire Sprinkler Assn.

W. A. Haas, Underwriters Laboratories Inc.

Roger A. Hage, Standard Oil Co. (Indiana)
Rep. Bldg. Owners & Mgrs. Assn.

Paul K. Heilstedt, BOCA Int'l.

William Hiotaky, The Taubman Co.

Richard A. Hudnut, Builders Hardware Mfrs. Assn.

Joseph E. Johnson, Hilton Head Island, SC
Rep. NEMA

Edwina Juillet, Waynesboro Community Hospital, VA

Rep. Nat'l. Task Force on Life Safety

Ode Richard Keil, Joint Comm. on Accred. of Hospitals

Gerald E. Lingenfelter, American Ins. Services Group Inc.

Billy R. Manning, Southern Bldg. Code Congress

Jonas Morehart, Nat'l. Institutes of Health

Harold E. Nelson, NBS Ctr. for Fire Research

R. R. Osman, Schirmer Engineering Corp.

Reginald A. Penney, Palm Beach County Fire Rescue

Rep. FMANA

James R. Quiter, Rolf Jensen & Associates Inc.

Thomas V. Rodante, Caltex Petroleum Corp.

Rep. American Petroleum Inst.

John A. Sharpy, Lawrence-Livermore Laboratories

Richard S. Smith, Chemical Bank of NY

Rep. NFPA Fire Service Section

Walter Smittle III, WV State Fire Marshal

Rep. FMANA

Robert H. Woodcock, Jr., Aetna Life & Casualty Co.

Rep. American Ins. Services Group, Inc.

Alternates

N. Cellentani, Autocall Div. Federal Signal Corp.
(Alternate to J. E. Johnson)

Charles M. Decker, Dept. of Community Affairs
(Alternate to P. K. Heilstedt)

Andrew J. Fowell, Nat'l. Bureau of Standards
(Alternate to H. E. Nelson)

Wayne A. Kleinfelder, Underwriters Laboratories Inc.
(Alternate to W. A. Haas)

John W. McCormick, Rolf Jensen & Assoc. Inc.
(Alternate to J. R. Quiter)

David W. Owen, Mobil Research & Development Corp.

(Alternate to T. V. Rodante)

J. K. Richardson, Nat'l. Research Council of Canada

(Alternate to J. F. Berndt)

Howard Teich, New York, NY

(Alternate to E. Juillet)

Richard Vognild, Southern Bldg. Code Congress Int'l. Inc.

(Alternate to B. R. Manning)

**Subcommittee on
Tents and Membrane Structures**

John G. Degenkolb, *Chairman*
Carson City, NV

Ron Cote', *Secretary*
National Fire Protection Association
(Nonvoting)

Thomas C. Campbell, Owens-Corning Fiberglas
Lee Erdman, CHEMFAB/Birdair Structures
Group

Erwin E. Fuller, Aetna Life & Casualty

Tim Holt, Nat'l. School Supply & Equip. Assn.

Marshal A. Klein, Marshal A. Klein & Assoc.
Inc.

Joseph C. Reed, E. I. duPont Co.
Rep. Society of the Plastics Industry

Neil Schultz, VTEC Laboratories Inc.

John A. Sharry, Lawrence - Livermore Labora-
tories

David L. Sutter, Hussey Mfr. Co. Inc.

Bala Venkataraman, Seaman Corp.

Bruce Wodetzki, Danville Tent & Awning Co.
Rep. IFAI

Alternate

James R. Porter, Owens-Corning Fiberglas Corp.
(Alternate to T. Campbell)

*This list represents the membership at the time the Committee was balloted on the text of this edition.
Since that time, changes in the membership may have occurred*

NOTE: Membership on a Committee shall not in and of itself constitute an endorsement of the
Association or any document developed by the Committee on which the member serves.

Contents

| | |
|---|--------|
| Chapter 1 General | 102- 6 |
| 1-1 Scope | 102- 6 |
| 1-2 Purpose | 102- 6 |
| 1-3 Application | 102- 6 |
| 1-4 Referenced Design Standards | 102- 6 |
| 1-5 Equivalency Concepts | 102- 6 |
| Chapter 2 Definitions | 102- 6 |
| 2-1 General | 102- 6 |
| 2-2 Definitions | 102- 6 |
| Chapter 3 Means of Egress | 102- 8 |
| 3-1 General | 102- 8 |
| 3-2 Types of Exits | 102- 9 |
| 3-3 Capacity of Exits | 102- 9 |
| 3-4 Number of Exits | 102- 9 |
| 3-5 Arrangement of Means of Egress | 102-10 |
| 3-6 Travel Distance | 102-10 |
| 3-7 Exit Discharge | 102-10 |
| 3-8 Illumination of Means of Egress | 102-10 |
| 3-9 Marking of Means of Egress | 102-10 |
| Chapter 4 Grandstands and Bleachers | 102-10 |
| 4-1 Location | 102-10 |
| 4-2 Design | 102-10 |
| 4-3 Aisles | 102-11 |
| 4-4 Travel Distance | 102-12 |
| 4-5 Seating | 102-12 |
| 4-6 Railings or Guards | 102-12 |
| 4-7 Special Requirements — Wood Grandstands | 102-13 |
| 4-8 Special Requirements — Portable Grandstands | 102-13 |
| 4-9 Spaces Underneath Grandstands | 102-13 |
| 4-10 Maintenance | 102-13 |
| Chapter 5 Folding and Telescopic Seating | 102-14 |
| 5-1 Application | 102-14 |
| 5-2 Design | 102-14 |
| 5-3 Review and Approvals | 102-14 |
| 5-4 Aisles | 102-14 |
| 5-5 Travel Distance | 102-14 |
| 5-6 Seating | 102-14 |
| 5-7 Guards and Rails | 102-15 |
| 5-8 Maintenance and Operation | 102-15 |
| Chapter 6 Permanent Membrane Structures | 102-15 |
| 6-1 General | 102-15 |
| 6-2 Tensioned-Membrane Structures | 102-16 |
| 6-3 Air-Supported, Air-Inflated Structures | 102-16 |
| Chapter 7 Temporary Membrane Structures | 102-17 |
| 7-1 General | 102-17 |
| 7-2 Safety | 102-17 |
| Chapter 8 Tents | 102-17 |
| 8-1 General | 102-17 |
| 8-2 Size Limitations | 102-17 |
| 8-3 Structural Requirements | 102-17 |
| 8-4 Flame Resistance | 102-17 |
| 8-5 Location and Means of Egress | 102-18 |

| | |
|---|--------|
| Chapter 9 Protection | 102-18 |
| 9-1 Flammable Liquids and Gases | 102-18 |
| 9-2 Fire Hazard | 102-18 |
| 9-3 Fire Extinguishing Equipment | 102-18 |
| 9-4 Emergency Communications | 102-19 |
| 9-5 Fire Detail | 102-19 |
| Chapter 10 Services | 102-19 |
| 10-1 Electrical Installations | 102-19 |
| 10-2 Heating Devices | 102-19 |
| Chapter 11 Referenced Publications | 102-19 |
| Appendix A | 102-20 |
| Appendix B Referenced Publications | 102-22 |
| Index | 102-23 |

NFPA 102**Standard for****Assembly Seating, Tents and
Membrane Structures****1986 Edition**

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates explanatory material on that paragraph in Appendix A.

Information on referenced publications can be found in Chapter 11 and Appendix B.

Chapter 1 General

1-1* Scope. This standard covers the following structures:

- (a) Folding or telescopic seating for mass seating as differentiated from grandstands and bleachers.
- (b) Assembly seating facilities, such as grandstands and bleachers, that are permanent, temporary, or portable, and that are fixed, folding, or telescoping and that are not within the scope of NFPA 101®, *Life Safety Code*®. Such seating facilities may be located in the open air or within enclosed or semienclosed structures such as tents, membrane structures, and stadium complexes.
- (c) Means of egress for assembly seating described in (a).
- (d) The construction, location, protection, and maintenance of tents and membrane structures used for any occupancy as permitted by the applicable building code.

1-2 Purpose. The purpose of this standard is to provide for life safety in relation to fire, storm, collapse, and crowd behavior in assembly seating, tents, and membrane structures.

1-3 Application. This standard applies to new facilities. Where specifically noted, it also applies to existing facilities.

1-4 Referenced Design Standards. The materials, design, fabrication, and construction of structures or devices included within the scope of this standard shall comply with approved construction standards for safety to life and property as contained herein and in the applicable building code. In matters not specifically covered in this standard, conformity with the applicable standards in Chapter 11 shall be deemed as compliance with approved standards for safety to persons and property.

1-5 Equivalency Concepts.

1-5.1 Nothing in this standard is intended to prevent the use of systems, methods, or devices of equivalent or superior quality, strength, fire resistance, effectiveness, durability, and safety to those prescribed by this standard provided technical documentation is submitted to the authority having jurisdiction to demonstrate equivalency

and the system, method, or device is approved for the intended purpose.

1-5.2 The specific requirements of this standard may be modified by the authority having jurisdiction to allow alternative arrangements that will secure as nearly equivalent safety to life from fire as practical, but in no case shall the modification afford less safety to life than in the judgement of the authority having jurisdiction that which would be provided by compliance with the corresponding provisions contained in this standard.

1-5.3 Buildings with alternative fire protection features accepted by the authority having jurisdiction shall be considered to conform with this standard.

Chapter 2 Definitions**2-1 General.**

2-1.1 The following terms, for the purposes of this standard, shall have the meanings given in this chapter.

2-1.2 Words used in the present tense include the future; words used in the masculine gender include the feminine and neuter; the singular number includes the plural and the plural the singular.

2-1.3 Where terms are not defined in this chapter, they shall have their ordinarily accepted meanings or such as the context may imply.

2-2 Definitions.

Air-Inflated Structure. A structure whose shape is maintained by air pressure in cells or tubes forming all or part of the enclosure of the usable area. Occupants of such a structure do not occupy the pressurized area used to support the structure.

Air-Supported Structure.* A structure where shape is maintained by air pressure, and occupants of the structure are within the elevated pressure area.

Approved. Acceptable to the "authority having jurisdiction."

NOTE: The National Fire Protection Association does not approve, inspect or certify any installations, procedures, equipment, or materials nor does it approve or evaluate testing laboratories. In determining the acceptability of installations or procedures, equipment or materials, the authority having jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure or use. The authority having jurisdiction may also refer to the listings or labeling practices of an organization concerned with product evaluations which is in a position to determine compliance with appropriate standards for the current production of listed items.

Assembly Occupancy.* Includes, but is not limited to, all structures or portions of structures used for gathering together 50 or more persons for such purposes as deliberation, worship, entertainment, eating and drinking, amusement, or awaiting transportation.

Authority Having Jurisdiction. The “authority having jurisdiction” is the organization, office or individual responsible for “approving” equipment, an installation or a procedure.

NOTE: The phrase “authority having jurisdiction” is used in NFPA documents in a broad manner since jurisdictions and “approval” agencies vary as do their responsibilities. Where public safety is primary, the “authority having jurisdiction” may be a federal, state, local or other regional department or individual such as a fire chief, fire marshal, chief of a fire prevention bureau, labor department, health department, building official, electrical inspector, or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the “authority having jurisdiction.” In many circumstances the property owner or his designated agent assumes the role of the “authority having jurisdiction”; at government installations, the commanding officer or departmental official may be the “authority having jurisdiction.”

Bleachers. A grandstand where the seats are not provided with backrests.

Exit.* That portion of a means of egress that is separated from all other spaces of the building or structure by construction or equipment as required to provide a protected way of travel to the exit discharge.

Exit Access. That portion of a means of egress that leads to an entrance to an exit.

Exit Discharge. That portion of a means of egress between the termination of an exit and a public way.

Fire Resistance. The time in minutes or hours that materials or assemblies have withstood a fire exposure as established in accordance with the test procedures of NFPA 251, *Standard Methods of Fire Tests of Building Construction and Materials*.

Folding and Telescopic Seating. A structure that is used for tiered seating of persons, and whose overall shape and size may be reduced, without being dismantled, for purposes of moving or storing.

Grandstand. A structure providing tiered or stepped seating. Where the term *grandstand* is preceded by an adjective denoting a material, it shall mean a grandstand the essential members of which, exclusive of seating, are of the material designated.

Heavy Timber Construction. Type IV (2HH) construction as defined in NFPA 220, *Standard on Types of Building Construction*.

Labeled. Equipment or materials to which has been attached a label, symbol or other identifying mark of an organization acceptable to the “authority having jurisdiction” and concerned with product evaluation, that maintains periodic inspection of production of labeled equipment or materials and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

Limited-Combustible. As applied to a building construction material, means a material, not complying with

the definition of noncombustible material, that, in the form in which it is used, has a potential heat value not exceeding 3500 Btu per pound (8141 kJ/kg) per NFPA 259, *Standard Test Method for Potential Heat of Building Materials*, and complies with one of the following paragraphs (a) or (b). Materials subject to increase in combustibility or flame spread rating beyond the limits herein established through the effects of age, moisture, or other atmospheric condition shall be considered combustible.

(a) Materials having a structural base of noncombustible material, with a surfacing not exceeding a thickness of $\frac{1}{8}$ in. (3.2 mm) that has a flame spread rating not greater than 50.

(b) Materials, in the form and thickness used, other than as described in (a), having neither a flame spread rating greater than 25 nor evidence of continued progressive combustion and of such composition that surfaces that would be exposed by cutting through the material on any plane would have neither a flame spread rating greater than 25 nor evidence of continued progressive combustion.

Listed. Equipment or materials included in a list published by an organization acceptable to the “authority having jurisdiction” and concerned with product evaluation, that maintains periodic inspection of production of listed equipment or materials and whose listing states either that the equipment or material meets appropriate standards or has been tested and found suitable for use in a specified manner.

NOTE: The means for identifying listed equipment may vary for each organization concerned with product evaluation, some of which do not recognize equipment as listed unless it is also labeled. The “authority having jurisdiction” should utilize the system employed by the listing organization to identify a listed product.

Means of Egress. A continuous and unobstructed way of exit travel from any point in a building or structure to a public way, consisting of three separate and distinct parts: (a) the way of exit access, (b) the exit, and (c) the way of exit discharge. A means of egress comprises the vertical and horizontal ways of travel and shall include intervening room spaces, doorways, hallways, corridors, passageways, balconies, ramps, stairs, enclosures, lobbies, escalators, horizontal exits, courts, and yards.

Membrane. A thin, flexible, water-impervious material capable of being supported by an air pressure of 1.5 in. (38.1 mm) of water column.

Membrane Structure. A building or portion of a building incorporating an air-inflated, air-supported, tensioned-membrane structure, a membrane roof, or membrane-covered rigid frame to protect habitable or usable space.

Noncombustible Material. A material that, in the form in which it is used and under the conditions anticipated, will not ignite, burn, support combustion, or release flammable vapors, when subjected to fire or heat. Materials that are reported as passing ASTM E 136, *Test*

Method for Behavior of Materials in a Vertical Tube Furnace at 750°C, shall be considered noncombustible materials.

Permanent. A building or structure that is intended to remain in place for a period of 180 days or more.

Private Party Tent. A tent erected in the yard of a private residence for entertainment, recreation, dining, reception, or similar function.

Professional Engineer. An engineer who is registered or licensed to practice engineering.

Shall. Indicates a mandatory requirement.

Should. Indicates a recommendation or that which is advised but not required.

Smoke-Protected Assembly Seating. Seating served by means of egress that is not subject to blockage by smoke accumulation within or under a structure.

Temporary. In place for less than 180 consecutive calendar days.

Tensioned-Membrane Structure. A membrane structure incorporating a membrane and a structural support system such as arches, columns and cables, or beams wherein the stresses developed in the tensioned membrane interact with those in the structural support so that the entire assembly acts together to resist the applied loads.

Tent. A temporary structure, the covering of which is made of pliable material that achieves its support by mechanical means such as beams, columns, poles, arches, rope, and/or cables. Tent may also include a temporary tensioned-membrane structure.

Weathered Membrane Material. Membrane material that has been subjected to a minimum of 3,000 hours in a weatherometer in accordance with ASTM G 26, *Practice for Operating Light/Exposure Apparatus (Zenon-Arc Type) With and Without Water for Exposure of Non-Metallic Materials*, or approved equal.

Chapter 3 Means of Egress

3-1 General.

3-1.1 Where not specifically covered by this standard, means of egress from facilities included with the scope of this standard shall comply with the provisions of NFPA 101, *Life Safety Code*.

3-1.2 Smoke-Protected Assembly Seating.

3-1.2.1* For purposes of means of egress for fixed seating, an assembly area with an occupant load in excess of 25,000 wherein the roof is not less than 15 ft (4.6 m) above the highest cross aisle or seat row, and having

smoke-actuated venting facilities within that part of the roof sufficient to maintain the level of smoke at least 6 ft (2.1 m) above the highest seating or walking level, shall be considered smoke-protected assembly seating. One method for such determination is contained in NFPA 204M, *Guide for Smoke and Heat Venting*.

3-1.2.2 Outdoor assembly seating and means of egress under a roof or other construction shall not be considered to be inherently smoke-protected assembly seating (*see Section 2-2*). Such areas shall be evaluated using applicable methods. One method for such determination is contained in NFPA 204M, *Guide for Smoke and Heat Venting*.

3-1.3 No aisle, passageway, stair, door, or other means of egress shall be obstructed in any manner while the facilities are occupied by the public.

3-1.4 No guy wire or guy rope shall cross any means of egress at a height of less than 7 ft (2.1 m). Tent stakes adjacent to any means of egress from any tent open to the public shall be railed off, capped, or covered in such manner as not to present a hazard to the public.

3-1.5* Consideration shall be given for making facilities accessible to physically disabled people.

3-1.6 Occupant Load.

3-1.6.1 The number of persons admitted to any place of assembly within the scope of this standard shall not exceed the capacity as computed in accordance with the provisions of this section, nor shall it exceed the capacity of the exits as defined in Section 3-3.

3-1.6.2 The occupant load in any assembly structure, or portion thereof, shall be based on the following:

(a) An assembly area of concentrated use with movable seats such as an auditorium, church, chapel, dance floor, or lodge room — 7 net sq ft (0.65 sq m) per person, or

(b) An assembly area of less concentrated use, such as a conference room, dining room, drinking establishment, exhibit room, gymnasium, or lounge — 15 net sq ft (1.4 sq m) per person.

Exception to (a) and (b): The occupant load permitted may be increased above that specified herein if the necessary aisles and exits are provided, subject to the approval of the authority having jurisdiction. An approved aisle, exit, and/or seating diagram may be required by the authority having jurisdiction to substantiate an increase in occupant load.

(c) Seats without dividing arms or other physical definition — 18 linear in. (45.7 linear cm) per person.

(d) The occupant load of an area having fixed seats shall be determined by the number of fixed seats installed.

3-1.6.3 The walking surfaces of stairways, ramps, aisles, passageways, or spaces used for exit access or circulation shall not be obstructed or used for seats or sitting or standing room.

3-2 Types of Exits.

3-2.1 Exits of the specified number and width shall be of one or more of the following types, in accordance with the provisions of Chapter 5 of NFPA 101, *Life Safety Code*.

(a) Door openings, leading directly to the outside of the structure.

(b) Stairs.

(c) Ramps, Class A or Class B.

(d) Previously approved escalators and moving walks in existing buildings and moving in the direction of exit travel.

(e) Revolving doors conforming to the requirements of Chapter 5 of NFPA 101, *Life Safety Code*.

3-2.2 Turnstiles. No turnstiles or other devices to restrict the movement of persons shall be installed in any place of assembly in such a manner as to interfere in any way with required exit facilities.

3-3 Capacity of Exits.

3-3.1 Means of egress shall be measured in units of exit width of 22 in. (55.9 cm). Fractions of a unit less than 12 in. (30.5 cm) shall not be counted. Fractions of a unit comprising 12 or more in. (30.5 cm) added to one or more full units shall be counted as one-half unit of exit width.

Exception: Calculation of the required width of means of egress may be done in accordance with the equivalency-based alternative calculation set out in Appendix D of NFPA 101, *Life Safety Code*, provided that performance at least equivalent to that set out by 3-3.3 is attained.

3-3.2 Capacity of Means of Egress.

3-3.2.1 Capacity per Unit of Exit Width for Enclosed Stadiums, Grandstands, and Arenas Subject to 3-1.2. The capacity and number of persons per unit of exit width for approved components of means of egress shall be as follows:

(a) Class A ramps and level egress components, not including revolving doors and turnstiles — 100.

(b) Class B ramps — 90 for travel in the up direction, 100 for travel in the down direction.

(c) Stairway provided with handrails and having a maximum 7 in. (17.8 cm) rise and a minimum of 11 in. (27.9 cm) tread — 75.

(d) Stairways not qualifying in (c) above — 60.

Exception No. 1: Revolving doors conforming to the requirements of Chapter 5 of NFPA 101, *Life Safety Code*, may be credited with the total capacity of 50 persons per door.

Exception No. 2: Existing previously approved escalators and moving walks, when moving only in the direction of exit travel, may be considered the equivalent of the lowest-quality, lowest-capacity stairs in computing exit capacity.

3-3.2.2* Capacity per Unit of Exit Width for Smoke-Protected Assembly Seating. The capacity in number of persons per unit of exit width for approved com-

ponents of the means of egress shall be as follows:

(a) Class A ramps and level egress components, not including revolving doors and turnstiles — 500.

(b) Class B ramps — 450 for travel in the up direction and 500 for travel in the down direction.

(c) Stairways provided with handrails and having a maximum 7 in. (17.8 cm) rise and a minimum 11 in. (27.9 cm) tread — 350.

(d) Stairways not qualifying in (c) above — 250.

Exception No. 1: Revolving doors conforming to the requirements of Chapter 5 of NFPA 101, *Life Safety Code*, may be credited with the total capacity of 50 persons per door.

Exception No. 2: Existing previously approved escalators and moving walks, when moving only in the direction of exit travel, may be considered the equivalent of the lowest-quality, lowest-capacity stairs in computing exit capacity.

3-3.3 Doorways serving as required exits from stairways, ramps, or passageways shall be not less than 32 in. (81 cm) in clear width. The total clear width of doorways shall provide at least the same capacity as the required capacity of exitways they serve. In addition, where doorways serve escalators or moving walks that could be used for egress, the required total clear width of the doorways shall be increased by the width of the escalators and moving walks.

3-3.4* The aggregate clear width of doorways serving as exits from the enclosure of a fenced assembly occupancy shall be determined on a basis of not less than one unit of 22 in. (55.9 cm) width for each 100 persons to be accommodated.

Exception: If the enclosure has within it an easily accessible and unobstructed area that provides refuge, the aggregate width may be determined on a basis of not less than one unit of 22 in. (55.9 cm) width for each 500 persons to be accommodated.

3-3.5 The width of exit discharge shall be at least equal to the required width for the occupant load served.

3-3.6 Where several ways serve as exit access, each shall have a width suitable for the traffic but not less than 32 in. (81 cm) in clear width.

Exception: Narrower aisles created by placement of handrails in center of aisles as provided in 4-3.4.2(f).

3-4 Number of Exits.

3-4.1 Every structure and every balcony or tier considered separately used as an assembly occupancy shall be provided with at least two means of egress remote from each other and leading directly to the outside. If the capacity of such structure or balcony or tier thereof exceeds 1,000 there shall be at least three exits, and if the capacity exceeds 4,000 there shall be at least four exits, provided that in tents and membrane structures if the capacity exceeds 500 (600 in existing structures) there shall be at least three exits, and if the capacity exceeds 1,000 there shall be at least four exits.

3-4.2 A fenced outdoor assembly occupancy shall have at least two widely separated exits from the enclosure. If more than 6,000 persons are to be served by such exits, there shall be at least three, and if more than 9,000 there shall be at least four exits. Exits shall be distributed as uniformly as practicable for exit purposes.

3-4.3 The space between a fence and the foot of a ramp, stairway, or vomitory shall be two times the aggregate width of three stairs or vomitories emptying into it and any such space shall be of sufficient width to accommodate one-third of the number of persons entering that particular space based on 3 sq ft (0.28 sq m) per person.

3-5 Arrangement of Means of Egress.

3-5.1 Aisles from seating arrangements that do not lead directly to an exit discharge shall discharge into an unobstructed space leading directly to one or more exit discharges, and shall be so arranged as to be accessible to every occupant; and such space shall have a clear width not less than the required width of the exit to which it leads, but in no case less than 5 ft (1.5 m).

3-5.2 Every aisle shall lead directly to one or more exits or to one or more paths of egress travel providing access to exits. Where aisles converge to form a single path of egress travel, the required egress capacity of that path shall be not less than the combined required egress capacity of the converging aisles. Where egress travel is possible in either of two directions, it shall be assumed that one-half of that number can go in each direction.

3-5.3 In grandstand seating, dead ends in vertical aisles shall not exceed a depth of sixteen rows.

3-6* Travel Distance.

3-6.1 The travel distance along the normal path of travel from any seat to an egress vomitory portal or the egress concourse shall not exceed 150 ft (45.7 m).

Exception: The travel distance may be increased to 200 ft (61 m) in buildings completely protected by automatic sprinklers installed in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems.

3-6.2 The travel distance from the vomitory portal, or entrance to the concourse, to the exterior of the building, or entrance to the stairway or ramp shall not exceed 150 ft (45.7 m) (see A-2-2, Exit).

3-7 Exit Discharge.

3-7.1 All structures regulated by this standard shall have at all times ample and unrestricted exit discharge to public ways at no less than two points remote from each other. An available park, field, or open space may be approved as a public way.

3-7.2 If required exits from structures regulated by this standard do not discharge directly into a street or open space leading to a street, unobstructed lanes not less than 20 ft (6.1 m) in width shall be maintained from such exits to the street at all times while such structures are occupied by the public.

3-8 Illumination of Means of Egress.

3-8.1 Means of egress from structures regulated by this standard shall be kept adequately lighted at all times when such structures are occupied. Artificial light shall be provided whenever natural light is inadequate. Lighting conforming to the requirements of Section 5-8 of NFPA 101, *Life Safety Code*, will be considered adequate.

3-8.2 All tents and membrane structures having an occupant load of 100 or more, if used when natural light is not available, shall have emergency lighting in accordance with Section 5-9 of NFPA 101, *Life Safety Code*.

Exception: Private party tents not larger than 1200 sq ft (111.5 sq m).

3-9 Marking of Means of Egress. In structures having a capacity of 100 persons or more, exit marking shall be provided in accordance with Section 5-10 of NFPA 101, *Life Safety Code*.

Exception: Where egress ramps, stairs, doors, or vomitories are sufficiently obvious to occupants, exit signs may be omitted.

Chapter 4 Grandstands and Bleachers

4-1 Location. Grandstands shall be erected or otherwise located only where adequate load-carrying capacities exist to safely support the loads.

4-2 Design.

4-2.1 The design of grandstands shall be in accordance with accepted structural engineering practice.

4-2.2 Load tests in accordance with accepted engineering practice may be made in lieu of the design analysis for a grandstand unit or a part thereof.

4-2.3 Where required by the authority having jurisdiction, the manufacturer shall submit either calculations verifying the design analysis prepared by a professional engineer or registered architect, or a report of load tests conducted by an approved independent testing laboratory and certified by a professional engineer. The authority having jurisdiction may also require the manufacturer to certify that the equipment supplied is in accordance with the design, or is essentially identical to the structure tested.

4-2.4 A grandstand shall be so designed and assembled that the maximum expansion, contraction, settlement, or misalignment likely to occur will not cause stresses in excess of those permissible, nor jeopardize the structure or its occupants. It shall be of such design as to remain stable, so as not to be overturned either by wind or unequal distribution of live load.

4-2.5 Design Loads.

4-2.5.1 Grandstands shall be designed to support, in addition to their own weight and the weight of added accessories, a uniformly distributed live load of not less than 100 lb per sq ft (488 kg per sq m) of gross horizontal projection.

4-2.5.2 All seat and footboard members shall be designed for live loads of not less than 120 lb per linear ft (179 kg per linear m).

4-2.5.3 Grandstands shall be designed to resist a horizontal swaying force applied to the seats, in a direction parallel to the length of the seats, of 24 lb per linear ft (36 kg per linear m) of seats and, in a direction perpendicular to the length of the seats, of 10 lb per linear ft (15 kg per linear m) of seats.

4-2.5.4 Wind Loads.

4-2.5.4.1 Grandstands shall be designed to withstand, with or without live loads, the horizontal and uplift pressures due to wind. Wind pressures shall be derived from ANSI A58.1, *Minimum Design Loads in Buildings and Other Structures*.

4-2.5.4.2 Horizontal pressures shall be assumed to be acting on the gross vertical projection of the grandstand measured above the average level of the adjoining ground.

4-2.5.4.3 Uplift wind pressures equal in magnitude to those shown in ANSI A58.1, *Minimum Design Loads in Buildings and Other Structures*, shall be assumed to be acting vertically on the gross horizontal projection of "closed deck" grandstands, the understructure of which is unenclosed. Uplift wind pressures equal to 60 percent of these values shall be assumed to be acting vertically on the gross horizontal projection of "closed deck" grandstands, the understructure of which is enclosed at the perimeter with solid walls.

4-2.5.4.4 Uplift wind pressures equal to $1\frac{1}{4}$ times those shown in ANSI A58.1, *Minimum Design Loads in Buildings and Other Structures*, shall be assumed to be acting normal to an unenclosed roof situated over a grandstand.

4-2.5.5 Railings or guards of grandstands shall be capable of sustaining a vertical or horizontal load of 50 lb per ft (75 kg per m). Loads need not be applied simultaneously.

4-2.5.6 Each of the horizontal forces in 4-2.5.3 and 4-2.5.5 need not be applied simultaneously with other lateral forces such as wind or seismic loads.

4-2.6 Members in which the stresses are greater under a partial loading of the grandstand than under full load shall be designed to meet the conditions causing the largest stress.

4-2.7 Stresses permitted in the design standards of the various materials may be increased by $33\frac{1}{3}$ percent due to sway or wind loads or by a combination of sway or wind

loads and vertical loads, provided that no such increases shall be allowed for stresses due to vertical loads acting alone.

4-2.8 Foundations for permanent grandstands shall be designed to sustain a total load equal to the dead load plus 60 percent of the total of the live load and the transmitted wind or sway load.

4-3 Aisles.

4-3.1 Aisles shall be provided so that the number of seats between any seat and the nearest aisle shall not exceed the number shown in Table 4-3.1.

Exception: Aisles are not required if all the following are met:

- (a) Egress from front row not obstructed by rail, guard, or other obstruction.
- (b) Row spacing less than 28 in. (71.1 cm).
- (c) Rise per row, including first row, 6 in. (15.2 cm) or less.
- (d) Number of rows does not exceed 16.
- (e) Seat spaces are not physically defined.
- (f) Seat boards that are also used as stepping surfaces for descent shall have a minimum width of 12 in. (30.5 cm) and, where there is a depressed footboard, the gap between seat boards of adjacent rows shall not exceed 12 in. (30.5 cm) measured horizontally. All surfaces of bleachers used for stepping shall be uniformly slip resistant and shall comply with 4-3.4.2(g) regarding tread marking.

Table 4-3.1
Number of Seats to Aisle

| Application | Outdoors | Indoors |
|---------------------------|----------|---------|
| Grandstands | 11 | 6 |
| Bleachers (see Exception) | 20 | 9 |

4-3.2 Aisles, including required stairways and ramps, shall not be less than 44 in. (112 cm). New aisle stairs shall not be less than 48 in. (122 cm).

Exception No. 1: Aisle stairs serving not more than 60 seats may be 22 in. (55.9 cm) in clear width.

Exception No. 2: Where an aisle is divided by a portal, column, handrail, or other obstruction, each part shall be not less than 22 in. (55.9 cm) clear width.

4-3.3 Where the entrance to an aisle is elevated above ground level, such aisle shall be provided with a stairway or ramp, whose width is not less than the width of the aisle, or shall be served by a cross aisle.

4-3.4 New Aisle Stairs and Ramps.

4-3.4.1 Every aisle with a gradient 1 in 8 or less shall consist of a ramp.

Exception: Folding and telescoping seating in accordance with Chapter 5.

4-3.4.2 Every aisle with a gradient exceeding 1 in 8 shall consist of a stair having treads, risers, and handrails complying with the following requirements:

- (a)* Tread depths shall be uniform in each aisle.

Exception: Nonuniformities or tolerances shall not exceed $\frac{3}{16}$ in. (0.5 cm) in adjacent treads.

- (b)* Treads shall be a minimum of 11 in. (27.9 cm).

- (c) Riser height shall be a minimum of 4 in. (10.2 cm).

Exception: Folding and telescoping seating in accordance with Chapter 5. Subpart (g) below shall be followed, without use of its exception, with respect to the need for contrasting marking striping.

- (d) Riser height shall not exceed 8 in. (20.3 cm).

Exception No. 1: Where the gradient of an aisle exceeds 8 in. (20.3 cm) in rise in 11 in. (27.9 cm) of run (to maintain necessary sight lines in the adjoining seating area) the riser height may exceed 8 in. (20.3 cm) but not exceed 9 in. (22.9 cm) for new construction or 11 in. (27.9 cm) for existing structures.

Exception No. 2: Folding or telescopic seating in accordance with Chapter 5.

- (e) Riser height shall be uniform within a flight.

Exception No. 1: Riser height may be nonuniform but only to the extent necessary by changes in gradient within a seating area to maintain necessary sight lines. Where nonuniformities exceed $\frac{3}{16}$ in. (0.5 cm) between adjacent risers the exact location of such nonuniformities shall be indicated with a distinctive marking stripe on each tread at the nosing or leading edge adjacent to the nonuniform risers.

Exception No. 2: Nonuniformity or tolerances shall not exceed $\frac{3}{16}$ in. (0.5 cm) in adjacent risers.

(f)* Aisle stairs shall be provided with handrails at one side or along the centerline complying with NFPA 101, *Life Safety Code*; however, such handrails shall be discontinuous at not more than every five rows where they are provided along the centerline of such aisles. Handrail height shall be not less than 34 in. (86.4 cm) nor more than 38 in. (96.5 cm) above the nosing of the tread. The gaps between adjacent sections of such discontinuous handrails shall not be less than 22 in. (55.9 cm) and not more than 36 in. (91.4 cm) measured horizontally.

(g)* A contrasting marking stripe shall be provided on each tread at the nosing or leading edge such that the location of such tread is readily apparent, particularly when viewed in descent. Such stripe shall be at least 1 in. (2.5 cm) wide and not exceed 2 in. (5.1 cm) wide.

Exception: The marking stripe may be omitted where tread surfaces and environmental conditions in all conditions of use are such that the location of each tread is readily apparent, particularly when viewed in descent.

4-3.5 Existing Aisle Stairs. Steps shall not be placed in aisles to overcome difference in level unless the gradient shall exceed 1 ft (0.3 m) in 10 ft (3 m) of run. When the rise of seating platform exceeds 11 in. (27.9 cm) an intermediate step shall be provided the full width of the aisles and so proportioned as to provide two steps of equal rise per platform. When the rise of the seating platform exceeds 18 in. (45.7 cm), two intermediate steps the full width of the aisles shall be provided and so proportioned as to provide three steps of equal rise per platform. The resulting treads shall be uniform and in no case less than

9 in. (22.9 cm). The full length of the nose of each step in the aisle shall be conspicuously marked.

4-4 Travel Distance.

4-4.1 The travel distance along the normal path of travel from any seat to an egress vomitory portal or the egress concourse shall not exceed 150 ft (45.7 m).

Exception: The travel distance may be increased to 200 ft (61 m) in buildings completely protected by automatic sprinklers installed in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems.

4-4.2 The travel distance from the vomitory portal, or entrance to the concourse, to the exterior of the building or entrance to the stairway or ramp shall not exceed 150 ft (45.7 m) (see A-2-2, *Exit*).

4-5 Seating.

4-5.1 The horizontal distance back-to-back of seats shall be not less than 30 in. (76.2 cm) for seats having backrests or not less than 22 in. (55.9 cm) for bleachers. There shall be a space of not less than 12 in. (30.5 cm) between the back of each seat and the front of the seat immediately behind it. Where the same level is used for both seats and footrests these levels shall be not less than 24 in. (61 cm) in width. All measurements shall be taken between plumb lines.

4-5.2 The depth of footboards and seatboards in grandstands shall be not less than 9 in. (22.9 cm). Where the same level is not used for both seat foundations and footrests, footrests independent of seats shall be provided.

4-5.3 Seats and footrests of grandstands shall be securely supported and fastened in such a manner that they cannot be inadvertently displaced.

4-5.4 Individual seats or chairs shall be permitted only if firmly secured in rows in an approved manner.

Exception: Seats, if not more than 16 in number, on level floors, and within railed-in enclosures, such as boxes, need not be fastened.

4-6 Railings or Guards.

4-6.1 Railings or guards not less than 42 in. (107 cm) high above the aisle surface or footrest or 42 in. (107 cm) vertically above the center of the seat board surface, whichever is adjacent, shall be provided along those portions of the backs and ends of all grandstands where the seats are more than 4 ft (1.2 m) above the ground.

Exception: When grandstands are used adjacent to a wall or fence, railings or guards may be omitted from those portions where such wall or fence affords equivalent safeguard.

4-6.2 Where the front footrest of any grandstand is more than 2 ft (0.6 m) above the ground, railings or guards not less than 26 in. (66 cm) high above such front footrests shall be provided.

4-6.3 Cross aisles located at the front of the grandstand shall be provided with a rail not less than 36 in. (91 cm) high.

Exception: Railings at the foot of aisles where steps occur shall not be less than 42 in. (107 cm) high for the width of the aisle.

4-6.4 Cross aisles other than those located at the front of the grandstand shall be provided with a rail not less than 26 in. (66 cm) high.

Exception: Where the backs of the seats in front of the cross aisle project 24 in. (61 cm) or more above the surface of the cross aisle, the rail may be omitted.

4-6.5 Openings between the top railing or guard and the walkway surface below shall not permit the passage of a sphere larger than 9 in. (22.9 cm) in diameter.

4-7 Special Requirements — Wood Grandstands.

4-7.1 No outdoor wood grandstand shall be erected within less than two-thirds of its height but in no case less than 10 ft (3 m) of a building, unless the separation from such building is of not less than 1-hr fire resistance and any openings in the separation are protected against the fire exposure hazard created by the grandstand, or unless a protection of not less than 1-hr fire resistance is interposed between such grandstand and building.

4-7.2* No outdoor wood grandstand unit shall exceed 10,000 sq ft (929 sq m) in ground area or 200 ft (61 m) in length. Grandstand units of the maximum size shall be placed not less than 20 ft (6.1 m) apart or shall be separated by walls of 1-hr fire resistance. Not more than three such units shall be erected in any one group. Each such group shall be separated from any other group by a wall of 2-hr fire resistance rated construction extending 2 ft (0.6 m) above the seat platforms or by an open space not less than 50 ft (15.2 m).

Exception: When entirely constructed of listed and labeled fire retardant treated wood that has passed the standard rain test, ASTM D 2898, Test Method for Accelerated Weathering of Fire-Retardant-Treated Wood for Fire Testing, or of members conforming to dimensions for heavy timber construction [Type IV (2HH)], the allowable ground area or length may be doubled.

4-7.3 The highest level of seat platforms of any wood grandstand shall be not more than 20 ft (6.1 m), and of portable grandstands within tents or membrane structures not more than 12 ft (3.7 m), above the ground or the surface at the front of the grandstand.

4-8 Special Requirements — Portable Grandstands.

4-8.1 Portable grandstands shall conform to the requirements of Chapter 4, for grandstands, and the following special requirements.

4-8.2 Portable grandstands shall be self-contained, having within all necessary parts to withstand and restrain all forces that might be developed during human occupancy. They shall be so designed and manufactured that if any structural members essential to the strength and stability of the structure have been omitted during erection, the presence of unused connection fittings shall make the omissions self-evident. The workmanship shall be of such quality as to produce in construction the strength required by the design.

4-8.3 Portable grandstands shall be provided with base plates, sills, floor runners, or sleepers of such area that the total live and dead load exerted under any of these shall not exceed 55 lb per sq in. (3.9 kg per sq cm). When portable grandstands rest directly on a base of such character as to be incapable of supporting the load without appreciable settlement, mud sills of suitable material, having sufficient area to prevent undue or dangerous settlement, shall be installed under base plates, runners, or sleepers. All bearing surfaces shall be in contact.

4-8.4 A-frames or other supports, and seat stringers for portable grandstands shall be secured to prevent accidental displacement during occupancy.

4-8.5 Field connections to wood members shall be by means of rivets, bolts, approved connectors, friction or other devices, or lag screws. The use of nails, lag screws, and wood screws is permissible for holding wood parts together, except that these shall not be used for demountable joinings, nor shall these be used where their loosening or splitting of surrounding wood would jeopardize the structure or its occupants. Members in tension shall be connected at each end by means of not less than two bolts, rivets, or lag screws or by approved connectors or other approved devices. All iron or steel fastenings and fastening devices shall be hot-dipped galvanized. (See *ASTM A 153 reference in Chapter 11.*) Adequate provision shall be made to prevent the splitting or shearing of wood at such connections.

4-8.6 Portable grandstands shall not be used for public occupancy unless all parts have been erected, or re-erected, in accordance with the approved design and specifications. Members comprising the seating, walkways, railings, bracing, and supporting members shall be structurally sound.

4-9 Spaces Underneath Grandstands. Spaces underneath a grandstand or bleacher shall be kept free of flammable or combustible materials.

Exception No. 1: Accessory uses such as ticket booths, toilet facilities, or concession booths, may be permitted in such spaces when of noncombustible or fire-resistive construction.

Exception No. 2: Small food serving or processing stands, such as a concession booth, that are protected by an automatic fire suppression system or of 1-hr fire resistance-rated construction.

Exception No. 3: Assembly occupancies that are protected throughout by an approved automatic sprinkler system and that are of 1-hr fire resistance-rated construction.

4-10 Maintenance. The owner shall provide for not less than annual inspection and required maintenance of each grandstand to assure safe conditions. At least biennially the inspection shall be performed by a professional engineer or registered architect. The authority having jurisdiction may require certification that such inspection has been performed.

Chapter 5 Folding and Telescopic Seating

5-1 Application. Folding and telescopic seating shall be permitted only if the supporting structure is of adequate strength and there are adequate exit facilities to accommodate the occupants of the seating as well as all other occupants.

5-2 Design.

5-2.1 The design of folding and telescopic seating shall be in accordance with accepted structural engineering practice.

5-2.2 Load tests in accordance with accepted engineering practice may be made in lieu of the design analysis for a seating unit or part thereof.

5-2.3 Where required by the authority having jurisdiction, the manufacturer shall submit either calculations verifying the design analysis prepared by a professional engineer or registered architect, or a report of load tests conducted by an approved independent testing laboratory and certified by a professional engineer. The authority having jurisdiction may also require the manufacturer to certify that the equipment supplied is in accordance with the design or is essentially identical to the structure tested.

5-2.4 Design Loads.

5-2.4.1 Folding and telescopic seating shall be designed to support, in addition to its own weight and the weight of added accessories, a uniformly distributed live load of not less than 100 lb per sq ft (488 kg per sq m) of gross horizontal projection.

5-2.4.2 Seatboards and footrests shall be designed for a live load of not less than 120 lb per linear ft (179 kg per linear m).

5-2.4.3 A sway force applied to seats shall be 24 lb per linear ft (36 kg per linear m) parallel to the seats, and 10 lb per linear ft (15 kg per linear m) perpendicular to the seats. Sway forces shall not be considered simultaneously applied.

5-2.4.4 Railings or guards shall be capable of sustaining a vertical or horizontal load of 50 lb per ft (75 kg per m). Loads need not be simultaneously applied.

5-2.4.5 Each of the horizontal forces in 5-2.4.3 and 5-2.4.4 needs not be applied simultaneously with other lateral forces such as wind or seismic loads.

5-2.4.6 Stresses permitted in the design standards of the various materials may be increased $33\frac{1}{3}$ percent due to sway or wind loads or by a combination of sway or wind loads and vertical loads, provided that no such increases shall be allowed for stresses due to vertical loads acting alone.

5-2.5 Structural design shall consider the stresses in all members due to all of the loadings indicated in 5-2.4, with particular attention to the following:

- (a) vertical dead load and live load,
- (b) wind loads,
- (c) sway load parallel with the seats,
- (d) sway load to the front and sway load to the rear,
- (e) wall attachments,
- (f) partial loading conditions,
- (g) for movable, reverse-fold and forward-fold folding and telescopic seating, stability against overturning forward or backward during normal operation, or in any condition of intended use, when operated in accordance with manufacturer's operating instructions.

5-2.6 All design criteria shall be met when the seating is in each configuration intended for occupancy.

5-3 Review and Approvals.

5-3.1 Design and installation drawings shall be approved prior to installation, and seating shall be installed in conformance therewith. This data shall include the following:

- (a) conformance with approved designs; this may be by reference to approved standard drawings with any variables applicable to the job noted;
- (b) location of the folding or telescopic seating units and details of attachments, if any;
- (c) location of guards and details thereof.

5-3.2 The owner, or his duly authorized representative, shall file with the authority having jurisdiction evidence of the following:

- (a) the adequacy of the exits to accommodate the occupants of the seating as well as all other occupants, based on NFPA 101, *Life Safety Code*;
- (b) structural ability of the site to support the folding and telescopic seating dead loads when closed, and also to support the dead loads and live loads when open.

5-4 Aisles. Aisles shall comply with the requirements of Section 4-3.

5-5 Travel Distance. The travel distance to the nearest exit shall be not greater than 150 ft (45.7 m).

Exception: The travel distance may be increased to 200 ft (61 m) in buildings completely protected by automatic sprinklers installed in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems.

5-6 Seating.

5-6.1 The horizontal distance back-to-back of seats shall be not less than 22 in. (55.9 cm) for seats without backs. There shall be a space of not less than 12 in. (30.5 cm) between the back of each seat and the front of each seat immediately behind it. If seats are of the chair type, the 12 in. (30.5 cm) dimension shall be measured to the front edge of the rear seat in its normal unoccupied position. All measurements shall be taken between plumb lines.

5-6.2 The depth of footboards (footrests) and seatboards in folding and telescopic seating shall be not less

than 9 in. (22.9 cm). Where the same level is not used for both seat foundations and footrests, footrests independent of seats shall be provided.

5-6.3 Individual chair-type seats shall be permitted in folding and telescopic seating only if firmly secured in groups of not less than three.

5-7 Guards and Rails.

5-7.1 Railings or guards not less than 42 in. (107 cm) high above the aisle surface or footrest or 36 in. (91 cm) vertically above the center of the seat or seatboard surface, whichever is adjacent, shall be provided along those portions of the backs and ends of all folding and telescopic seating where the seats are more than 4 ft (1.2 m) above the floor.

Exception: When folding or telescopic seating is used adjacent to a wall or fence within 6 in. (15.2 cm) of the seating and of sufficient height to afford the intended protection, guards may be omitted.

5-7.2 Where the front footrest of any folding or telescopic seating is more than 2 ft (0.6 m) above the floor, railings or guards not less than 33 in. (84 cm) high above such footrests shall be provided.

Exception: Where the front row of seats includes backrests, the rails shall be not less than 26 in. (66 cm) high.

5-7.3 Rails 42 in. (107 cm) high shall be located at the foot of each aisle that extends to the front of such folding or telescopic seating and along the front of any cross aisle located at the front of the seating.

5-7.4 Cross aisles located within the seating area shall be provided with rails not less than 26 in. (66 cm) high along the front edge of the aisle.

Exception: Where the backs of the seats in front of the cross aisle project 24 in. (61 cm) or more above the surface of the cross aisle, this rail may be omitted.

5-7.5 Openings between the top railing or guard and the walkway surface below shall not permit the passage of a sphere larger than 9 in. (22.9 cm) in diameter.

5-8 Maintenance and Operation.

5-8.1 Instructions in both operation and maintenance shall be transmitted to the owner by the manufacturer of the seating or his representative.

5-8.2 Maintenance and operation of folding and telescopic seating shall be the responsibility of the owner or his duly authorized representative, and shall include the following:

(a) During operation of the folding and telescopic seats, the opening and closing shall be supervised by responsible personnel who will assure that the operation is in accordance with the manufacturer's instructions.

(b) Only attachments specifically approved by the manufacturer for the specific installation shall be attached to the seating.

(c) An annual inspection and required maintenance of each grandstand shall be performed to assure safe conditions. At least biennially the inspection shall be performed by a professional engineer or qualified service personnel.

Chapter 6 Permanent Membrane Structures

6-1 General.

6-1.1 Membrane structures designed to meet the applicable requirements of NFPA 101, *Life Safety Code*, this chapter, and the building codes may be constructed as permanent buildings or parts thereof.

6-1.2 Membrane structures may be used for any occupancy as defined in NFPA 101, *Life Safety Code*, subject to all of the requirements contained therein, and as permitted by the applicable building code.

6-1.3 Heights and areas shall be limited by the requirements of applicable building codes based on the type of construction and occupancy classification.

6-1.4 Testing of membrane materials for compliance with this section's use of the categories of noncombustible and limited-combustible materials and flame spread ratings shall be performed on weathered membrane material as defined in Section 2-2.

6-1.5 Membrane materials shall not be used where fire resistance ratings are required for walls or roofs.

Exception: Where every part of the roof, including the roof membrane, is not less than 20 ft (6.1 m) above any floor, balcony, or gallery, a noncombustible or limited-combustible membrane may be used as the roof in any type of construction.

6-1.6 Flame spread rating of all materials, including membrane, exposed within the structure shall be as required by NFPA 101, *Life Safety Code*.

6-1.7 Roof membranes shall have a roof covering classification as required by the applicable building codes, when tested in accordance with NFPA 256, *Standard Methods of Fire Tests of Roof Coverings*.

6-1.8 Flame Resistance. All membrane structure fabric shall meet the requirements of the small-scale test contained in NFPA 701, *Standard Methods of Fire Tests for Flame-Resistant Textiles and Films*, as listed below:

| | |
|--------------------------------|------------|
| Afterflame (max.) seconds | 2.0 |
| Char Length (avg.) inches (cm) | 3.5 (8.9) |
| Char Length (max.) inches (cm) | 4.5 (11.4) |
| Melt Drip Flame Time | |
| Measured at Floor of Test | |
| Chamber (max.) seconds | 0 |

The material shall also pass the large-scale test contained therein.

The authority having jurisdiction shall require a certificate or other evidence of acceptance by an organization acceptable to the authority having jurisdiction, or may accept the report of tests made by other inspection authorities or organizations acceptable to the authority having jurisdiction as evidence that the fabric materials have the required flame resistance.

The authority having jurisdiction may also require confirmatory field tests using test specimens from the original material, which shall have been affixed at the time of manufacture to the exterior of the structure.

6-2 Tensioned-Membrane Structures.

6-2.1 Design. The design, materials, and construction of the building shall be based upon plans and specifications prepared by a licensed architect or engineer knowledgeable in this type of construction.

6-2.2 Material loading and strength shall be based upon physical properties of the materials verified and certified by an approved testing laboratory.

6-2.3 The membrane roof for structures in climates subject to freezing temperatures and ice buildup shall be composed of two layers with an air space between them through which heated air can be moved to guard against ice accumulation. In lieu of the above, any other approved methods that will protect against ice accumulation may be used.

6-2.4 Roof drains shall be equipped with electrical elements to protect against ice buildup, which would prevent the drains from functioning. Such heating elements shall be served by on-site standby electrical power in addition to the normal public service. In lieu of the above, any other approved methods that will protect against ice accumulation may be used.

6-3 Air-Supported, Air-Inflated Structures.

6-3.1 General. In addition to the foregoing, the requirements of this section shall apply to air-supported structures.

6-3.2 Structural Requirements.

6-3.2.1 Envelope Design. The design, materials, and construction for the structural envelope shall conform to the requirements of this section. Membrane structures shall be designed by a licensed architect or engineer knowledgeable in this type of construction.

6-3.2.2 Material Strength. Calculation of fabric stresses shall include consideration of inflation pressure, the radius of the structure, and wind, ice, snow, and earthquake loads. The minimum design criteria for material strength shall comply with the requirements of ASI 77, *Air Structures Design and Standards Manual*. Minimum design criteria shall be for 80 mph (129 km per hr) wind conditions. More severe design loads, as specified in local building codes, may be required as a result of local climatic conditions. All material characteristics shall be verified by an approved test method. Material strengths

shall be certified by the manufacturer and verified by test data from an organization acceptable to the authority having jurisdiction.

6-3.2.3 Joint Strength. All seams shall develop the full strength of the envelope material as specified in ASI 77, *Air Structures Design and Standards Manual*.

6-3.3 Load Distribution.

6-3.3.1 The envelope shall be patterned and constructed to minimize stress concentrations in crown areas, around openings, and where rigid components such as door frames, vent pipes, and structural members are attached to the envelope.

6-3.3.2 There shall be sufficient clearance between the envelope and rigid components to permit free movement under load.

6-3.3.3 Reinforced areas, such as around openings, shall provide a flexible but airtight seal.

6-3.4 Pressurization (Inflation) System.

6-3.4.1 The operating inflation pressure for the structure shall be adequate to withstand a wind velocity of 80 mph (129 km per hr). Local climatic conditions, as determined by local authorities, may require pressurization for higher wind conditions.

6-3.4.2 The pressurization system shall consist of one or more operating blower units. The system shall include automatic control of auxiliary blower unit(s) to reliably maintain the required operating pressure. This equipment shall meet the following requirements:

(a) Blowers shall be powered by continuous-rated motors at the maximum power required.

(b) Blowers shall have adequate personnel protection, such as inlet screens and belt guards.

(c) Blower systems shall be weather protected.

(d) Blower systems shall be equipped with back-draft check dampers.

(e) There shall be not fewer than two blower units, each of which has adequate capacity to maintain full inflation pressure with normal leakage.

(f) The blowers shall be designed to be incapable of overpressurization.

(g) The auxiliary blower unit(s) shall operate automatically if there is any loss of internal pressure or if an operating blower unit becomes inoperative.

(h) The design inflation pressure and the capacity of each blower system shall be certified by a professional engineer.

6-3.5 Emergency Power System.

6-3.5.1 Design.

6-3.5.1.1 A fully automatic emergency power system shall be provided. This shall be either an auxiliary engine generator set capable of running the blower system, or a supplementary blower unit that is sized for 1½ times the normal operating capacity and is powered by an internal combustion engine.

6-3.5.1.2 The emergency power system shall be fully automatic to assure continuous inflation in the event of any failure of the primary power. This system shall start automatically within 30 seconds of a power failure and shall be capable of operating continuously for a minimum period of 8 hours.

6-3.5.2 Certification. The sizing and capacity of the emergency power system shall be certified by a professional engineer.

6-3.6 Anchorage Design.

6-3.6.1 Basic Requirements. A positive anchorage system shall be provided to securely anchor the envelope to the ground or to the structure.

6-3.6.2* Specific Requirements. Anchor loading varies with the size, height, and anchor spacing for the structure, and this shall be determined and verified by analytical data prepared by a professional engineer. The minimum requirements for anchorage designs shall be in accordance with the requirements of ASI 77, *Air Structures Design and Standards Manual*.

6-3.7 Means of Egress.

6-3.7.1 The means of egress shall conform to Chapter 3.

6-3.7.2 Other specific requirements for means of egress shall be as follows:

- (a) All door openings shall be reinforced and balanced to evenly distribute structural loads around openings.
- (b) All door frames or housings shall be structurally anchored at the base.
- (c) All doors shall automatically close against normal operating pressures.
- (d) Opening force at the door edge shall not exceed 15 lbf (67 N) with the structure inflated to its operating inflation pressure.

6-3.8 Accessory Equipment. The design and use of accessory equipment for heating, air conditioning, lighting, and similar functions shall conform to the requirements of Chapter 10 and to approved recognized standards.

Chapter 7 Temporary Membrane Structures

7-1 General.

7-1.1 Membrane structures designed to meet all the requirements of this chapter may be constructed as temporary buildings subject to the approval of the authority having jurisdiction.

7-1.2 Temporary membrane structures shall comply with all the requirements for:

- (a) Chapter 6, "Permanent Membrane Structures," except 6-1.1, 6-1.4, 6-1.5, and 6-1.6.
- (b) Chapter 9, "Protection."

7-1.3 Temporary tensioned-membrane structures may comply with Chapter 8, "Tents," instead of this chapter.

7-2 Safety.

7-2.1 Operating Pressure. Operating pressure shall be maintained at the design pressure.

7-2.2 Clearance. There shall be a minimum clearance of 3 ft (0.9 m) between the membrane and the contents or equipment within the building and between the membrane and any exterior object.

Chapter 8 Tents

8-1 General. Tents shall be permitted only on a temporary basis.

8-2 Size Limitations. Tents shall be erected to cover not more than 75 percent of the premises, unless otherwise approved by the authority having jurisdiction.

8-3 Structural Requirements.

8-3.1 All supporting members shall be of sufficient size and strength to support the structure.

8-3.2 The poles and their supporting guys, stays, stakes, and fastenings shall be of sufficient strength and attached so as to resist a minimum wind pressure of 20 lbf per sq ft (0.96 kPa) of projected area of the tent.

8-3.3 Tents shall be adequately guyed, supported, and braced to withstand a minimum pressure or suction of 10 lbf per sq ft (0.48 kPa).

8-3.4 Pull-down ropes (jump ropes) shall be provided on all poles.

8-4 Flame Resistance.

8-4.1 All tent fabric shall meet the requirements of the small-scale test contained in NFPA 701, *Standard Methods of Fire Tests for Flame-Resistant Textiles and Films*.

Exception: The authority having jurisdiction may require the tent fabric to meet the requirements of the large-scale test contained in NFPA 701, Standard Methods of Fire Tests for Flame-Resistant Textiles and Films.

8-4.2 The authority having jurisdiction shall require a certificate or other evidence of approval by a laboratory of recognized standing, or he may accept the report of tests made by other inspection authorities as evidence that the tent fabric materials have the required flame resistance.

8-4.3 The authority having jurisdiction may also require confirmatory field tests using test specimens from the original material affixed at the time of manufacture

to the exterior of the tent. The test specimen shall consist of a full width of material that has been cut into test strips 1½ in. by 4 in. (3.8 cm by 10.2 cm).

8-5 Location and Means of Egress.

8-5.1 Location and Spacing.

8-5.1.1 There shall be a minimum of 10 ft (3 m) between stake lines.

8-5.1.2 Adjacent tents shall be sufficiently distant from each other to provide an area to be used as a means of emergency egress. Where 10 ft (3 m) between stake lines is not sufficient for means of egress, the distance necessary for means of egress shall govern.

Exception No. 1: Tents not occupied by the public and not used for the storage of combustible material may be erected less than 10 ft (3 m) from other structures only if the authority having jurisdiction deems such close spacing safe from hazard to the public.

Exception No. 2: Tents, each not exceeding 1200 sq ft (111.5 sq m) in ground area, located in fair grounds or similar open spaces, need not be separated from each other, provided safety precautions meet the approval of the authority having jurisdiction.

8-5.1.3 The placement of tents relative to other structures shall be at the discretion of the authority having jurisdiction with consideration being given to occupancy, use, opening, exposure, and other similar factors.

8-5.2 Means of Egress.

8-5.2.1 Seating shall conform to the requirements of Chapter 8 of NFPA 101, *Life Safety Code*.

Exception: Grandstand seating shall comply with Chapter 4 of this standard.

8-5.2.2 Aisles serving areas other than seating shall be not less than 5 ft (1.5 m) wide and the number of such aisles shall be at the discretion of the authority having jurisdiction.

Chapter 9 Protection

9-1 Flammable Liquids and Gases.

9-1.1 Storage and handling of flammable liquids or gases shall be in accordance with the applicable standards below:

(a) NFPA 30, *Flammable and Combustible Liquids Code*;

(b) NFPA 54, *National Fuel Gas Code*;

(c) NFPA 58, *Standard for the Storage and Handling of Liquefied Petroleum Gases*.

9-1.2 No storage or handling of flammable liquids or gases shall be permitted at any location at which it would jeopardize egress from the structure.

9-1.3 Refueling of equipment with liquids with flash points below 100°F (38°C) shall not be permitted within the structure.

9-2 Fire Hazard.

9-2.1 The applicable provisions of NFPA 101, *Life Safety Code*, that pertain to fire hazards shall govern in tents and membrane structures.

9-2.2 The ground enclosed by any tent or temporary membrane structure and for a reasonable distance, but not less than 10 ft (3 m) outside of such structure or structures, shall be cleared of all flammable or combustible material or vegetation. This work shall be accomplished to the satisfaction of the authority having jurisdiction prior to the erection of such structure or structures. The premises shall be kept free from such flammable or combustible materials during the period for which the premises are used by the public.

Exception: Necessary support equipment.

9-2.3 No hay, straw, shavings, or similar combustible materials that have not been treated to make them flame retardant to a degree acceptable to the authority having jurisdiction shall be permitted within any structure used as an assembly occupancy.

Exception: Animal bedding and fodders in quantities approved by the authority having jurisdiction.

9-2.4 Where prohibited by the authority having jurisdiction, smoking shall not be allowed in any tent or temporary membrane structure.

9-2.5 Fireworks or unauthorized open flames shall be prohibited in any tent or temporary membrane structure.

9-3* Fire Extinguishing Equipment.

9-3.1 Structures using the provisions of 3-1.2 shall be protected throughout by an approved supervised automatic sprinkler system in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*.

Exception No. 1: When the ceiling or roof, whichever is lower, of the playing (activity) area is more than 55 ft (17 m) above the floor the authority having jurisdiction may permit the omission of sprinklers above the playing (activity) area.

Exception No. 2: Sprinklers may be omitted above seating areas that view the playing (activity) area.

9-3.2 Facilities such as press boxes, restaurants, club houses, and enclosed boxes and the like within stadia, arenas, and similar structures shall be protected throughout by an approved automatic sprinkler system.

Exception: Press boxes in stadia or arenas with seating capacity less than 5000 persons.

9-3.3 In permanent stadia, arenas, and similar structures, all enclosed areas such as offices, dressing rooms, concession storage areas, food preparation, and similar areas as are conventionally found in stadia and sports arenas shall be protected by an approved automatic sprinkler system.

9-3.4 Fire extinguishing equipment of approved types shall be furnished and maintained in tents and temporary membrane structures by the person operating any assembly occupancy in such amount and in such locations

as may be directed by the authority having jurisdiction.
Exception: Extinguishers may be omitted from private party tents when a functioning garden hose that can reach all portions of the tent is provided.

9-3.5 Fire extinguishing equipment shall be maintained in accordance with NFPA 10, *Standard for Portable Fire Extinguishers*.

9-3.6 Employees of places of assembly shall be trained to operate fire extinguishing equipment and shall be required to exhibit their skill when requested by the authority having jurisdiction.

9-4 Emergency Communications. One or more methods of fire alarm and emergency communications shall be provided to the satisfaction of the authority having jurisdiction.

9-5* Fire Detail. Fire details, if deemed necessary in any assembly occupancy, shall be determined by the authority having jurisdiction.

Chapter 10 Services

10-1 Electrical Installations.

10-1.1 Electrical installations shall conform to the requirements of NFPA 70, *National Electrical Code*®.

Exception: As otherwise provided by law, ordinance, or regulation.

10-1.2 The electrical system shall be installed, maintained, and operated in a safe and workmanlike manner. If portable, it shall be inspected daily when in use by a qualified person representing the owner and any defects found shall be corrected before the public is admitted.

10-1.3 The electrical system and equipment shall be isolated from the public by proper elevation or guarding, and all electrical fuses and switches shall be enclosed in approved enclosures. Cables on the ground in areas traversed by the public shall be placed in trenches or protected by approved covers.

10-2 Heating Devices.

10-2.1 Fired Heaters.

10-2.1.1 Only listed and labeled heating devices shall be used.

10-2.1.2 Fired heaters and their installation shall be approved by the authority having jurisdiction.

10-2.1.3 Ducts used to convey heated air shall comply with NFPA 90A, *Standard for the Installation of Air Conditioning and Ventilating Systems*.

10-2.1.4 Containers for liquefied petroleum gases shall be installed not less than 5 ft (1.5 m) from any tent or temporary membrane structure and in accordance with

the provisions of NFPA 58, *Standard for the Storage and Handling of Liquefied Petroleum Gases*.

10-2.1.5 Tanks shall be secured in the upright position and protected from vehicular traffic.

10-2.1.6 Heating devices shall comply with the requirements of the following standards:

(a) NFPA 31, *Standard for the Installation of Oil Burning Equipment*;

(b) NFPA 54, *National Fuel Gas Code* (see Chapter 11);

(c) NFPA 211, *Standard for Chimneys, Fireplaces, Vents and Solid Fuel Burning Appliances*.

10-2.2 Electric Heaters.

10-2.2.1 Only listed and labeled heaters shall be used.

10-2.2.2 Heaters may be used inside a tent or temporary membrane structure when approved by the authority having jurisdiction.

10-2.2.3 Heaters must be connected to electricity by electric cable suitable for outside use, and of sufficient size to handle electric load.

Chapter 11 Referenced Publications

11-1 The following documents or portions thereof are referenced within this standard and shall be considered part of the requirements of this document. The edition indicated for each reference is current as of the NFPA issuance of this document. These references are listed separately to facilitate updating to the latest edition by the user.

11-1.1 NFPA Publications. National Fire Protection Association, Batterymarch Park, Quincy, MA 02269..

NFPA 10-1984, *Standard for Portable Fire Extinguishers*

NFPA 13-1985, *Standard for the Installation of Sprinkler Systems*

NFPA 30-1984, *Flammable and Combustible Liquids Code*

NFPA 31-1983, *Standard for the Installation of Oil Burning Equipment*

NFPA 54-1984, *National Fuel Gas Code*

NFPA 58-1983, *Standard for the Storage and Handling of Liquefied Petroleum Gases*

NFPA 70-1987, *National Electrical Code*

NFPA 90A-1985, *Standard for the Installation of Air Conditioning and Ventilating Systems*

NFPA 101-1985, *Life Safety Code*

NFPA 204M-1985, *Guide for Smoke and Heat Venting*

NFPA 211-1984, *Standard for Chimneys, Fireplaces, Vents and Solid Fuel Burning Appliances*

NFPA 220-1985, *Standard on Types of Building Construction*

NFPA 251-1985, *Standard Methods of Fire Tests of Building Construction and Materials*

NFPA 256-1982, *Standard Methods of Fire Tests of Roof Coverings*

NFPA 259-1982, *Standard Test Method for Potential Heat of Building Materials*

NFPA 701-1977, *Standard Methods of Fire Tests for Flame-Resistant Textiles and Films*.

11-1.2 ASTM Publications. American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103.

ASTM A 153-1982, *Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware*

ASTM D 2898-1981, *Test Method for Accelerated Weathering of Fire-Retardant-Treated Wood for Fire Testing*

ASTM E 136-1982, *Test Method for Behavior of Materials in a Vertical Tube Furnace at 750°C*

ASTM G 26-1983, *Practice for Operating Light/Exposure Apparatus (Zenon-Arc Type) With and Without Water for Exposure of Non-Metallic Materials*.

11-1.3 Other Publications.

ASI 77-1977, *Air Structures Design and Standards Manual*, Architectural Fabric Structures Institute, 1800 Pickwick Ave., Glenview, IL 60025-1377

ANSI A 58.1-1982, *Minimum Design Loads in Buildings and Other Structures*, American National Standards Institute, 1430 Broadway, New York, NY 10018.

Appendix A

This Appendix is not a part of the requirements of this NFPA document, but is included for information purposes only.

A-1-1 The provisions of this standard are intended to be applicable to facilities and structures where a number of persons may stand or sit for the viewing of a contest, exhibition, performance, or for entertainment, and other facilities and structures used for other occupancies as permitted by the applicable building code.

The management of crowds outside of bleachers, grandstands, tents, or membrane structures while approaching or departing from events is beyond the scope of this standard, but the following principles should be considered in the overall planning.

Routes of departure should lead to a street or public way of sufficient capacity to allow continued movement of persons leaving the facility. Parking areas can absorb much of this crowd but structures and garages should not be considered refuge areas unless designed for this purpose. At least one street should be kept clear at all times to permit access of emergency equipment. In addition, adjacent automobile parking lots, open fields, public parks, etc., may also be used as places of refuge. Where

such space is needed for this purpose, the continued use of the facility should be contingent on free access to the space during the periods when crowds may assemble.

Large stadium complexes, which are designed for major uses in addition to spectator viewing, are beyond the scope of this standard.

A-2-2 Air-Supported Structure. A cable-restrained air-supported structure is one in which the uplift is resisted by cables or webbing that are anchored by various methods to the membrane or that may be an integral part of the membrane. This is not a tensioned-membrane structure.

A-2-2 Assembly Occupancy. For the purposes of this standard, assembly occupancies include, among others, structures for such occupancies as the following, and all similar types of places, together with such premises, buildings, appurtenances, and establishments as are necessary to the operation of such assembly occupancies:

| | |
|------------------------|---------------------------|
| Amusement parks | Athletic fields or bowls |
| Arenas | Automobile speedways |
| Aviation shows | Reviewing stands |
| Bandstands | Rodeos |
| Baseball parks | Skating rinks |
| Bathing establishments | Stadiums |
| Beach enclosures | Swimming pools |
| Bleachers | Enclosures for circuses, |
| Concession booths | exhibits, carnivals, |
| Grandstands | religious, educational, |
| Observation platforms | or recreational purposes, |
| Racetracks | public meetings, etc. |

A-2-2 Exit. In structures where all parts of the means of egress are essentially open to the exterior and, therefore, are not likely to be significantly affected by combustion products from a fire in the structure, an exit in functional terms is that portion of the egress system where flows from the largest number of egress routes are combined. Such an exit would include such items as an opening in the ticket control barrier, a major means of vertical circulation to the level of exit discharge, or similar feature where the maximum number of egress flows converge.

A-3-1.2.1 The traditional relaxation of some requirements for means of egress for outdoor grandstands has been extended to very large, fully-enclosed and roofed stadia on the assumption that means of egress are not subject to blockage by smoke and fire. Some intermediate size, fully-enclosed and roofed assembly seating facilities (such as arenas and colosseums) have been constructed with egress provisions intermediate between those of traditional assembly occupancy requirements and those permitted for outdoor grandstands. Use of all or part of any relaxation permitted for smoke-protected assembly seating requires further study in the use of such intermediate size buildings.

A-3-1.5 Reference is made to ANSI A117.1, *Specifications for Making Buildings and Facilities Accessible to, and Usable by, the Physically Handicapped (see Appendix B)*.

A-3-3.2.2 For smoke-protected (outdoor) assembly seating the minimum flow times expected with the capacities listed will be 11 minutes for populations that are largely young adults, able-bodied, and familiar with the facility; other populations could require several additional minutes of flow time to clear any part of the egress system. Although such flow times are beyond the scope of Appendix D of NFPA 101, *Life Safety Code*, that appendix provides general information regarding factors influencing capacity of stairs and may be useful for interpolating between specific capacities listed.

A-3-3.4 Exits from Enclosures. The purpose of this provision is to ensure that persons occupying an assembly occupancy that is enclosed by a fence or wall will have ample egress from the enclosure. Where the enclosure has an easily accessible open space, such as the playing field of a baseball park, or open spaces, such as those found in many amusement parks, where temporary refuge may be obtained until the emergency is over, it is not believed necessary to require the same aggregate width of exits as would be necessary for egress from a building. Movement of persons to the exits from these places of refuge can be slower and more orderly than from a building, and, hence, facilities for rapid discharge of the occupants are less critical. However, where such areas of refuge are not present or are not easily accessible, it is necessary that facilities be provided for an undiminished route of travel from any structure within the enclosure to safe refuge outside.

A-3-6 Travel Distance to Exit. In this section as well as in 4-4 and 5-5 the distance to an exit or to an entrance to an exitway is limited to ensure reasonably prompt evacuation of any area that may be in danger from one cause or another. The structures to which the standard applies vary in design and size due to differences in their capacities and to the topography of the sites. Since the requirements of the two sections mentioned are necessarily expressed in general terms some indication of the committee's intent may be helpful to the authority having jurisdiction.

Sections 4-4 and 5-5 recognize this variation in size, which may range from a simple playground structure with a capacity of perhaps 50 persons to a grandstand accommodating many thousands. Obviously, no hard-and-fast rules can be laid down in the requirements that will fit this range exactly. For the small playground structure the exit from the seating area will be directly to the ground and the same may be true of grandstands accommodating up to perhaps 100,000 persons. From the upper decks of multidecked grandstands, the exit from the seating area may be to a balcony or passage at the rear of the stands that connects with ramps leading to the ground, a travel distance of several hundred feet.

It is not necessary that persons get to the ground or street in a travel distance of 150 ft (45.7 m). What is intended in Sections 4-4 and 5-5 is that persons will be able to get out of any threatened area by traveling not more than 150 ft (45.7 m). The limiting distance therefore may be to the ground, or to openings on a passage from the seating area, leading to a place of refuge, or to openings through the seating deck structure, such as the portals or vomitories.

A-4-3.4.2(a) Completely uniform tread dimensions are preferred over aisle stair designs where tread depths alternate between relatively small intermediate treads between seating platforms and relatively larger treads at seating platforms. A larger tread, level with the seating platform, is not needed to facilitate easy access to and egress from a row of seating.

A-4-3.4.2(b) Tread depth is more important to stair safety than is riser height. Therefore, in cases where seating area gradient is less than 5 in 11, it is recommended that the tread dimension be increased beyond 11 in. (27.9 cm) rather than reducing the riser height. Where seating area gradient exceeds 8 in 11, it is recommended that the riser height be increased while maintaining a tread depth of at least 11 in. (27.9 cm).

A-4-3.4.2(f) Gaps in center-aisle handrails permit crossovers from one side of an aisle stair to the other side and they should be located at intervals of three to five rows. A minimum clear width of 48 in. (122 cm) between seats is recommended for aisle stairs having center-aisle handrails.

Possible justification for not installing handrails on an aisle stair would be that such handrails are used by less than five percent of people using the aisle stair. This low level of handrails use should not be expected to occur on aisle stairs of even very moderate gradient where flight lengths are unusually large, where there are distracting views in descent, or where light conditions are not conducive to tread nosing visibility. Thus, a strong case can be made for handrails in aisle stairs in stadia, arenas, grandstands, and theaters on the grounds that safety, egress efficiency, convenience, and comfort are significantly improved.

A-4-3.4.2(g) Certain tread covering materials such as plush carpets, often used in theaters, produce an inherently well-marked tread nosing under most light conditions. On the other hand, concrete treads (with nosings having a sharp edge), especially under outdoor light conditions, are difficult to discriminate and therefore require an applied marking stripe. Slip resistance of such marking stripes should be similar to the rest of the treads and no tripping hazard should be created.

A-4-7.2 Fire Retardant Treated Lumber. The increases permitted in the sizes of wood grandstands, if of fire retardant treated lumber, are predicated on the use of lumber impregnated by pressure processes with fire retardant preservatives in accordance with NFPA 703, *Standard for Fire Retardant Impregnated Wood and Fire Retardant Coatings for Building Materials*, or the American Wood Preservers Association standards C-20, *Structural Lumber Fire Retardant Treatment by Pressure Processes*, and C-27, *Plywood-Fire Retardant Treatment by Pressure Processes*.

A-6-3.6.2 These loadings are the same as envelope fabric loadings, but must be converted from lb/sq in. (kg/sq cm) to the equivalent load for the anchor spacing used [generally in terms of lb/sq ft (kg/sq m)]. Anchor loadings are based upon 80 mph (129 km per hr) wind

and a design safety factor of 2 should be used to assure secure anchorage under steady load conditions.

A-9-3 Fire Extinguishing Equipment. Recommendations on the distribution, use, and maintenance of portable fire extinguishing equipment are given in NFPA 10, *Standard for Portable Fire Extinguishers*.

The general information in NFPA 10, *Standard for Portable Fire Extinguishers*, defines Class A, B, C, and D fires and contains specific recommendations for the minimum area of distribution for each extinguisher for "light," "ordinary," and "extra hazard" occupancies. An appendix to the standard gives the appropriate ratings of each type and size of extinguisher based upon a standard method of test.

The requirements cited in the standard are, in general, minimum requirements and do not preclude the installation of additional fire extinguishing equipment where desired.

A-9-5 Patrols or Fire Details. Because of the variety of types of places of assembly covered in this standard, no general requirement for patrols or fire watchers has been included. The committee fully recognizes the importance of this feature of fire protection, however, and believes that a system of well-trained patrols or fire watchers should be maintained in every place of assembly where fire hazards may develop. Such locations would include, among others, the spaces underneath grandstands and the areas inside and outside tents and air-supported structures. The fire watchers serve to detect incipient fires and to prevent an accumulation of materials that will carry fire. The number of such watchers required will, of course, vary for the different types of assembly occupancies, depending upon the combustibility of the construction and the number of persons accommodated. Provided with an adequate supply of portable fire extinguishing equipment located at readily accessible points, such a fire watch or detail should be able to prevent small fires from reaching serious proportions.

Appendix B Referenced Publications

B-1 The following documents or portions thereof are referenced within this standard for informational purposes only and thus should not be considered part of the requirements of this document. The edition indicated for each reference is current as of the date of the NFPA issuance of this document. These references are listed separately to facilitate updating to the latest edition by the user.

B-1.1 NFPA Publications. National Fire Protection Association, Batterymarch Park, Quincy, MA 02269.

NFPA 204M-1985, *Guide for Smoke and Heat Venting*.

NFPA 703-1985, *Standard for Fire Retardant Impregnated Wood and Fire Retardant Coatings for Building Materials*.

B-1.2 AWWA Publications. American Wood Preservers Association, 1625 I St, NW, Washington, DC 20006.

AWPA C-20-1974, *Structural Lumber Fire Retardant Treatment by Pressure Processes*.

AWPA C-27-1974, *Plywood-Fire Retardant Treatment by Pressure Processes*.

B-1.3 Other Publications.

ANSI/ASME A17.1-1984, *Safety Code for Elevators and Escalators*; and Supplements: ANSI A17.1a-1972, A17.1b-1973, A17.1c-1974, A17.1d-f-1975. American Society of Mechanical Engineers, 345 East 47th St., New York, NY 10017.

ANSI A117.1-1980, *Specifications for Making Buildings and Facilities Accessible to, and Usable by, the Physically Handicapped*. American National Standards Institute, 1430 Broadway, New York, NY 10018.

Index

© 1986 National Fire Protection Association. All Rights Reserved.

The copyright in this index is separate and distinct from the copyright in the document which it indexes. The licensing provisions set forth for the document are not applicable to this index. This index may not be reproduced in whole or in part by any means without the express written permission of the National Fire Protection Association, Inc.

-A-

- Air-inflated structures** 6-3
 - Definition 2-2
- Air-supported structures** 6-3
 - Definition 2-2
- Aisle stairs, grandstands** 4-3.4 thru 4-3.5, A-4-3.4.2
- Aisles** 3-5
 - Folding and telescopic seating 5-4
 - Grandstands 4-3, 4-6.3 thru 4-6.4, A-4-3.4.2
- Anchorage**
 - Air-inflated and air-supported structures 6-3.6
- Application of standard** 1-3
- Assembly occupancy**
 - Definition 2-2, A-2-2

-B-

- Bleachers** Chap. 4
 - Definition 2-2

-C-

- Construction, heavy timber**
 - Definition 2-2
- Containers, LP-Gas** 10-2.1.4

-D-

- Design load**
 - Folding and telescopic seating 5-2.4
 - Grandstands 4-2.5
- Ducts** 10-2.1.3

-E-

- Egress, means of** Chap. 3, A-3
 - Air-supported and air-inflated structures 6-3.7
 - Arrangement 3-5
 - Definition 2-2
 - Illumination 3-8
 - Marking 3-9
 - Tents 8-5.2
- Electrical installations** 10-1
- Emergency communications** 9-4
- Emergency power system** 6-3.5
- Engineer, professional**
 - Definition 2-2
- Equivalency concepts** 1-5
- Exit access**
 - Definition 2-2
- Exit discharge**
 - Definition 2-2
- Exits**
 - Capacity 3-3, A-3-3.4
 - Definition 2-2, A-2-2
 - Number of 3-4
 - Travel distance 3-6, A-3-6
 - Types of 3-2

-F-

- Fire alarms** 9-4
- Fire details** 9-5, A-9-5
- Fire extinguishing equipment** 9-3, A-9-3
- Fire hazards** 9-2

Fire resistance

- Definition 2-2

Flame resistance

- Membrane structure fabrics 6-1.7

- Tents 8-4

Flammable liquids and gases 9-1

- Folding and telescopic seating** see Seating, Folding and telescopic

-G-

- Grandstands** Chap. 4, A-4
 - Definition 2-2
 - Design 4-2
 - Location 4-1
 - Maintenance 4-10
 - Portable 4-8
 - Spaces underneath 4-9
 - Wood 4-7, 4-7.2
- Guards, grandstand** 4-6
- Guy wires or ropes** 3-1.4, 8-3

-H-

- Handicapped** 3-1.5, A-3-1.5
- Heating devices** 10-2

-I-

- Lighting, means of egress** 3-8
- Limited-combustible**
 - Definition 2-2

-M-

- Maintenance** A-1-2
 - Folding and telescopic seating 5-8
 - Grandstands 4-10
- Membrane**
 - Definition 2-2
- Membrane structures** see also Air-inflated structures, Air-supported structures, and Tensioned-membrane structures
 - Definition 2-2
 - Permanent Chap. 6, A-6-3.6.2
 - Temporary Chap. 7

-N-

- Noncombustible materials**
 - Definition 2-2

-O-

- Occupant load** 3-1.6
- Outdoor structure** 3-1.2, A-3-1.2.1

-P-

- Patrols** see Fire details
- Permanent**
 - Definition 2-2
- Pressurization (inflation) system**
 - Air-inflated and air-supported structures 6-3.4
- Purpose of standard** 1-2, A-1-2

-R-

| | |
|------------------------------------|--------------------|
| Railings | |
| Folding and telescopic seating | 5-7 |
| Grandstands | 4-6 |
| Ramps, grandstands | 4-3, A-4-3.4.2 |
| Referenced design standards | 1-4 |
| Risers, grandstands | 4-3.4.2, A-4-3.4.2 |

-S-

| | |
|--------------------------------------|---|
| Scope of standard | 1-1, A-1-1 |
| Seating | |
| Folding and telescopic | Chap. 5 |
| Application | 5-1 |
| Definition | 2-2 |
| Design | 5-2 |
| Maintenance and operation | 5-8 |
| Review and approval | 5-3 |
| Seats | 5-6 |
| Grandstands and bleachers | 4-5 |
| Smoke-protected assembly | 3-1.2, 3-3.2.2, A-3-1.2.1 |
| Signs, exit | 3-9 |
| Spaces underneath grandstands | 4-9 |
| Structures | see specific type such as Air-inflated structures |

-T-

| | |
|--------------------------------------|------------|
| Tanks | 10-2.1.5 |
| Temporary | |
| Definition | 2-2 |
| Tensioned-membrane structures | 6-2 |
| Definition | 2-2 |
| Temporary | Chap. 7 |
| Tent stakes | 3-1.4 |
| Tents | Chap. 8 |
| Definition | 2-2 |
| Private party | |
| Definition | 2-2 |
| Testing, membrane materials | 6-1.4 |
| Travel distance | 3-6, A-3-6 |
| Folding and telescopic seating | 5-6 |
| Grandstands | 4-4 |
| Turnstiles | 3-2.2 |

-W-

| | |
|------------------------------------|---------|
| Weathered membrane material | 6-1.4 |
| Definition | 2-2 |
| Wind loads, grandstands | 4-2.5.4 |