

NFPA 1963

Standard for Fire Hose Connections

2003 Edition



NFPA, 1 Batterymarch Park, PO Box 9101, Quincy, MA 02269-9101
An International Codes and Standards Organization

NFPA License Agreement

This document is copyrighted by the National Fire Protection Association (NFPA), 1 Batterymarch Park, Quincy, MA 02269-9101 USA.
All rights reserved.

NFPA grants you a license as follows: The right to download an electronic file of this NFPA document for temporary storage on one computer for purposes of viewing and/or printing one copy of the NFPA document for individual use. Neither the electronic file nor the hard copy print may be reproduced in any way. In addition, the electronic file may not be distributed elsewhere over computer networks or otherwise. The hard copy print may only be used personally or distributed to other employees for their internal use within your organization.

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA DOCUMENTS

NOTICE AND DISCLAIMER OF LIABILITY CONCERNING THE USE OF NFPA DOCUMENTS

NFPA codes, standards, recommended practices, and guides, of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in its codes and standards.

The NFPA disclaims liability for any personal injury, property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on this document. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making this document available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of this document. Nor does the NFPA list, certify, test or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

ADDITIONAL NOTICES AND DISCLAIMERS

Updating of NFPA Documents

Users of NFPA codes, standards, recommended practices, and guides should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of Tentative Interim Amendments. An official NFPA document at any point in time consists of the current edition of the document together with any Tentative Interim Amendments and any Errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of Tentative Interim Amendments or corrected through the issuance of Errata, consult appropriate NFPA publications such as the National Fire Codes® Subscription Service, visit the NFPA website at www.nfpa.org, or contact the NFPA at the address listed below.

Interpretations of NFPA Documents

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing Committee Projects shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights asserted in connection with any items which are mentioned in or are the subject of NFPA codes, standards, recommended practices, and guides, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on these documents. Users of these documents are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

NFPA adheres to applicable policies of the American National Standards Institute with respect to patents. For further information contact the NFPA at the address listed below.

Law and Regulations

Users of these documents should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

This document is copyrighted by the NFPA. It is made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making this document available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to this document.

Use of NFPA documents for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA documents, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA codes, standards, recommended practices, and guides and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA documents during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

For more information about NFPA, visit the NFPA website at www.nfpa.org.

Copyright © 2003, National Fire Protection Association, All Rights Reserved

NFPA 1963
Standard for
Fire Hose Connections
2003 Edition

This edition of NFPA 1963, *Standard for Fire Hose Connections*, was prepared by the Technical Committee on Fire Hose and acted on by NFPA at its May Association Technical Meeting held May 18–21, 2003, in Dallas, TX. It was issued by the Standards Council on July 18, 2003, with an effective date of August 7, 2003, and supersedes all previous editions.

This edition of NFPA 1963 was approved as an American National Standard on July 18, 2003.

Origin and Development of NFPA 1963

The development of a standard for screw threads and gaskets for fire hose connections began over a century ago. Specifications for hose couplings were drawn up by the NFPA as early as 1898. An NFPA committee appointed in 1905 established a national standard thread for 2½ in. and larger hose connections. Work on smaller hose threads was started in 1916, and the standard was adopted in 1922. The standard for suction hose coupling threads was adopted in 1955. The present standard covers the 11 standard sizes of threaded connections from ¾ in. (19 mm) to 8 in. (200 mm).

See Annex B for a detailed history of fire hose coupling thread standardization in the United States.

In recent history, editions of this standard were published in 1979, 1985, 1993, and 1998. The 1979 edition included metric conversion figures where applicable. Also, the number designation of the document was changed from NFPA 194 to NFPA 1963. Changes in 1985 were editorial.

The 1993 edition was a major expansion of the standard. A new chapter was added to cover general requirements for couplings and adapters. Another was added to cover nonthreaded connections in the 4 in. and 5 in. sizes. New material was added to the chapter on gaskets to cover gaskets used with nonthreaded connections. Sections dealing with the threads on fire department pump discharges and intakes, portable pumps, and sprinkler and standpipe systems were deleted, as requirements addressing those threads are covered in other NFPA standards. The title of the document was changed from *Standard for Screw Threads and Gaskets for Fire Hose Connections* to *Standard for Fire Hose Connections* to reflect the broader scope of the document.

In the 1998 edition, the requirement for locks on caps used with nonthreaded couplings was removed, and some editorial revisions were made to the document.

This edition adds dimensioning for an 8 in. NH thread. Format revisions were made to meet the requirements of the *NFPA Manual of Style*.

Technical Committee on Fire Hose

John W. Stacey, Chair

Bellevue Fire Department, NE [E]

Rep. International Association of Fire Chiefs

Milan J. Dotlich II, Underwriters Laboratories Inc., IL [RT]

Robert Ely, San Diego, CA [SE]

Ray K. Farm, City of Corvallis Fire Department, OR [U]

Thomas G. Farruggia, Illinois Fire Extinguisher Company, Inc., IL [IM]

Rep. National Association of Fire Equipment Distributors Inc.

Stephen Gilbert, Los Angeles, CA [SE]

Robert M. Harcourt, Snap-tite Hose, Inc., PA [M]

Paul Robert Kaveler, Ameren Services, MO [U]
Rep. Edison Electric Institute

Gregory Kozey, Kochek Company, Inc., CT [M]

Larry Linton, Washington Township Volunteer Fire Department, IN [L]

William J. Patterson, Federal Emergency Management Agency, CA [SE]

David J. Pritchard, Apex, NC [SE]

Mark Saner, Akron Brass, OH [M]

Joe Stonecypher, Kidde Fire Fighting, TX [M]

Ralph D. Taylor, U.S.D.A. Forest Service, CA [U]

Alternates

David A. Lord, Niedner Ltd, Canada [M]

(Voting Alt. to Fire Equipment Manufacturers' Association Rep.)

Byron J. Sarago, Detroit Edison Company, MI [U]

(Alt. to P. R. Kaveler)

Lois P. Sicking, U.S.D.A. Forest Service, CA [U]

(Alt. to R. D. Taylor)

Kenneth W. Zastrow, Underwriters Laboratories Inc., IL [RT]

(Alt. to M. J. Dotlich II)

Carl E. Peterson, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on the size and design of fire hose connections, and the performance, maintenance, and selection of all types of fire hose, couplings, nozzles, and accessory equipment.

Contents

Chapter 1 Administration	1963– 4	5.3 Dimensions of American National Fire Hose Connection Screw Threads (NH)	1963– 8
1.1 Scope	1963– 4	5.4 Thread Dimensions	1963– 8
1.2 Purpose	1963– 4	5.5 Tolerance	1963– 8
1.3 Application	1963– 4	5.6 Gauges and Gauging NH Threads	1963–11
Chapter 2 Referenced Publications	1963– 4	Chapter 6 Nonthreaded Connections	1963–15
2.1 General	1963– 4	6.1 General	1963–15
2.2 NFPA Publication	1963– 4	6.2 Gauges	1963–15
2.3 Other Publications	1963– 4	6.3 Locks	1963–15
Chapter 3 Definitions	1963– 4	6.4 Indicators	1963–16
3.1 General	1963– 4	6.5 Force to Connect and Disconnect	1963–16
3.2 NFPA Official Definitions	1963– 4	6.6 Caps	1963–17
3.3 General Definitions	1963– 4	6.7 Adapters	1963–17
Chapter 4 General Coupling and Adapter Requirements	1963– 5	6.8 Metal-Face Hydrant Connections	1963–17
4.1 Workmanship	1963– 5	Chapter 7 Gaskets	1963–19
4.2 Materials	1963– 5	7.1 Threaded Coupling Gasket	1963–19
4.3 Minimum Waterway	1963– 5	7.2 Nonthreaded Coupling Gaskets	1963–19
4.4 Gasket Groove	1963– 5	7.3 Tail Gasket	1963–19
4.5 Testing	1963– 5	Chapter 8 Use of NH Threads and Nonthreaded Connections	1963–20
4.6 Internal Strength	1963– 5	8.1 Hose Coupling Threads	1963–20
4.7 Tensile Strength	1963– 5	8.2 Connections for Fire Service Nozzles for Handlines	1963–20
4.8 Connect/Disconnect Capability	1963– 6	8.3 Connections for Large-Stream Devices ...	1963–21
4.9 Rough Usage	1963– 6	Annex A Explanatory Material	1963–22
4.10 Coupling Retention	1963– 6	Annex B History of Fire Hose Coupling Thread Standardization in the United States	1963–26
4.11 Vacuum Tightness	1963– 6	Annex C Informational References	1963–27
4.12 Corrosion Resistance	1963– 6	Index	1963–28
4.13 Nonmetallic Materials	1963– 6		
4.14 High-Temperature Performance	1963– 6		
4.15 Low-Temperature Performance	1963– 6		
4.16 Gasket Performance	1963– 7		
Chapter 5 Screw Threads for Couplings and Adapters	1963– 7		
5.1 Basic Form of Thread	1963– 7		
5.2 Thread Series Designation	1963– 8		

NFPA 1963

Standard for

Fire Hose Connections

2003 Edition

IMPORTANT NOTE: This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading "Important Notices and Disclaimers Concerning NFPA Documents." They can also be obtained on request from NFPA or viewed at www.nfpa.org/disclaimers.

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

Changes other than editorial are indicated by a vertical rule beside the paragraph, table, or figure in which the change occurred. These rules are included as an aid to the user in identifying changes from the previous edition.

Information on referenced publications can be found in Chapter 2 and Annex C.

Chapter 1 Administration

1.1* Scope. This standard gives the performance requirements for new fire hose couplings and adapters with nominal sizes from $\frac{3}{4}$ in. (19 mm) through 8 in. (200 mm) and the specifications for the mating surfaces.

1.2 Purpose. The purpose of this standard is to provide a uniform standard for safe couplings and adapters for the users of fire hose connections.

1.3 Application. The requirements of this standard shall apply to the following devices in the sizes defined in Section 1.1.

- (1) Fire hose couplings
- (2) Booster hose couplings
- (3) Hard suction hose couplings
- (4) Pump intake connections on fire apparatus
- (5) Pump discharge connections on fire apparatus
- (6) Sprinkler connections
- (7) Standpipe connections
- (8) Hose connections on fire hydrants
- (9) Adapters
- (10) Reducers
- (11) Caps
- (12) Plugs
- (13) Connections on all other hose fittings and appliances that attach to fire pumps, hose, or hydrants

Chapter 2 Referenced Publications

2.1 General. The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

2.2 NFPA Publication. National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

NFPA 1971, *Standard on Protective Ensemble for Structural Fire Fighting*, 2000 edition.

2.3 Other Publications.

2.3.1 ANSI Publication. American National Standards Institute, 25 West 43rd Street, 4th floor, New York, NY 10036.

ANSI/ASME B1.2, *Gages and Gaging for Unified Inch Screw Threads*, 1983.

2.3.2 ASTM Publications. American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959.

ASTM B 30, *Standard Specification for Copper-Brass Alloys in Ingot Form*, 2000.

ASTM B 117, *Standard Practice for Operating Salt Spray (Fog) Apparatus*, 1997.

ASTM B 584, *Standard Specification for Copper Alloy Sand Castings for General Applications*, 2000.

ASTM D 395, *Standard Test Methods for Rubber Property — Compression Set*, 2001.

ASTM D 573, *Standard Test Method for Rubber Deterioration in an Air Oven*, 1999.

ASTM D 3183, *Standard Practice for Rubber — Preparation of Pieces for Test Purposes from Products*, 1984.

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not included, common usage of the terms shall apply.

3.2 NFPA Official Definitions.

3.2.1* Approved. Acceptable to the authority having jurisdiction.

3.2.2* Authority Having Jurisdiction (AHJ). An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.

3.2.3 Shall. Indicates a mandatory requirement.

3.2.4 Should. Indicates a recommendation or that which is advised but not required.

3.3 General Definitions.

3.3.1 Adapter. Any device that allows fire hose couplings to be safely interconnected with couplings of different sizes, threads, or mating surfaces, or that allows fire hose couplings to be safely connected to other appliances.

3.3.2 Blunt Start. The removal of the incomplete thread at the end of the thread. This is a feature of threaded parts that are repeatedly assembled by hand. Also known as the "Higbee cut."

3.3.3 Coupling Assembly. A complete coupling including its gaskets and the expansion rings or collar pieces used in attaching the coupling to the hose.

3.3.4 Couplings. One set or pair of connection devices attached to a fire hose that allow the hose to be interconnected to additional lengths of hose or adapters and other fire-fighting appliances.

3.3.5 Gasket.

3.3.5.1 Bowl Gasket. See *Tail Gasket*.

3.3.5.2 Face Gasket. The water pressure seal at the mating surfaces of nonthreaded couplings or adapters.

3.3.5.3 Tail Gasket. A gasket in the bowl of a coupling used to provide a watertight seal between the coupling and the hose in an expansion ring-type coupling.

3.3.5.4 Thread Gasket. A gasket used in a female threaded connection to provide a watertight seal between the male and female threaded connections.

3.3.6 Hard Suction Hose. A hose used for drafting water from static supplies (lakes, rivers, wells, and so forth). It can also be used for supplying pumps on fire apparatus from hydrants if designed for that purpose. The hose contains a semirigid or rigid reinforcement designed to prevent collapse of the hose under vacuum.

3.3.7 Large-Stream Device. Any device that discharges water at a flow rate greater than 400 gpm (1600 L/min).

3.3.8 NH. An American National Fire Hose Connection Screw Thread. (See Section 5.2.)

3.3.9 Nonthreaded Coupling or Adapter. A coupling or adapter in which the mating is achieved with locks or cams but without the use of screw threads.

3.3.10 Nozzle.

3.3.10.1 Spray Nozzle. A nozzle with an adjustable pattern and a control device that shuts off the flow.

3.3.10.2 Straight Tip Nozzle. A smooth-bore nozzle for producing a solid stream.

3.3.11 Primary Inlet. The inlet where an appliance connects to a hose.

3.3.12 Screw Thread Coupling or Adapter. A coupling or adapter in which the mating is achieved with the use of threads.

Chapter 4 General Coupling and Adapter Requirements

4.1* Workmanship. The coupling assembly or adapter shall be made and finished in a workmanship-like manner throughout.

4.1.1 All edges shall be chamfered and free from burrs.

4.1.2 Hose bowl or tailpiece lips shall be rounded to prevent damage to the hose.

4.2 Materials. Materials used shall be free of defects that would adversely affect the performance or maintenance of individual components or of the overall assembly.

4.3 Minimum Waterway. The design of the shank-type and nonthreaded expansion ring coupling shall be such that the coupling shall not restrict the waterway by more than ¼ in. (6.4 mm) on couplings of nominal size 2½ in. (65 mm) or less and not more than ½ in. (12.7 mm) on couplings of nominal size greater than 2½ in. (65 mm). Gaskets shall not protrude into the waterway.

4.3.1 The waterway of a size-increasing-style coupling, other than a shank-type coupling, shall be no smaller than the nominal size of the hose to which it is attached.

4.3.2 The waterway of a size-reducing-style coupling, other than a shank-type coupling, shall be no smaller than the nominal size of the attachment face.

4.4 Gasket Groove. All sizes of internal NH threaded couplings, connections, or adapters shall have a standard gasket groove diameter as shown in Table 5.4.2, column K. (See also Figure 5.1.5.1, dimension K.)

4.5 Testing. Tests required by this standard shall be conducted by the manufacturer or by an approved testing facility designated by the manufacturer.

4.5.1 All tests shall be conducted on standard commercially available product.

4.5.2 Any test that requires the use of hose shall use hose with the highest service test pressure commercially available to which the coupling can be attached.

4.6 Internal Strength.

4.6.1 The coupling or adapter shall be capable of withstanding a hydrostatic pressure equal to the service test pressure without leakage, two times service test pressure with no leakage more severe than 12 drops per minute (½ ml per minute), and three times the service test pressure plus 100 psi (690 kPa) without separation. It shall be tested in accordance with 4.6.2 to prove compliance.

4.6.2 Internal Strength Test.

4.6.2.1 The coupling or adapter shall be plugged and adapted on one end to accept a pump connection from a hydrostatic test table.

4.6.2.2 The other end shall be plugged or adapted to accept a petcock to remove air.

4.6.2.3 The coupling or adapter shall be filled with water until all air has been exhausted and the petcock closed.

4.6.2.4 Pressure shall be applied until the test pressure is reached.

4.6.2.5 The test pressure shall be held for at least 15 seconds but not more than 60 seconds.

4.7 Tensile Strength.

4.7.1 Couplings shall have a tensile strength of at least 1200 lb/in. (210 N/mm) of diameter. They shall be tested in accordance with 4.7.2 to prove compliance.

4.7.2 Tensile Strength Test.

4.7.2.1 A pair of couplings shall be attached to a section of hose.

4.7.2.2 The couplings shall be connected together and the hose installed in a tension testing machine such that the tension will be on the couplings.

4.7.2.3 A tensile load shall be applied at a rate of not more than 2 in. (51 mm) per minute up to 1200 lb/in. (210 N/mm) of nominal hose diameter.

4.7.3 After the tensile strength test, the couplings shall be subjected to a test pressure equal to the service test pressure of the hose to which they are attached. Any leakage or deformation shall constitute failure of this test.

4.8 Connect/Disconnect Capability.

4.8.1 Couplings shall be capable of being connected and disconnected at least 3000 times without leakage or failure. They shall be tested in accordance with 4.8.2 to prove compliance.

4.8.2 Connect/Disconnect Capability Test.

4.8.2.1 Tests shall be conducted on standard commercial product without lubrication.

4.8.2.2 Hose couplings shall be completely connected and disconnected to each other at least 3000 times.

4.8.2.3 At the completion of this portion of the test, the couplings shall be attached to hose such that tested couplings can be connected together.

4.8.2.4 The tested couplings when connected together shall withstand the service test pressure of the hose without leakage or failure.

4.9 Rough Usage.

4.9.1 Couplings shall be capable of being dropped up to 6 ft (1.8 m) without deformation or damage that impairs operation. They shall be tested in accordance with 4.9.2 to prove compliance.

4.9.2 Rough Usage Test.

4.9.2.1 Couplings shall be installed on approximately 10 ft (3 m) lengths of fire hose.

4.9.2.2 The couplings shall be coupled together, forming a loop in the hose.

4.9.2.3 The coupling assembly shall then be dropped onto a concrete surface from a height of 6 ft (1.8 m) so as to land as squarely as possible on the swivel ring.

4.9.2.4 This shall be repeated three times.

4.9.2.5 The couplings shall operate freely and shall show no signs of deformation when inspected inside and outside.

4.9.2.6 Samples showing distortion or binding of the swivel mechanism shall be judged acceptable if the mechanism can be corrected to turn freely and evenly when straightened by the use of a hammer.

4.9.2.7 Samples developing cracks or broken sections either before or after attempts to straighten damaged portions shall be deemed as having failed the test. The coupling/hose assembly shall withstand the service test pressure of the hose without leakage or failure.

4.10 Coupling Retention.

4.10.1 Couplings shall remain on the hose without movement up to the rated burst pressure of the hose. They shall be tested in accordance with 4.10.2 to prove compliance.

4.10.2 Coupling Retention Test.

4.10.2.1 The couplings shall be attached to a 3 ft (1 m) length of hose.

4.10.2.2 The hose and coupling as an assembly shall be pressurized to the service pressure of the hose for 1 minute, and then the pressure shall be released.

4.10.2.3 The position of the coupling with relation to the hose shall be marked.

4.10.2.4 The pressure in the hose/coupling assembly shall then be raised at a rate of 300 psi to 1000 psi (2068 kPa to 6895 kPa) per minute until the rated burst pressure of the hose is reached.

4.10.2.5 The pressure shall be held for a minimum of 15 seconds but not longer than 60 seconds.

4.10.2.6 The hose shall show no signs of movement from the coupling.

4.11 Vacuum Tightness.

4.11.1 When couplings are used on hard suction hose, they shall be capable of holding a vacuum of 22 in. Hg (74.2 kPa) for 5 minutes. They shall be tested in accordance with 4.11.2 to prove compliance.

4.11.2 Vacuum Tightness Test.

4.11.2.1 The coupling shall be attached to a suitable section of hard suction hose.

4.11.2.2 A blank cap shall be attached to the coupling on one end, and a vacuum pump shall be attached to the other end.

4.11.2.3 A vacuum of 22 in. Hg (74.2 kPa) shall be developed within the assembly, and the assembly shall hold the vacuum for 5 minutes without any loss of vacuum.

4.12 Corrosion Resistance.

4.12.1 Couplings having parts other than high-strength yellow brass No. 8A as defined in ASTM B 30, *Standard Specification for Copper-Brass Alloys in Ingot Form*, or ASTM B 584, *Standard Specification for Copper Alloy Sand Castings for General Applications*, shall be capable of being coupled and uncoupled using accepted standard practices and shall not show any evidence of galvanic corrosion between dissimilar metals after testing in accordance with 4.12.2.

4.12.2 Coupling assemblies including expansion rings and gaskets shall be supported vertically in a fog chamber and exposed to salt spray (fog) as specified by ASTM B 117, *Standard Practice for Operating Salt Spray (Fog) Apparatus*, for a period of 120 hours.

4.13 Nonmetallic Materials. Any nonmetallic material used in couplings except for the gaskets shall be certified by the manufacturer of the nonmetallic material as fit for the service intended.

4.14 High-Temperature Performance.

4.14.1 Temperatures up to 275°F (135°C) shall not affect the ease with which a coupling assembly is coupled or uncoupled. Couplings shall be tested in accordance with 4.14.2 to prove compliance.

4.14.2 High-Temperature Performance Test.

4.14.2.1 Dry couplings with gaskets installed shall be conditioned in an oven at 275°F (135°C) for 4 hours.

4.14.2.2 Immediately upon their removal from the oven, the torque to connect and disconnect the couplings shall be measured and shall be within the original torque range.

4.15 Low-Temperature Performance.

4.15.1 Temperatures down to -25°F ± 2°F (-32°C ± 1°C) shall not affect the performance of the coupling assembly. Couplings shall be tested in accordance with 4.15.2 to prove compliance.

4.15.2 Low-Temperature Performance Test.

4.15.2.1 With the gasket(s) installed, a coupling assembly shall be subjected to an environment of $0^{\circ}\text{F} \pm 1^{\circ}\text{F}$ ($-18^{\circ}\text{C} \pm 1^{\circ}\text{C}$) for a period of 24 hours and subsequently to an environment of $-25^{\circ}\text{F} \pm 2^{\circ}\text{F}$ ($-32^{\circ}\text{C} \pm 1^{\circ}\text{C}$) for a period of 2 hours.

4.15.2.2 Following this exposure, the coupling shall be dropped from a height of 10 ft (3 m) onto its longitudinal axis.

4.15.2.3 The torque to connect and disconnect the couplings shall then be measured and shall be no greater than the torque required before the test.

4.16 Gasket Performance. The gasket material used with any coupling or adapter shall meet the test requirements of 4.16.1 through 4.16.3.

4.16.1 Low-Temperature Test.

4.16.1.1 Gaskets shall be subjected to an environment of $0^{\circ}\text{F} \pm 1^{\circ}\text{F}$ ($-18^{\circ}\text{C} \pm 1^{\circ}\text{C}$) for a period of 24 hours and subsequently to an environment of $-25^{\circ}\text{F} \pm 2^{\circ}\text{F}$ ($-32^{\circ}\text{C} \pm 1^{\circ}\text{C}$) for a period of 2 hours.

4.16.1.2 Immediately upon removal from the test chamber, the gasket shall not crack when squeezed from any two opposite points into a figure 8 configuration.

4.16.2 Accelerated Aging Test.

4.16.2.1 Samples of the gasket material shall be prepared in accordance with the procedures described in ASTM D 3183, *Standard Practice for Rubber — Preparation of Pieces for Test Purposes from Products*.

4.16.2.2 The samples of the gaskets shall then be subjected to oven aging at $212^{\circ}\text{F} \pm 3^{\circ}\text{F}$ ($100^{\circ}\text{C} \pm 2^{\circ}\text{C}$) for 70 hours in accordance with ASTM D 573, *Standard Test Method for Rubber Deterioration in an Air Oven*.

4.16.2.3 The samples shall then be tested for tensile strength and ultimate elongation, and the tensile strength shall be not

less than 80 percent, and the ultimate elongation shall be not less than 50 percent of the corresponding properties of samples that have not been so treated.

4.16.3 Compression Set Test.

4.16.3.1 A sample of gasket material shall be compressed as defined in ASTM D 395, *Standard Test Methods for Rubber Property — Compression Set (Method B)*, and subjected to heat treatment at $158^{\circ}\text{F} \pm 1^{\circ}\text{F}$ ($70^{\circ}\text{C} \pm 1^{\circ}\text{C}$) for a period of 24 hours.

4.16.3.2 The compression set of the sample of gasket material so tested shall not exceed 15 percent of the original thickness.

Chapter 5 Screw Threads for Couplings and Adapters

5.1 Basic Form of Thread.

5.1.1 Basic thread form, as specified in Figure 5.1.1, shall have an included angle of 60 degrees and truncated top and bottom.

5.1.2 The basic angle of the thread between the sides of the thread measured in an axial plane shall be 60 degrees. The line bisecting this 60-degree angle shall be perpendicular to the axis of the screw thread.

5.1.3 The flat at the root and crest of the basic thread, as specified in Figure 5.1.1, shall be $\frac{1}{8}$ times the pitch or 0.125 times the pitch (p).

5.1.4 The height of the basic thread shall be

$$h = 0.649519 \times p$$

or

$$h = \frac{0.649519}{n}$$

where:

p = pitch in inches ($p = 1/n$)

n = number of threads per inch

h = basic thread height in inches





FIGURE 5.1.1 Form of Thread of American National Fire Hose Connection Screw Thread (NH).
(See Table 5.4.1 for dimensions.)

5.1.5* Blunt Start.

5.1.5.1 The outer ends of all external and internal threads shall be terminated by the blunt start, or Higbee cut, as shown in Figure 5.1.5.1, on full thread to avoid crossing and mutilation of thread.



- C = Inside diameter of connection waterway (nominal size of connection)
 D = Approximate outside diameter of external thread (ODM)
 H = Depth of internal connection
 I = Length of the pilot from the face of the external connection to the start of the second thread (Higbee cut)
 J = Distance from the face of the internal connection to the start of the second thread (Higbee cut)
 K = Diameter of the gasket seat
 L = Length of external thread
 T = Length of internal thread

FIGURE 5.1.5.1 Nominal Dimensions of Connections. (See Table 5.4.2 for dimensions.)

5.1.5.2 The blunt start shall have a minimum length of not less than the radius formed by a cutter with a radius not less than the height of the thread.

5.1.5.3 The maximum length of the blunt start shall not exceed 10 degrees of arc.

5.2 Thread Series Designation.

5.2.1* Fire hose connection threads that meet the requirements of this chapter shall be identified as "American National Fire Hose Connection Screw Threads" (abbreviated throughout the standard with the thread symbol NH).

5.2.2 They shall be designated by specifying in sequence the nominal size of the connection, the number of threads per inch, and the thread symbol "NH" as shown in the following example:

0.75-8 NH	3.5-6 NH
1-8 NH	4-4 NH
1.5-9 NH	4.5-4 NH
2.5-7.5 NH	5-4 NH
3-6 NH	6-4 NH
	8-4 NH

5.3 Dimensions of American National Fire Hose Connection Screw Threads (NH).

5.3.1 The basic major diameter, basic pitch diameter, and basic minor diameter and tolerances of the thread shall be as specified in Figure 5.1.1.

5.3.2 Nominal dimensions shall be as specified in Figure 5.1.5.1.

5.4 Thread Dimensions.

5.4.1 The basic dimensions for the threads shall be as specified in Table 5.4.1.

5.4.2 The nominal dimensions for the threads shall be as specified in Table 5.4.2.

5.4.3 The limiting dimensions for external threads (nipples) shall be as specified in Table 5.4.3.

5.4.4 The limiting dimensions for internal threads (couplings) shall be as specified in Table 5.4.4.

5.5 Tolerance.

5.5.1 The pitch diameter tolerances for a mating external (nipple) and internal (coupling) thread shall be the same.

5.5.1.1 Pitch diameter tolerances shall include lead and half-angle deviations.

5.5.1.2 Values for lead and half-angle deviations consuming one-half of the pitch diameter tolerance shall be as specified in Table 5.5.1.2.

5.5.2 The tolerance relationships for the external (nipple) threads shall be as follows:

$$\text{Major diameter tolerance} = 2 \times \text{pitch diameter tolerance}$$

$$\text{Minor diameter tolerance} = \text{pitch diameter tolerance} + 2h/9$$

5.5.2.1 The minimum minor diameter of the external thread (nipple) shall be such as to result in a flat equal to $\frac{1}{8}$ of the $p/8$ basic flat ($p/24$) at the root when the pitch diameter of the nipple is at its minimum value.

5.5.2.2 The maximum minor diameter is basic but shall be permitted to be such as results from the use of a worn or rounded threading tool.

5.5.2.3 The maximum minor diameter shall be as specified in Figure 5.1.1 and is the diameter on which the minor diameter tolerance formula shown in 5.5.2 shall be based.

5.5.3 The tolerance relationships for the internal (coupling) threads shall be as follows:

$$\text{Minor diameter tolerance} = 2 \times \text{pitch diameter tolerance}$$

$$\text{Major diameter tolerance} = \text{pitch diameter tolerance} + 2h/g$$

Table 5.4.1 Basic Dimensions of NH Threads (See Figure 5.1.1.)

Nominal Size of Connection	Threads per Inch (tpi) ¹	Thread Designation (NH) ¹	Pitch (p)	Basic Thread Height (h)	External Thread Dimensions (Nipple)				Minimum Internal Thread Dimensions		
					Allowance	Maximum Major Diameter, D – Col. 6	Maximum Pitch Diameter, Col. 7 – h	Maximum Minor Diameter, Col. 7 – 2h	Minimum Minor Diameter, D – 2h	Basic Pitch Diameter, D – h	Basic Major Diameter, D
1	2	3	4	5	6	7	8	9	10	11	12
¾	8	0.75-8 NH	0.12500	0.08119	0.0120	1.3750	1.2938	1.2126	1.2246	1.3058	1.3870
1	8	1-8 NH	0.12500	0.08119	0.0120	1.3750	1.2938	1.2126	1.2246	1.3058	1.3870
1½	9	1.5-9 NH	0.11111	0.07217	0.0120	1.9900	1.9178	1.8457	1.8577	1.9298	2.0020
2½	7.5	2.5-7.5 NH	0.13333	0.08660	0.0150	3.0686	2.9820	2.8954	2.9104	2.9970	3.0836
3	6	3-6 NH	0.16667	0.10825	0.0150	3.6239	3.5156	3.4073	3.4223	3.5306	3.6389
3½	6	3.5-6 NH	0.16667	0.10825	0.0200	4.2439	4.1356	4.0273	4.0473	4.1556	4.2639
4	4	4-4 NH	0.25000	0.16238	0.0250	5.0109	4.8485	4.6861	4.7111	4.8735	5.0359
4½	4	4.5-4 NH	0.25000	0.16238	0.0250	5.7609	5.5985	5.4361	5.4611	5.6235	5.7859
5	4	5-4 NH	0.25000	0.16238	0.0250	6.2600	6.0976	5.9352	5.9602	6.1226	6.2850
6	4	6-4 NH	0.25000	0.16238	0.0250	7.0250	6.8626	6.7002	6.7252	6.8876	7.0500
8	4	8-4 NH	0.25000	0.16238	0.0250	9.0250	8.8626	8.7002	8.7252	8.8876	9.0500

¹All other values are in inches.

Table 5.4.2 Nominal Dimensions of NH Threads (See Figure 5.1.5.1.)

Nominal Size of Connection Waterway, C	Threads per Inch (tpi) ¹	Thread Designation (NH) ¹	Approximate Outside Diameter of External Thread, D ²	Length of External Thread (Min), L	Length of Pilot to Start of Second Thread (External), I	Depth of Internal Connector, H	Diameter of Gasket Seat in Coupling, K	Length of Internal Thread, T	Length of Pilot to Start of Second Thread (Internal), J
¾	8	0.75-8 NH	1⅜	⅝	⅝ ₃₂	1⅞ ₃₂	1⅞ ₁₆	1⅜ ₃₂	⅝ ₃₂
1	8	1-8 NH	1⅜	⅝	⅝ ₃₂	1⅞ ₃₂	1⅞ ₁₆	1⅜ ₃₂	⅝ ₃₂
1½	9	1.5-9 NH	2	⅝	⅝ ₃₂	1⅞ ₃₂	2⅞ ₁₆	1⅜ ₃₂	⅝ ₃₂
2½	7½	2.5-7.5 NH	3⅞ ₁₆	1	¼	1⅝ ₁₆	3⅞ ₁₆	1⅞ ₁₆	¾ ₁₆
3	6	3-6 NH	3⅝	1⅞	⅝ ₁₆	1⅞ ₁₆	3⅞ ₄	¾	¼
3½	6	3.5-6 NH	4¼	1⅞	⅝ ₁₆	1⅞ ₁₆	4⅞ ₈	¾	¼
4	4	4-4 NH	5	1⅞	⅞ ₁₆	1⅞ ₁₆	5⅞ ₈	⅞ ₈	⅝ ₈
4½	4	4.5-4 NH	5¾	1⅞	⅞ ₁₆	1⅞ ₁₆	5⅞ ₈	⅞ ₈	⅝ ₈
5	4	5-4 NH	6¼	1⅞	⅞ ₁₆	1⅞ ₁₆	6⅞ ₈	1	⅝ ₈
6	4	6-4 NH	7⅞ ₃₂	1⅞	⅞ ₁₆	1⅞ ₁₆	7⅞ ₈	1	⅝ ₈
8	4	8-4 NH	9⅞ ₃₂	1½	⅞ ₁₆	1⅞ ₁₆	9⅞ ₈	1⅞ ₈	⅝ ₈

¹All other values are in inches.²Approximate dimensions are for field identification purposes only. Exact basic manufacturing dimensions and tolerances are given in subsequent tables.

Table 5.4.3 Limits of Size and Tolerances of NH External Threads (Nipples)

Nominal Size of Connection	Threads per Inch (tpi) ¹	Thread Designation (NH) ¹	Pitch (p)	Basic Thread Height (h)	External Thread (Nipple)						
					Major Diameter			Pitch Diameter			Minor Diameter ²
					Maximum	Minimum	Tolerance	Maximum	Minimum	Tolerance	Maximum
1	2	3	4	5	6	7	8	9	10	11	12
¾	8	0.75-8 NH	0.12500	0.08119	1.3750	1.3528	0.0222	1.2938	1.2827	0.0111	1.2126
1	8	1-8 NH	0.12500	0.08119	1.3750	1.3528	0.0222	1.2938	1.2827	0.0111	1.2126
1½	9	1.5-9 NH	0.11111	0.07217	1.9900	1.9678	0.0222	1.9178	1.9067	0.0111	1.8457
2½	7.5	2.5-7.5 NH	0.13333	0.08660	3.0686	3.0366	0.0320	2.9820	2.9660	0.0160	2.8954
3	6	3-6 NH	0.16667	0.10825	3.6239	3.5879	0.0360	3.5156	3.4976	0.0180	3.4073
3½	6	3.5-6 NH	0.16667	0.10825	4.2439	4.2079	0.0360	4.1356	4.1176	0.0180	4.0273
4	4	4-4 NH	0.25000	0.16238	5.0109	4.9609	0.0500	4.8485	4.8235	0.0250	4.6861
4½	4	4.5-4 NH	0.25000	0.16238	5.7609	5.7109	0.0500	5.5985	5.5735	0.0250	5.4361
5	4	5-4 NH	0.25000	0.16238	6.2600	6.2100	0.0500	6.0976	6.0726	0.0250	5.9352
6	4	6-4 NH	0.25000	0.16238	7.0250	6.9750	0.0500	6.8626	6.8376	0.0250	6.7002
8	4	8-4 NH	0.25000	0.16238	9.0250	8.9750	0.0500	8.8626	8.8376	0.0250	8.7002

¹All other values are in inches.

²Dimensions given for the maximum minor diameter of the nipple are figured to the intersection of the worn tool arc with a centerline through crest and root. The minimum minor diameter of the nipple shall be that corresponding to a flat at the minor diameter of the minimum nipple equal to $p/24$ and may be determined by subtracting $11 h/9$ (or $0.7939p$) from the minimum pitch diameter of the nipple.

Table 5.4.4 Thread Limits of Size and Tolerances of NH Internal Threads (Couplings)

Nominal Size of Connection	Threads per Inch (tpi) ¹	Thread Designation (NH) ¹	Pitch (p)	Basic Thread Height (h)	Internal Thread (Coupling)						
					Minor Diameter			Pitch Diameter			Major Diameter ²
					Minimum	Maximum	Tolerance	Minimum	Maximum	Tolerance	Minimum
1	2	3	4	5	6	7	8	9	10	11	12
¾	8	0.75-8 NH	0.12500	0.08119	1.2246	1.2468	0.0222	1.3058	1.3169	0.0111	1.3870
1	8	1-8 NH	0.12500	0.08119	1.2246	1.2468	0.0222	1.3058	1.3169	0.0111	1.3870
1½	9	1.5-9 NH	0.11111	0.07217	1.8577	1.8799	0.0222	1.9298	1.9409	0.0111	2.0020
2½	7.5	2.5-7.5 NH	0.13333	0.08660	2.9104	2.9424	0.0320	2.9970	3.0130	0.0160	3.0836
3	6	3-6 NH	0.16667	0.10825	3.4223	3.4583	0.0360	3.5306	3.5486	0.0180	3.6389
3½	6	3.5-6 NH	0.16667	0.10825	4.0473	4.0833	0.0360	4.1556	4.1736	0.0180	4.2639
4	4	4-4 NH	0.25000	0.16238	4.7111	4.7611	0.0500	4.8735	4.8985	0.0250	5.0359
4½	4	4.5-4 NH	0.25000	0.16238	5.4611	5.5111	0.0500	5.6235	5.6485	0.0250	5.7859
5	4	5-4 NH	0.25000	0.16238	5.9602	6.0102	0.0500	6.1226	6.1476	0.0250	6.2850
6	4	6-4 NH	0.25000	0.16238	6.7252	6.7752	0.0500	6.8876	6.9126	0.0250	7.0500
8	4	8-4 NH	0.25000	0.16238	8.7252	8.7752	0.0500	8.8876	8.9126	0.0250	9.0500

¹All other values are in inches.

²Dimensions for the minimum major diameter of the coupling correspond to the basic flat $p/8$, and the profile at the major diameter produced by a worn tool must not fall below the basic outline. The maximum major diameter of the coupling shall be that corresponding to a flat at the major diameter of the maximum coupling equal to $p/24$ and can be determined by adding $11h/9$ (or $0.7939p$) to the maximum pitch diameter of the coupling.

Table 5.5.1.2 Lead and Half-Angle Deviations Consuming One-Half of Pitch-Diameter Tolerances for NH Threads

Nominal Size of Connection	Thread per Inch (tpi) ¹	Thread Designation (NH) ¹	Pitch-Diameter Tolerance ²	Lead Deviation Consuming One-Half of Pitch-Diameter Tolerance ³	Half-Angle Deviation Consuming One-Half of Pitch-Diameter Tolerance ¹	
					Degree	Minute
¾	8	0.75-8 NH	0.0111	0.0032	1	42
1	8	1-8 NH	0.0111	0.0032	1	42
1½	9	1.5-9 NH	0.0111	0.0032	1	54
2½	7.5	2.5-7.5 NH	0.0160	0.0046	2	17
3	6	3-6 NH	0.0180	0.0052	2	4
3½	6	3.5-6 NH	0.0180	0.0052	2	4
4	4	4-4 NH	0.0250	0.0072	1	55
4½	4	4.5-4 NH	0.0250	0.0072	1	55
5	4	5-4 NH	0.0250	0.0072	1	55
6	4	6-4 NH	0.0250	0.0072	1	55
8	4	8-4 NH	0.0250	0.0072	1	55

¹All other values are in inches.

²The tolerances specified for pitch diameter include all deviations of pitch diameter, lead, and angle. The full tolerance cannot, therefore, be used on pitch diameter unless the lead and angle of the thread are perfect. The last two columns give, for information, the deviations in lead and in angle, each of which can be compensated for by half the pitch-diameter tolerance given in this column. If lead and angle deviations both exist to the amount tabulated, the pitch diameter of a nipple, for example, must be reduced by the full tolerance or it will not enter the GO gauge.

³Between any two threads not farther apart than the length of engagement.

5.5.3.1 The minimum minor diameter of a coupling shall be such as to result in a basic flat, $p/8$, at the crest when the pitch diameter of the coupling is at its minimum value.

5.6 Gauges and Gauging NH Threads.

5.6.1 The limits of size for the gauges to be used in the gauging of fire hose connections shall be as specified in Table 5.6.1(a), Table 5.6.1(b), and Table 5.6.1(c).


5.6.2 For these gauges, the allowable variation in lead between any two threads not farther apart than the length of

engagement shall be ± 0.0004 in. The allowable variation in half-angle of thread shall be ± 5 minutes.

5.6.3* Except as otherwise specified herein, the gauges and gauging practices shall conform to ANSI/ASME B1.2, *Gages and Gaging for Unified Inch Screw Threads*.

5.6.4* Adjustable thread ring gauges shall be set by means of threaded setting plug gauges, the dimensions of which are given in Table 5.6.1(a). Means of setting ring gauges shall be as specified in ANSI/ASME B1.2, *Gages and Gaging for Unified Inch Screw Threads*.

Table 5.6.1(a) Setting Thread Plug Limits of Size for NH Thread Ring Gauges¹


Nominal Size of Connection	Threads per Inch (tpi) ²	Thread Designation (NH) ²		X Truncated Setting Plugs						X Basic-Crest Setting Plugs ³	
				Plug for GO Thread Gauge			Plug for LO (NOT GO) Thread Gauge			Major Diameter	
				Major Diameter		Pitch Diameter	Major Diameter		Pitch Diameter	Plug for GO Thread Gauge	Plug for LO (NOT GO) Thread Gauge
				Truncated	Full		Truncated	Full			
Gauge Tolerance 				—	+	—	—	+	+	+	+
1	2	3	4	5	6	7	8	9	10	11	12
¾	8	0.75-8 NH	Max Min	1.3579 1.3572	1.3757 1.3750	1.2938 1.2934	1.3368 1.3361	1.3757 1.3750	1.2831 1.2827	1.3757 1.3750	1.3757 1.3750
1	8	1-8 NH	Max Min	1.3579 1.3572	1.3757 1.3750	1.2938 1.2934	1.3368 1.3361	1.3757 1.3750	1.2831 1.2827	1.3757 1.3750	1.3757 1.3750
1½	9	1.5-9 NH	Max Min	1.9742 1.9735	1.9907 1.9900	1.9178 1.9174	1.9548 1.9541	1.9907 1.9900	1.9071 1.9067	1.9907 1.9900	1.9907 1.9900
2½	7.5	2.5-7.5 NH	Max Min	3.0507 3.0500	3.0693 3.0686	2.9820 2.9815	3.0237 3.0230	3.0693 3.0686	2.9665 2.9660	3.0693 3.0686	3.0693 3.0686
3	6	3-6 NH	Max Min	3.6029 3.6021	3.6247 3.6239	3.5156 3.5151	3.5698 3.5690	3.6247 3.6239	3.4981 3.4976	3.6247 3.6239	3.6247 3.6239
3½	6	3.5-6 NH	Max Min	4.2229 4.2216	4.2452 4.2439	4.1356 4.1350	4.1898 4.1885	4.2452 4.2439	4.1182 4.1176	4.2452 4.2439	4.2452 4.2439
4	4	4-4 NH	Max Min	4.9828 4.9813	5.0124 5.0109	4.8485 4.8479	4.9318 4.9303	5.0124 5.0109	4.8241 4.8235	5.0124 5.0109	5.0124 5.0109
4½	4	4.5-4 NH	Max Min	5.7328 5.7313	5.7624 5.7609	5.5985 5.5979	5.6818 5.6803	5.7624 5.7609	5.5741 5.5735	5.7624 5.7609	5.7624 5.7609
5	4	5-4 NH	Max Min	6.2319 6.2304	6.2615 6.2600	6.0976 6.0970	6.1809 6.1794	6.2615 6.2600	6.0732 6.0726	6.2615 6.2600	6.2615 6.2600
6	4	6-4 NH	Max Min	6.9969 6.9954	7.0265 7.0250	6.8626 6.8620	6.9459 6.9444	7.0265 7.0250	6.8382 6.8376	7.0265 7.0250	7.0265 7.0250
8	4	8-4 NH	Max Min	8.9969 8.9954	9.0265 9.0250	8.8626 8.8620	8.9459 8.9444	9.0265 9.0250	8.8382 8.8376	9.0265 9.0250	9.0265 9.0250

¹Gauge limit values in this table have been obtained in accordance with ANSI/ASME B1.2, *Gages and Gaging for Unified Inch Screw Threads*.

²All other values are in inches.

³Pitch-diameter limits for basic-crest GO setting plugs are the same as those shown in column 7. Pitch-diameter limits for basic-crest LO (NOT GO) setting plugs are the same as those shown in column 10.


Table 5.6.1(b) Gauge Limits of Size for Ring Gauges for NH External (Nipple) Threads¹

Nominal Size of Connection	Threads per Inch (tpi) ²	Thread Designation (NH) ²		X Thread Ring Gauges				Z Plain Ring Gauges	
				GO		LO (NOT GO)		Major Diameter	
				Pitch Diameter	Minor Diameter	Pitch Diameter	Minor Diameter	GO	NOT GO
Gauge Tolerance 				—	—	+	+	—	—
1	2	3	4	5	6	7	8	9	10
¾	8	0.75-8 NH	Max Min	1.2938 1.2934	1.2246 1.2239	1.2831 1.2827	1.2563 1.2556	1.37500 1.37488	1.35292 1.35280
1	8	1-8 NH	Max Min	1.2938 1.2934	1.2246 1.2239	1.2831 1.2827	1.2563 1.2556	1.37500 1.37488	1.35292 1.35280
1½	9	1.5-9 NH	Max Min	1.9178 1.9174	1.8577 1.8570	1.9071 1.9067	1.8833 1.8826	1.99000 1.98984	1.96796 1.96780
2½	7.5	2.5-7.5 NH	Max Min	2.9820 2.9815	2.9104 2.9097	2.9665 2.9660	2.9378 2.9371	3.06860 3.06840	3.03680 3.03660
3	6	3-6 NH	Max Min	3.5156 3.5151	3.4223 3.4215	3.4981 3.4976	3.4623 3.4615	3.62390 3.62370	3.58810 3.58790
3½	6	3.5-6 NH	Max Min	4.1356 4.1350	4.0473 4.0460	4.1182 4.1176	4.0828 4.0815	4.24390 4.24370	4.20810 4.20790
4	4	4-4 NH	Max Min	4.8485 4.8479	4.7111 4.7096	4.8241 4.8235	4.7709 4.7694	5.01090 5.01065	4.96115 4.96090
4½	4	4.5-4 NH	Max Min	5.5985 5.5979	5.4611 5.4596	5.5741 5.5735	5.5209 5.5194	5.76090 5.76065	5.71115 5.71090
5	4	5-4 NH	Max Min	6.0976 6.0970	5.9602 5.9587	6.0732 6.0726	6.0200 6.0185	6.26000 6.25975	6.21025 6.21000
6	4	6-4 NH	Max Min	6.8626 6.8620	6.7252 6.7237	6.8382 6.8376	6.7850 6.7835	7.02500 7.02468	6.97532 6.97500
8	4	8-4 NH	Max Min	8.8626 8.8620	8.7252 8.7237	8.8382 8.8376	8.7850 8.7835	9.02500 9.02468	8.97532 8.97500

¹Gauge limit values in this table have been obtained in accordance with ANSI/ASME B1.2, *Gages and Gaging for Unified Inch Screw Threads*, except for the values shown in column 6. The maximum values shown in column 6 are values for the minimum minor diameter of the internal thread.

²All other values are in inches.

Table 5.6.1(c) Gauge Limits of Size for Plug Gauges for NH Internal (Coupling) Threads¹

Nominal Size of Connection	Threads per Inch (tpi) ²	Thread Designation (NH) ²		X Thread Plug Gauges				Z Plain Plug Gauges	
				GO		HI (NOT GO)		Minor Diameter	
				Major Diameter	Pitch Diameter	Major Diameter	Pitch Diameter	GO	NOT GO
Gauge Tolerance 				+	+	—	—	+	—
1	2	3	4	5	6	7	8	9	10
¾	8	0.75-8 NH	Max Min	1.3877 1.3870	1.3062 1.3058	1.3710 1.3703	1.3169 1.3165	1.22472 1.22460	1.24680 1.24668
1	8	1-8 NH	Max Min	1.3877 1.3870	1.3062 1.3058	1.3710 1.3703	1.3169 1.3165	1.22472 1.22460	1.24680 1.24668
1½	9	1.5-9 NH	Max Min	2.0027 2.0020	1.9302 1.9298	1.9890 1.9883	1.9409 1.9405	1.85786 1.85770	1.87990 1.87974
2½	7.5	2.5-7.5 NH	Max Min	3.0843 3.0836	2.9975 2.9970	3.0707 3.0700	3.0130 3.0125	2.91060 2.91040	2.94240 2.94220
3	6	3-6 NH	Max Min	3.6397 3.6389	3.5311 3.5306	3.6208 3.6200	3.5486 3.5481	3.42250 3.42230	3.45830 3.45810
3½	6	3.5-6 NH	Max Min	4.2652 4.2639	4.1562 4.1556	4.2458 4.2445	4.1736 4.1730	4.04750 4.04730	4.08330 4.08310
4	4	4-4 NH	Max Min	5.0374 5.0359	4.8741 4.8735	5.0068 5.0053	4.8985 4.8979	4.71135 4.71110	4.76110 4.76085
4½	4	4.5-4 NH	Max Min	5.7874 5.7859	5.6241 5.6235	5.7568 5.7553	5.6485 5.6479	5.46135 5.46110	5.51110 5.51085
5	4	5-4 NH	Max Min	6.2865 6.2850	6.1232 6.1226	6.2559 6.2544	6.1476 6.1470	5.96045 5.96020	6.01020 6.00995
6	4	6-4 NH	Max Min	7.0515 7.0500	6.8882 6.8876	7.0209 7.0194	6.9126 6.9120	6.72552 6.72520	6.77520 6.77488
8	4	8-4 NH	Max Min	9.0515 9.0500	8.8882 8.8876	9.0209 9.0194	8.9126 8.9120	8.72552 8.72520	8.77520 8.77488

¹Gauge limit values in this table have been obtained in accordance with ANSI/ASME B1.2, *Gages and Gaging for Unified Inch Screw Threads*.

²All other values are in inches.

Chapter 6 Nonthreaded Connections

6.1* General. The requirements of Chapters 1 through 4 and the requirements of this chapter shall apply to nonthreaded connections in the 4 in. (100 mm) and 5 in. (125 mm) sizes.

6.2* Gauges.


6.2.1 The dimensional characteristics and tolerances for the metal-face gauges to be used in the gauging of nonthreaded connections shall be as specified in Figure 6.2.1(a) for a Type A test gauge and Figure 6.2.1(b) for a Type B test gauge.

6.2.2 In addition, the 4 in. (100 mm) metal-face gauge shall meet the dimensional characteristics of Figure 6.2.2(a), and the 5 in. (125 mm) metal-face gauge shall meet the dimensional characteristics of Figure 6.2.2(b).

6.3 Locks.

6.3.1* Nonthreaded connections shall be provided with locks within the confines of the nonthreaded connection to ensure against unintentional disconnection. Caps for use with nonthreaded connections shall be permitted without a lock.


6.3.2 The locks shall be located so that the nonthreaded connection will connect to the Type A metal-face test gauge and lock.



Note 1: All linear measurements in inches. Tolerances: .XXXX = ±0.002 in.

Note 2: All dimensions are to be the same for similar configurations on the gauge.

FIGURE 6.2.1(a) Dimensions for Type A Test Gauge (No Ramp Angle).



Note 1: All linear measurements in inches. Tolerances: .XXXX = ± 0.005 in.; .XXX = ± 0.002 in.

Note 2: All dimensions are to be the same for similar configurations on the gauge.

FIGURE 6.2.1(b) Dimensions for Type B Test Gauge (with Lugs Removed).

6.3.3 The locks shall be designed so as to lock automatically when connecting two nonthreaded connections without additional action needed to engage the locks. The lock shall not be capable of being secured (mechanically) in the open (unlocked) position.

6.3.4 The locks shall be field repairable.

6.3.5 The locks shall be designed so as to be disengaged by hand in a separate action other than that needed to disconnect the nonthreaded connection.

6.3.5.1 The locks shall be capable of being unlocked by a fire fighter wearing gloves meeting the requirements of NFPA 1971, *Standard on Protective Ensemble for Structural Fire Fighting*.


6.3.5.2 A device such as a wrench incorporating actions to disengage the lock and disconnect the nonthreaded connection in one motion shall be permitted to be used.

6.3.6 The lock mechanism shall not shear when a force of 300 lb \times ft (407 N \times m) is applied at the nut on the test wrench.

6.4 Indicators. Permanent indicators, obvious to sight and touch, shall be located at two points 180 degrees apart, as shown on Figure 6.2.2(a) and Figure 6.2.2(b), to indicate the fully engaged position of the connections.

6.5 Force to Connect and Disconnect.

6.5.1* All nonthreaded pressure connections shall be capable of connection and disconnection to both the Type A and the Type B metal-face test gauges at a force of between 6.0 lb \times in. (0.68 N \times m) and 30 lb \times in. (3.4 N \times m) when measured as described in 6.5.3 and under the conditions described in 6.5.4. The force to connect and disconnect nonthreaded pressure connections to each other shall not exceed 40 lb \times in. (4.5 N \times m) when measured as described in 6.5.3 and under the conditions described in 6.5.4.



Note: All dimensions are to be the same for similar configurations on the gauge.

FIGURE 6.2.2(a) End View of 4 in. (100 mm) Metal-Face Gauge and Nonthreaded 4 in. (100 mm) Connections.


6.5.2 All nonthreaded suction connections shall be capable of connection and disconnection to both the Type A and the Type B metal-face test gauges at a force of between 168 lb × in. (19.0 N × m) and 312 lb × in. (35.3 N × m) when measured as described in 6.5.3 and under the conditions described in 6.5.4. The force to connect and disconnect nonthreaded suction connections to each other shall not exceed 360 lb × in. (40.7 N × m) when measured as described in 6.5.3 and under the conditions described in 6.5.4.

6.5.3* The force to connect and disconnect shall be tested as follows.

6.5.3.1 One of the metal-face test gauges, or one-half of a pressure or suction connector, depending on the force to be checked, shall be secured in a vise or similar device. The connector to be tested shall be free to turn without constraint or assistance.

6.5.3.2 For 4 in. (100 mm) connectors, a test wrench with dimensions as shown in Figure 6.5.3.2(a) shall be attached over the external lugs of the connector being tested. For 5 in. (125 mm) connectors, a test wrench with dimensions as shown in Figure 6.5.3.2(b) shall be attached over the external lugs of the connector to be tested.

6.5.3.3 A standard torque wrench measuring inch-pounds shall be connected to the test wrench.



Note: All dimensions are to be the same for similar configurations on the gauge.

FIGURE 6.2.2(b) End View of 5 in. (125 mm) Metal-Face Gauge and Nonthreaded 5 in. (125 mm) Connections.

6.5.3.4 The torque wrench shall be moved in the direction necessary to connect or disconnect the connector being tested.

6.5.3.4.1 The lock shall be held open only when the connector is being disconnected.

6.5.3.4.2 The torque wrench shall be in direct line with the center of the connector when the torque reading is being taken.

6.5.4 The force to connect and disconnect test shall be done at 70°F (21°C) ambient temperature. The gaskets shall be clean but not lubricated.


6.6 Caps. All nonthreaded caps shall have suction gaskets installed.

6.7 Adapters. All nonthreaded adapters shall have pressure gaskets installed.

6.8 Metal-Face Hydrant Connections.

6.8.1 All nonthreaded, metal-face hydrant connections shall be made to the dimensions specified in Figure 6.8.1.

6.8.2 In addition, 4 in. (100 mm) metal-face hydrant connections shall meet the dimensional characteristics of Figure 6.2.2(a), and the 5 in. (125 mm) metal-face connections shall meet the dimensional characteristics of Figure 6.2.2(b).



Note 1: All linear dimensions in inches. Tolerances: .XXXX = ± 0.002 in.; .XXX = ± 0.005 in.

Note 2: Attachment to hydrant — as specified by purchaser.

Note 3: All dimensions are to be the same for similar configurations on the hydrant connection.

FIGURE 6.8.1 Metal-Face Hydrant Connection Showing Required Dimensions.

Chapter 7 Gaskets

7.1 Threaded Coupling Gasket.

7.1.1 Each internal connection shall be provided with a resilient thread gasket that does not leak under normal use when fitted accurately in the seat specified in this standard.

7.1.2 Each thread gasket shall meet the dimensions specified in Table 7.1.2.

7.1.3 The durometer of the thread gasket shall be 70 ± 5 Shore A.

7.2 Nonthreaded Coupling Gaskets.

7.2.1 Each nonthreaded connection shall be fitted with a resilient face gasket that does not leak under normal use.

7.2.2 The durometer of the gasket shall be 70 ± 5 Shore A.

7.2.3 The face gasket shall be either a suction gasket or a pressure gasket, depending on the application in which the coupling is to be used.

7.2.3.1 Pressure gaskets shall be designed to withstand the pressure requirements of Sections 4.6 and 4.10 without leakage. They shall be black in color.

7.2.3.2 Suction gaskets shall be designed to allow couplings equipped with the gasket to meet the requirements of Section 4.11. They shall be gray in color.

7.3* Tail Gasket.

7.3.1 Each coupling that is installed on a fire hose with an expansion ring shall be equipped with a resilient gasket of durometer 60 ± 5 Shore A in the hose bowl that keeps the ends of the fabric of the fire hose dry.

7.3.2 The nominal dimensions of these gaskets shall be as follows:

- (1) Minimum inside diameter as specified in Table 7.1.2
- (2) Outside diameter to accurately fit the recess provided
- (3) Thickness $\frac{3}{16}$ in. (4.8 mm) minimum

Table 7.1.2 Dimensions of Thread Gaskets for Standard Internal Threaded Connections

Nominal Size of Connection	Inside Diameter	Outside Diameter	Thickness
$\frac{3}{4}$	$1\frac{1}{16}$ (20.6)	$1\frac{7}{16}$ (36.5)	$\frac{1}{8}$ (3.18)
1	$1\frac{1}{16}$ (27)	$1\frac{7}{16}$ (36.5)	$\frac{1}{8}$ (3.18)
$1\frac{1}{2}$	$1\frac{9}{16}$ (40)	$2\frac{1}{16}$ (52)	$\frac{1}{8}$ (3.18)
$2\frac{1}{2}$	$2\frac{9}{16}$ (65)	$3\frac{3}{16}$ (81)	$\frac{3}{16}$ (4.8)
3	$3\frac{1}{16}$ (78)	$3\frac{3}{4}$ (95)	$\frac{1}{4}$ (6.4)
$3\frac{1}{2}$	$3\frac{9}{16}$ (91)	$4\frac{3}{8}$ (111)	$\frac{1}{4}$ (6.4)
4	$4\frac{1}{16}$ (103)	$5\frac{1}{8}$ (130)	$\frac{1}{4}$ (6.4)
$4\frac{1}{2}$	$4\frac{9}{16}$ (117)	$5\frac{7}{8}$ (149)	$\frac{1}{4}$ (6.4)
5	$5\frac{1}{16}$ (129)	$6\frac{3}{8}$ (162)	$\frac{1}{4}$ (6.4)
6	$6\frac{1}{16}$ (154)	$7\frac{1}{8}$ (181)	$\frac{1}{4}$ (6.4)
8	$8\frac{1}{16}$ (205)	$9\frac{1}{8}$ (232)	$\frac{1}{4}$ (6.4)

Note: All dimensions are in inches (mm).

Chapter 8 Use of NH Threads and Nonthreaded Connections

8.1* Hose Coupling Threads.

8.1.1* $\frac{3}{4}$ in. and 1 in. (19 mm and 25 mm) Hose. All $\frac{3}{4}$ in. and 1 in. (19 mm and 25 mm) hose shall be provided with couplings having the 0.75-8 NH standard thread and 1-8 NH standard thread, respectively.

8.1.2 $1\frac{1}{2}$ in. through 2 in. (38 mm through 52 mm) Fire Hose. All $1\frac{1}{2}$ in. through 2 in. (38 mm through 52 mm) fire hose shall be provided with couplings having the 1.5-9 NH standard thread.

8.1.3 $2\frac{1}{2}$ in. (65 mm) Fire Hose. All $2\frac{1}{2}$ in. (65 mm) fire hose shall be provided with couplings having the 2.5-7.5 NH standard thread.

8.1.4 3 in. (75 mm) Fire Hose. All 3 in. (75 mm) fire hose shall be provided with couplings having the 2.5-7.5 NH standard thread for interchangeability with $2\frac{1}{2}$ in. (65 mm) fire hose.

8.1.4.1 Where interchangeability with $2\frac{1}{2}$ in. (65 mm) fire hose is not a factor, the couplings shall be permitted to have the 3-6 NH standard thread.

8.1.5 $3\frac{1}{2}$ in. (90 mm) Fire Hose. All $3\frac{1}{2}$ in. (90 mm) fire hose shall be provided with couplings having the 3.5-6 NH standard thread.

8.1.5.1 Where interchangeability with 3 in. (75 mm) fire hose or other connections is required, the couplings shall be permitted to have the 3-6 NH standard thread.

8.1.6 4 in. (100 mm) Fire Hose. All 4 in. (100 mm) fire hose shall be provided with couplings having the 4-4 NH standard thread.

8.1.6.1 Where interchangeability with $3\frac{1}{2}$ in. (90 mm) fire hose or other connections is required, the couplings shall be permitted to have the 3.5-6 NH standard thread.

8.1.6.2 Where the authority having jurisdiction permits, 4 in. (100 mm) nonthreaded couplings shall be permitted to be used.

8.1.7 $4\frac{1}{2}$ in. (114 mm) Fire Hose. All $4\frac{1}{2}$ in. (114 mm) fire hose shall be provided with couplings having the 4.5-4 NH standard thread.

8.1.7.1 Where interchangeability with 4 in. (100 mm) fire hose or other connections is required, the couplings shall be permitted to have the 4-4 NH standard thread.

8.1.8 5 in. (125 mm) Fire Hose. All 5 in. (125 mm) fire hose shall be provided with couplings having the 5-4 NH standard thread.

8.1.8.1 Where interchangeability with $4\frac{1}{2}$ in. (114 mm) fire hose or other connections is required, the couplings shall be permitted to have the 4.5-4 NH standard thread.

8.1.8.2 Where the authority having jurisdiction permits, 5 in. (125 mm) nonthreaded couplings shall be permitted to be used.

8.1.9 6 in. (150 mm) Fire Hose. All 6 in. (150 mm) fire hose shall be provided with couplings having the 6-4 NH standard thread.

8.1.9.1 Where interchangeability with 5 in. (125 mm) fire hose or other connections is required, the couplings shall be permitted to have the 5-4 NH standard thread.

8.1.10 8 in. (200 mm) Fire Hose. All 8 in. (200 mm) fire hose shall be provided with couplings having the 8-4 NH standard thread.

8.1.11* Hard Suction Hose. Hard suction hose shall be provided with couplings having the NH standard thread compatible with the nominal size of the hard suction hose.

8.2* Connections for Fire Service Nozzles for Handlines.

8.2.1 Playpipes for connecting shutoff nozzles to $2\frac{1}{2}$ in. (65 mm) fire hose shall have the 2.5-7.5 NH standard thread at the base or primary inlet and the 1.5-9 NH standard thread at the discharge end, as shown in Figure 8.2.1.

8.2.2 Nozzle shutoff valves for either $2\frac{1}{2}$ in. (65 mm) nozzles or $1\frac{1}{2}$ in. (38 mm) nozzles shall have the 1.5-9 NH standard thread for both the inlet and discharge sides of the valve, as shown in Figure 8.2.1 for $2\frac{1}{2}$ in. (65 mm) and Figure 8.2.2 for $1\frac{1}{2}$ in. (38 mm).

8.2.2.1 Where the valve is an integral nondetachable part of a $2\frac{1}{2}$ in. (65 mm) playpipe, the 1.5-9 NH standard thread shall be provided only on the discharge side of the valve.

8.2.3 All nozzles used on booster hose shall have the 1-8 NH standard thread.




FIGURE 8.2.1 Nozzle Assembly for 2½ in. (65 mm) Hose.




FIGURE 8.2.2 Nozzle Assembly for 1½ in. (38 mm) Hose.

8.2.4 All nozzle tips for use on 2½ in. (65 mm) and 1½ in. (38 mm) nozzles shall have the 1.5-9 NH standard thread.

8.2.5* All spray nozzles with a shutoff valve for use on 1½ in. (38 mm) and 2½ in. (65 mm) hose where flows at rated pressure do not exceed 400 gpm (1600 L/min) shall have at least 1.5-9 NH standard thread at the internal connection.

8.3 Connections for Large-Stream Devices.

8.3.1* Primary Inlet. At least one inlet connection on each fire department large-stream device equipped with multiple primary inlets (other than devices piped permanently to a pump) shall be fitted with at least one female swivel connection, which shall have 2.5-7.5 NH standard thread as shown in Figure 8.3.1(a) and Figure 8.3.1(b). An adapter shall be permitted to be provided to meet this intent.

8.3.2* Subsequent Connections and Nozzles.




FIGURE 8.3.1(a) Large-Stream Device Rated Under 1250 gpm (5000 L/min).




FIGURE 8.3.1(b) Large-Stream Device Rated Over 1250 gpm (5000 L/min) But Less Than 3000 gpm (12,000 L/min).

8.3.2.1 The discharge end of large-stream devices designed to discharge from 400 gpm to 1250 gpm (1600 L/min to 5000 L/min) shall have the 2.5-7.5 NH thread for attaching straight tip nozzle tips or spray nozzles.

8.3.2.1.1 If stacked straight tip nozzles are used, one of the tips shall have the 1.5-9 NH thread as shown in Figure 8.3.1(a).

8.3.2.1.2 Straight tip nozzles and spray nozzles designed to discharge between 400 gpm and 1250 gpm (1600 L/min and 5000 L/min) shall have 2.5-7.5 NH thread on their inlet.

8.3.2.2 The discharge end of large-stream devices designed to discharge in excess of 1250 gpm (5000 L/min) but less than 3000 gpm (12,000 L/min) shall have the 3.5-6 NH thread for attaching straight tip nozzles or spray nozzles.

8.3.2.2.1 A 3.5-6 NH female × 2.5-7.5 NH male reducer fitting, or a stacked tip having the male 2.5-7.5 NH thread as an integral component as shown in Figure 8.3.1(b) shall be provided.

8.3.2.2.2 Straight tip nozzles and spray nozzles designed to discharge flows in excess of 1250 gpm (5000 L/min) but less than 3000 gpm (12,000 L/min) shall have 3.5-6 NH thread on their inlet.

8.3.2.3 Subsequent connections, straight tip nozzles, and spray nozzles on large-stream devices designed to discharge 3000 gpm (12,000 L/min) or more shall have an NH standard thread consistent with the nominal inlet or outlet size.

Annex A Explanatory Material

Annex A is not a part of the requirements of this NFPA document but is included for informational purposes only. This annex contains explanatory material, numbered to correspond with the applicable text paragraphs.

A.1.1 Some fire-fighting organizations use small hose less than $\frac{3}{4}$ in. (19 mm) nominal diameter fitted with garden hose couplings. Such couplings should have 0.75-11.5 NH (garden hose thread) threads conforming to ANSI/ASME B1.20.7, *Standard on Hose Coupling Screw Threads*.

A.3.2.1 Approved. The National Fire Protection Association does not approve, inspect, or certify any installations, procedures, equipment, or materials; nor does it approve or evaluate testing laboratories. In determining the acceptability of installations, procedures, equipment, or materials, the authority having jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure, or use. The authority having jurisdiction may also refer to the listings or labeling practices of an organization that is concerned with product evaluations and is thus in a position to determine compliance with appropriate standards for the current production of listed items.

A.3.2.2 Authority Having Jurisdiction (AHJ). The phrase “authority having jurisdiction,” or its acronym AHJ, is used in NFPA documents in a broad manner, since jurisdictions and approval agencies vary, as do their responsibilities. Where pub-

lic safety is primary, the authority having jurisdiction may be a federal, state, local, or other regional department or individual such as a fire chief; fire marshal; chief of a fire prevention bureau, labor department, or health department; building official; electrical inspector; or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the authority having jurisdiction. In many circumstances, the property owner or his or her designated agent assumes the role of the authority having jurisdiction; at government installations, the commanding officer or departmental official may be the authority having jurisdiction.

A.4.1 Figure A.4.1(a) shows an expansion ring coupling set for a set of threaded couplings. Figure A.4.1(b) shows a typical nonthreaded fire hose connection that connects to the fire hose with a tailpiece and external reattachable collar.

A.5.1.5 Blunt starts are required on the entering ends of the NH screw thread on all sizes of fire hose connections that meet the requirements of NFPA 1963. The blunt start is formed by cutting off the entering ends of the screw threads completely to where, at the blunt start, the dimension from the face of the connection to the root of the start of the second thread is as specified in Table 5.4.2 (Column I for external threads and Column J for internal threads), as illustrated in Figure 5.1.5.1.

When the entering threads are cut back as required, it forms a pilot on the male coupling and a counter bore in the female coupling, making it easier to align the connections and start the thread engagement.

When the starting ends of the threads are cut off, the following occur:

- (1) It takes fewer turns to connect the connection — over one turn less on a 2½ in. (65 mm) connection.
- (2) There are no threads at the ends of the connections to be damaged when dropped.
- (3) The sharp entering threads are gone, reducing cuts to hands.




FIGURE A.4.1(a) An Expansion Ring Coupling Set.




FIGURE A.4.1(b) A Nonthreaded Fire Hose Connection.

A good blunt start does the following:

- (1) Helps ream dirt out of the threads when a coupling has been dropped in the dirt
- (2) Prevents cross-threading
- (3) Makes it easier and faster to connect fire hose connections


A.5.2.1 American National Fire Hose Connection Screw Threads are also sometimes known by the abbreviations NST and NS.

A.5.6.3 See Figure A.5.6.3.

A.5.6.4 Note that setting plug gauges is necessary only for setting of adjustable thread ring gauges and for checking solid ring gauges.

A.6.1 Figure A.6.1 shows the names of the various parts of a nonthreaded coupling.

A.6.2 The Type A test gauge checks the distance from under the high point of the two ramps of a nonthreaded connection to the corresponding connection's gasket face, which is at the centerline between the gauge and the connection when they are connected. The Type B test gauge checks the distance from under the two lugs of a nonthreaded connection to the corresponding connection's gasket face, which is at the centerline between the gauge and the connection when they are connected.




[See Tables 5.6.1(b) and 5.6.1(c) for complete dimensions for these gauges.]

Note 1: The GO plain ring gauge and the GO plain plug gauge have not been included in this figure since the sharpness of the crests of the external and internal threads will be considered generally acceptable if the GO thread ring gauge and the GO thread plug gauge assemble on the two mating parts of the coupling.

Note 2: Internal threads are acceptable when the HI thread plug is applied to the coupling thread if (a) it does not enter, or if (b) all complete coupling threads can be entered, provided that a definite drag (from contact with the coupling material) results on or before the second turn of entry. The gauge should not be forced after the drag becomes definite.

Note 3: External threads are acceptable when the LO thread ring gauge is applied to the nipple thread if (a) it is not entered, or if (b) all complete nipple threads can be entered, provided that a definite drag (from contact with the nipple material) results from contact on or before the second turn of entry. The gauge should not be forced after the drag is definite.

FIGURE A.5.6.3 Gauges for 2.5-7.5 NH Threads.



Legend:

1. Circumferential O.D.: The largest outer diameter of connection that protects the connection from damage.
2. Coupling face: The front part of the connection from which dimensions are developed.
3. Internal lug: The two internal lugs with recesses that fit on the ramp under the face of the cam head.
4. Ramp: The inclined plane under the face of the cam head that, when turned clockwise, increases pressure on lip seals.
5. Lug stop: The stop at the end of the ramp that the internal lug comes against.
6. Lug recess: Recessed area where opposite internal lugs enter the ramp.
7. Cleaning port: Area on end of connection face where dirt is pushed in by mating lug.
8. External wrenching lug: The external ribs or lugs on back diameter of connection head.
9. External wrenching lug indicator: The identification on rib or lug that, when lined up together, indicates the connection is fully engaged.
10. Tail piece recess: The recess counterbore on the interface of the cam head that the tail piece rides in.
11. Lock: To keep the connection from becoming unintentionally disengaged.

FIGURE A.6.1 Diagram of a Nonthreaded Connection.

A.6.3.1 During the transition in a fire department from couplings without locks to couplings with locks, there will be times when hose will be coupled together with one coupling being a locking type and the other a nonlocking type. Because disconnection procedures are different for couplings with locks, consideration should be given to painting a ring in a distinctive color on the hose near the couplings with locks to alert the fire fighter to the presence of the lock.

A.6.5.1 The forces defined in this requirement are intended to provide nonthreaded connections that are able to be connected and disconnected easily by hand and without the use of wrenches when the connectors are not under pressure.

A.6.5.3 Figure A.6.5.3 shows an example of the setup and location of the torque wrench, test wrench, nonthreaded connector, and test gauge.




FIGURE A.6.5.3 Arrangement for Testing Nonthreaded Connections.

Other methods of measuring force to connect and disconnect can be used if they produce the same results. A second method of testing the force to connect and disconnect against the test gauges is to fit the metal-face gauge with a plug that has a hex head connection for the torque wrench on the back side of the gauge at the center of rotation. The nonthreaded connector to be tested is then held stationary in a vise or similar device, and the metal-face gauge is mated to the nonthreaded connection with the torque wrench measuring the amount of force to connect and disconnect the two parts. When the force is measured at any point other than as defined in 6.5.3, the acceptable range of force values will need to be calculated for the position of the torque wrench.

A.7.3 It is important when ordering couplings and tail gaskets for recoupling hose with expansion ring couplings that the appropriate tail gasket be obtained. The coupling manufacturer needs the outside diameter of the hose and the wall thickness of the hose to provide the proper coupling and gasket. Also, the length of the expansion ring must be consistent with the length of the coupling bowl.

A.8.1 Where local fire hose coupling threads are not standard, swivel adapters, with the NH female thread and the local male thread, and with the local female thread and the NH male thread, should be carried on the apparatus, stored in hose houses, and so forth.

A.8.1.1 Some fire-fighting organizations use small hose less than $\frac{3}{4}$ in. (19 mm) nominal diameter fitted with garden hose couplings. Such couplings should have 0.75-11.5 NH (garden hose thread) threads conforming to ANSI/ASME B1.20.7, *Standard on Hose Coupling Screw Threads*.

A.8.1.11 Where the hydrant connections have local threads, adapters with the NH male thread and the local female thread for intake supply hose, and the NH female thread and the