

NFPA®

220

**Standard on
Types of Building Construction**

2018



IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

NOTICE AND DISCLAIMER OF LIABILITY CONCERNING THE USE OF NFPA STANDARDS

NFPA® codes, standards, recommended practices, and guides (“NFPA Standards”), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Standards.

The NFPA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Standards. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Standards available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Standards. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

REVISION SYMBOLS IDENTIFYING CHANGES FROM THE PREVIOUS EDITION

Text revisions are shaded. A **Δ** before a section number indicates that words within that section were deleted and a **Δ** to the left of a table or figure number indicates a revision to an existing table or figure. When a chapter was heavily revised, the entire chapter is marked throughout with the **Δ** symbol. Where one or more sections were deleted, a **•** is placed between the remaining sections. Chapters, annexes, sections, figures, and tables that are new are indicated with an **N**.

Note that these indicators are a guide. Rearrangement of sections may not be captured in the markup, but users can view complete revision details in the First and Second Draft Reports located in the archived revision information section of each code at www.nfpa.org/docinfo. Any subsequent changes from the NFPA Technical Meeting, Tentative Interim Amendments, and Errata are also located there.

REMINDER: UPDATING OF NFPA STANDARDS

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that NFPA Standards may be amended from time to time through the issuance of a Tentative Interim Amendment (TIA) or corrected by Errata. An official NFPA Standard at any point in time consists of the current edition of the document together with any TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of Tentative Interim Amendments or corrected by Errata, go to www.nfpa.org/docinfo to choose from the list of NFPA Standards or use the search feature to select the NFPA Standard number (e.g., NFPA 13). The document information page provides up-to-date document-specific information as well as postings of all existing TIAs and Errata. It also includes the option to register for an “Alert” feature to receive an automatic email notification when new updates and other information are posted regarding the document.

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

ADDITIONAL NOTICES AND DISCLAIMERS

Updating of NFPA Standards

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of Tentative Interim Amendments or corrected by Errata. An official NFPA Standard at any point in time consists of the current edition of the document together with any Tentative Interim Amendments and any Errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of Tentative Interim Amendments or corrected through the issuance of Errata, consult appropriate NFPA publications such as the National Fire Codes® Subscription Service, visit the NFPA website at www.nfpa.org, or contact the NFPA at the address listed below.

Interpretations of NFPA Standards

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing the Development of NFPA Standards shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Standard. The users of NFPA Standards bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Standards.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards (“the ANSI Patent Policy”), and hereby gives the following notice pursuant to that policy:

NOTICE: The user’s attention is called to the possibility that compliance with an NFPA Standard may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

Law and Regulations

Users of NFPA Standards should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

NFPA Standards are copyrighted. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Standards for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Standards, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA Standards and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA standards during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101; email: stds_admin@nfpa.org.

For more information about NFPA, visit the NFPA website at www.nfpa.org. All NFPA codes and standards can be viewed at no cost at www.nfpa.org/docinfo.

Copyright © 2017 National Fire Protection Association®. All Rights Reserved.

NFPA® 220

Standard on

Types of Building Construction

2018 Edition

This edition of NFPA 220, *Standard on Types of Building Construction*, was prepared by the Technical Committee on Building Construction. It was issued by the Standards Council on August 1, 2017, with an effective date of August 21, 2017, and supersedes all previous editions.

This edition of NFPA 220 was approved as an American National Standard on August 21, 2017.

Origin and Development of NFPA 220

In 1952, the Committee on Building Construction secured tentative adoption of NFPA 220, *Standard on Types of Building Construction*, at the NFPA Annual Meeting. At the 1954 NFPA Annual Meeting, revisions of the 1952 tentative text were adopted by the Association, and in 1955 minor revisions also were acted on favorably. A new definition of *noncombustibility* and editorial changes in the description of the fire resistance rating of structural members (under the definition of *fire-resistive construction*) were adopted at the 1956 NFPA Annual Meeting on the recommendation of the Committee on Building Construction.

In 1958, with the development of the use of plastics in building construction, recommendations on the types of standard fire tests to be used in evaluating the fire safety of these materials were adopted and inserted in the appendix.

In 1961, an appendix was adopted to furnish a guide to NFPA committees, regulatory officials, and others that addressed the classification of air-supported structures.

In 1975, a more fundamental definition of *noncombustible* was added, including the introduction of a definition of the term *limited-combustible* based on potential heat value limitations and more generalized definitions for types of building construction.

In 1979, the standard was extensively rewritten to introduce the nomenclature related to construction Type I through Type V, which included parenthetically placed hourly fire resistance designations of the structural components.

The 1985 edition included the addition of a new Chapter 4, which provided referenced publications whose use is mandated within this standard. The 1992 and 1995 editions provided changes in technical terminology as well as changes to increase the user-friendliness of the standard.

The 1999 edition implemented a number of relatively minor changes, including the addition of several new definitions, the addition of a new requirement pertaining to exterior non-load-bearing walls, and a new provision concerning the use of heavy timber exterior walls.

In the 2006 edition, NFPA 220 became an extract document of *NFPA 5000*®, Section 7.2. At the request of the Standards Council, the new edition provided users with a stand-alone set of requirements for construction types and fire resistance ratings of structural elements.

The 2009 edition provided updates to the extracted text that was sourced back to *NFPA 5000* and NFPA 90A. These revisions included updates to the test protocols used to establish flame spread/smoke developed index values, modified criteria for materials used in air handling plenum spaces, and provided recognition of the new criteria used to determine building height and grade geometries.

The 2012 edition was updated to reflect changes in *NFPA 5000* and NFPA 90A. Revisions included updates to the requirements for plenums and noncombustible materials.

The 2015 edition was revised to include new requirements for limited and noncombustible materials. Referenced publications were updated.

The 2018 edition includes updates to extracted material from *NFPA 5000*. Referenced publications have been updated.

Technical Committee on Building Construction

Renato R. Molina, *Chair*
JENSEN HUGHES, MD [SE]

Nasser Ahmed Al Zeyara, Qatar Civil Defense, Qatar [E]
Farid Alfawakhiri, American Iron and Steel Institute, IL [M]
Mark Chrisman, Henderson Engineers, KS [SE]
David S. Collins, The Preview Group, Inc., OH [SE]
Rep. American Institute of Architects
Richard J. Davis, FM Global, MA [I]
Richard L. Day, Michigan State Fire Marshal's Office, MI [E]
Alan J. Dopart, Willis of New Jersey, NJ [I]
Victor L. Dubrowski, Code Consultants, Inc., MO [SE]
Paul Ferro, Fire Department City of New York, NY [L]
Rep. International Association of Fire Fighters
David W. Frable, U.S. General Services Administration, IL [U]
Sam W. Francis, American Wood Council, PA [M]
James W. Gaut, Marriott Vacations Worldwide, FL [U]
Kurtis Grant, U.S. Department of Health & Human Services, GA [E]
William J. Hall, Portland Cement Association, VA [M]

Robert E. Hanson, Savannah River Nuclear Solutions, GA [U]
Khaled Heiza, Monofia University, Egypt [SE]
Joseph T. Holland, Hoover Treated Wood Products, FL [M]
Jeffrey M. Hugo, National Fire Sprinkler Association, Inc., MI [M]
Aaron Johnson, Rural/Metro Corporation, FL [E]
Dale Litton, Texas Instruments, Inc., TX [U]
Rep. Semiconductor Industry Association
Vickie J. Lovell, InterCode Incorporated, FL [M]
Rep. Fire Safe North America
Joe McElvaney, City of Phoenix Fire Department, AZ [E]
Thomas W. McKeon, Everest National Insurance, NJ [I]
Brad Schiffer, Brad Schiffer/Taxis, Inc., FL [SE]
Michael Schmeida, Gypsum Association, OH [M]
Joseph H. Versteeg, Versteeg Associates, CT [E]
Rep. International Fire Marshals Association
Peter J. Willse, XL Global Asset Protection Services, CT [I]
Luke C. Woods, UL LLC, MA [RT]

Alternates

David G. Bueche, Hoover Treated Wood Products, CO [M]
(Alt. to Joseph T. Holland)
Paul D. Coats, American Wood Council, SC [M]
(Alt. to Sam W. Francis)
James M. Dalton, Chicago Fire Department, IL [L]
(Alt. to Paul Ferro)
Jonathan Humble, American Iron and Steel Institute, CT [M]
(Alt. to Farid Alfawakhiri)

William E. Koffel, Koffel Associates, Inc., MD [U]
(Alt. to Dale Litton)
Edward R. LaPine, JENSEN HUGHES/AON, AZ [SE]
(Alt. to Renato R. Molina)
Richard N. Walke, UL LLC, IL [RT]
(Alt. to Luke C. Woods)

Valerie Boutin, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This committee shall have primary responsibility for documents on the selection and design of types of building construction, exterior walls, building height and area, firewalls, and fire barrier walls, as they relate to the protection of life and property from fire. For the processing of *NFPA 5000*, Chapter 7, and Sections 8.3 and 8.4, this committee reports directly to the *NFPA 5000* Correlating Committee; whereas, for the processing of NFPA 220 and NFPA 221, this committee does not report to the *NFPA 5000* Correlating Committee.

Contents

Chapter 1	Administration	220– 5	Chapter 4	Types of Construction	220– 6
1.1	Scope.	220– 5	4.1	General.	220– 6
1.2	Purpose.	220– 5	4.2	Reserved.	220– 8
1.3	Application. (Reserved)	220– 5	4.3	Type I (442 or 332) and Type II (222, 111, or 000) Construction.	220– 8
1.4	Retroactivity.	220– 5	4.4	Type III (211 or 200) Construction.	220– 9
1.5	Equivalency.	220– 5	4.5	Type IV (2HH) Construction.	220– 9
1.6	Units.	220– 5	4.6	Type V (111 or 000) Construction.	220– 11
Chapter 2	Referenced Publications	220– 5	Chapter 5	Fire Resistance Rating Requirements for Structural Elements	220– 11
2.1	General.	220– 5	5.1	Fire Resistance Rating Requirements.	220– 11
2.2	NFPA Publications.	220– 5	Annex A	Explanatory Material	220– 12
2.3	Other Publications.	220– 6	Annex B	Informational References	220– 13
2.4	References for Extracts in Mandatory Sections.	220– 6	Index	220– 14
Chapter 3	Definitions	220– 6			
3.1	General.	220– 6			
3.2	NFPA Official Definitions.	220– 6			
3.3	General Definitions.	220– 6			

NFPA 220

Standard on

Types of Building Construction

2018 Edition

IMPORTANT NOTE: This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notices and Disclaimers Concerning NFPA Standards.” They can also be viewed at www.nfpa.org/disclaimers or obtained on request from NFPA.

UPDATES, ALERTS, AND FUTURE EDITIONS: New editions of NFPA codes, standards, recommended practices, and guides (i.e., NFPA Standards) are released on scheduled revision cycles. This edition may be superseded by a later one, or it may be amended outside of its scheduled revision cycle through the issuance of Tentative Interim Amendments (TIAs). An official NFPA Standard at any point in time consists of the current edition of the document, together with all TIAs and Errata in effect. To verify that this document is the current edition or to determine if it has been amended by TIAs or Errata, please consult the National Fire Codes® Subscription Service or the “List of NFPA Codes & Standards” at www.nfpa.org/docinfo. In addition to TIAs and Errata, the document information pages also include the option to sign up for alerts for individual documents and to be involved in the development of the next edition.

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. As an aid to the user, the complete title and edition of the source documents for extracts in mandatory sections of the document are given in Chapter 2 and those for extracts in informational sections are given in Annex B. Extracted text may be edited for consistency and style and may include the revision of internal paragraph references and other references as appropriate. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced publications can be found in Chapter 2 and Annex B.

Chapter 1 Administration

1.1* Scope. This standard defines types of building construction based on the combustibility and the fire resistance rating of a building's structural elements. Fire walls, nonbearing exterior walls, nonbearing interior partitions, fire barrier walls, shaft enclosures, and openings in walls, partitions, floors, and roofs are not related to the types of building construction and are regulated by other standards and codes, where appropriate.

1.2 Purpose. This standard provides definitions for standard types of building construction.

1.3 Application. (Reserved)

1.4 Retroactivity.

1.4.1 The provisions of this standard reflect a consensus of what is necessary to provide an acceptable degree of protection

from the hazards addressed in this standard at the time the standard was issued.

1.4.2 Unless otherwise specified, the provisions of this standard shall not apply to facilities, equipment, structures, or installations that existed or were approved for construction or installation prior to the effective date of the standard. Where specified, the provisions of this standard shall be retroactive.

1.4.3 In those cases where the authority having jurisdiction determines that the existing situation presents an unacceptable degree of risk, the authority having jurisdiction shall be permitted to apply retroactively any portions of this standard deemed appropriate.

1.4.4 The retroactive requirements of this standard shall be permitted to be modified if their application clearly would be impractical in the judgment of the authority having jurisdiction, and only where it is clearly evident that a reasonable degree of safety is provided.

1.5 Equivalency.

1.5.1 Nothing in this standard is intended to prevent the use of systems, methods, or devices of equivalent or superior quality, strength, fire resistance, effectiveness, durability, and safety over those prescribed by this standard.

1.5.2 Technical documentation shall be submitted to the authority having jurisdiction to demonstrate equivalency. The system, method, or device shall be approved for the intended purpose by the authority having jurisdiction.

1.6 Units.

1.6.1 SI Units. Metric units in this standard are in accordance with the modernized metric system known as the International System of Units (SI).

1.6.2 Primary and Equivalent Values. If a value for a measurement as given in this standard is followed by an equivalent value in other units, the first stated value shall be regarded as the requirement. A given equivalent value might be approximate.

Chapter 2 Referenced Publications

2.1 General. The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

2.2 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 90A, *Standard for the Installation of Air-Conditioning and Ventilating Systems*, 2018 edition.

NFPA 101®, *Life Safety Code®*, 2018 edition.

NFPA 285, *Standard Fire Test Method for Evaluation of Fire Propagation Characteristics of Exterior Non-Load-Bearing Wall Assemblies Containing Combustible Components*, 2012 edition.

NFPA 5000®, *Building Construction and Safety Code®*, 2018 edition.

2.3 Other Publications.

Δ **2.3.1 ASTM Publications.** ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

ASTM E84, *Standard Test Method for Surface Burning Characteristics of Building Materials*, 2015a.

ASTM E119, *Standard Test Methods for Fire Tests of Building Construction and Materials*, 2014.

ASTM E136, *Standard Test Method for Behavior of Materials in a Vertical Tube Furnace at 750°C*, 2012.

ASTM E2652, *Standard Test Method for Behavior of Materials in a Tube Furnace with a Cone-shaped Airflow Stabilizer, at 750°C*, 2012.

2.3.2 UL Publications. Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096.

ANSI/UL 263, *Standard for Fire Tests of Building Construction and Materials*, 2003, revised 2015.

ANSI/UL 723, *Standard for Test for Surface Burning Characteristics of Building Materials*, 2008, revised 2013.

2.3.3 Other Publications.

Merriam-Webster's Collegiate Dictionary, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

2.4 References for Extracts in Mandatory Sections.

NFPA 5000®, *Building Construction and Safety Code*®, 2018 edition.

Chapter 3 Definitions

3.1* General. The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not defined in this chapter or within another chapter, they shall be defined using their ordinarily accepted meanings within the context in which they are used. *Merriam-Webster's Collegiate Dictionary*, 11th edition, shall be the source for the ordinarily accepted meaning.

3.2 NFPA Official Definitions.

3.2.1* Approved. Acceptable to the authority having jurisdiction.

3.2.2* Authority Having Jurisdiction (AHJ). An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.

3.2.3* Listed. Equipment, materials, or services included in a list published by an organization that is acceptable to the authority having jurisdiction and concerned with evaluation of products or services, that maintains periodic inspection of production of listed equipment or materials or periodic evaluation of services, and whose listing states that either the equipment, material, or service meets appropriate designated standards or has been tested and found suitable for a specified purpose.

3.2.4 Shall. Indicates a mandatory requirement.

3.2.5 Should. Indicates a recommendation or that which is advised but not required.

3.2.6 Standard. An NFPA Standard, the main text of which contains only mandatory provisions using the word "shall" to indicate requirements and that is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions are not to be considered a part of the requirements of a standard and shall be located in an appendix, annex, footnote, informational note, or other means as permitted in the NFPA Manuals of Style. When used in a generic sense, such as in the phrase "standards development process" or "standards development activities," the term "standards" includes all NFPA Standards, including Codes, Standards, Recommended Practices, and Guides.

3.3 General Definitions.

3.3.1 Fire Resistance Rating. The time, in minutes or hours, that materials or assemblies have withstood a fire exposure as determined by the tests, or methods based on tests, prescribed by this standard. [5000, 2018].

3.3.2* Flame Spread Index. A number obtained according to ASTM E84, *Standard Test Method for Surface Burning Characteristics of Building Materials*, or ANSI/UL 723, *Standard for Test for Surface Burning Characteristics of Building Materials*.

3.3.3 Limited-Combustible Material. See 4.1.6.

3.3.4 Noncombustible Material. See 4.1.5.

Chapter 4 Types of Construction

4.1 General. [5000:7.2.1]

4.1.1* Buildings and structures shall be classified according to their type of construction, which shall be based upon one of five basic types of construction designated as Type I, Type II, Type III, Type IV, and Type V, with fire resistance ratings not less than those specified in Table 4.1.1 and Sections 4.3 through 4.6, and with fire resistance ratings meeting the requirements of Chapter 5. [5000:7.2.1.1]

4.1.2 Where two or more types of construction are used in the same building, the entire building shall be classified as the least type of construction in the building and shall be subject to the requirements for that type, except as permitted by other provisions of NFPA 5000. [5000:7.2.1.2]

4.1.3 Requirements for specific materials, types of construction, and fire protection shall be minimum requirements, and any material, type of construction, or fire protection affording safety or a fire resistance rating equal to or greater than that provided in NFPA 5000, shall be permitted. [5000:7.2.1.3]

Δ **4.1.4** Materials shall be in accordance with all of the following, except as modified by any special requirements in Section 4.3:

- (1) NFPA 5000, Chapter 41, Concrete
- (2) NFPA 5000, Chapter 42, Aluminum
- (3) NFPA 5000, Chapter 43, Masonry
- (4) NFPA 5000, Chapter 44, Steel
- (5) NFPA 5000, Chapter 45, Wood
- (6) NFPA 5000, Chapter 46, Glass and Glazing
- (7) NFPA 5000, Chapter 47, Gypsum Board, Lath, and Plaster
- (8) NFPA 5000, Chapter 48, Plastics

[5000:7.2.1.4]

Table 4.1.1 Fire Resistance Ratings for Type I through Type V Construction (hr)

Construction Element	Type I		Type II			Type III		Type IV	Type V	
	442	332	222	111	000	211	200	2HH	111	000
Exterior Bearing Walls^a										
Supporting more than one floor, columns, or other bearing walls	4	3	2	1	0 ^b	2	2	2	1	0 ^b
Supporting one floor only	4	3	2	1	0 ^b	2	2	2	1	0 ^b
Supporting a roof only	4	3	1	1	0 ^b	2	2	2	1	0 ^b
Interior Bearing Walls										
Supporting more than one floor, columns, or other bearing walls	4	3	2	1	0	1	0	2	1	0
Supporting one floor only	3	2	2	1	0	1	0	1	1	0
Supporting roofs only	3	2	1	1	0	1	0	1	1	0
Columns										
Supporting more than one floor, columns, or other bearing walls	4	3	2	1	0	1	0	H	1	0
Supporting one floor only	3	2	2	1	0	1	0	H	1	0
Supporting roofs only	3	2	1	1	0	1	0	H	1	0
Beams, Girders, Trusses, and Arches										
Supporting more than one floor, columns, or other bearing walls	4	3	2	1	0	1	0	H	1	0
Supporting one floor only	2	2	2	1	0	1	0	H	1	0
Supporting roofs only	2	2	1	1	0	1	0	H	1	0
Floor-Ceiling Assemblies	2	2	2	1	0	1	0	H	1	0
Roof-Ceiling Assemblies	2	1½	1	1	0	1	0	H	1	0
Interior Nonbearing Walls	0	0	0	0	0	0	0	0	0	0
Exterior Nonbearing Walls^c	0 ^b	0 ^b	0 ^b	0 ^b	0 ^b	0 ^b	0 ^b	0 ^b	0 ^b	0 ^b

H: heavy timber members (see text for requirements).

^aSee NFPA 5000, 7.3.2.1.^bSee NFPA 5000, Section 7.3.^cSee 4.3.2.12, 4.4.2.3, and 4.5.6.8.

[5000: Table 7.2.1.1]

4.1.5 Noncombustible Material

Δ 4.1.5.1* A material that complies with any of the following shall be considered a noncombustible material:

- (1)* The material that, in the form in which it is used, and under the conditions anticipated, will not ignite, burn, support combustion, or release flammable vapors when subjected to fire or heat.
- (2) The material is reported as passing ASTM E136, *Standard Test Method for Behavior of Materials in a Vertical Tube Furnace at 750°C*.
- (3) The material is reported as complying with the pass/fail criteria of ASTM E136 when tested in accordance with the test method and procedure in ASTM E2652, *Standard Test Method for Behavior of Materials in a Tube Furnace with a Cone-shaped Airflow Stabilizer, at 750°C*. [

[5000:7.1.4.1.1]

4.1.5.2 Where the term *limited-combustible* is used in this Code, it shall also include the term *noncombustible*. [5000:7.1.4.1.2]

4.1.6* **Limited-Combustible Material.** A material shall be considered a limited-combustible material where both of the following conditions of 4.1.6.1, and 4.1.6.2, and the conditions of either 4.1.6.3 or 4.1.6.4 are met. [5000:7.1.4.2]

Δ 4.1.6.1 The material does not comply with the requirements for a noncombustible material in accordance with 4.1.5. [5000:7.1.4.2(1)]

Δ 4.1.6.2 The material, in the form in which it is used, exhibits a potential heat value not exceeding 3500 Btu/lb (8141 kJ/kg), when tested in accordance with NFPA 259. [5000:7.1.4.2(2)]

Δ 4.1.6.3 The material shall have a structural base of noncombustible material with a surfacing not exceeding a thickness of 1/8 in. (3.2 mm) where the surfacing exhibits a flame spread index not greater than 50 when tested in accordance with ASTM E84, *Standard Test Method for Surface Burning Characteristics of Building Materials* or ANSI/UL 723, *Standard for Test for Surface Burning Characteristics of Building Materials*. [5000:7.1.4.2.1]

Δ 4.1.6.4 The material shall be composed of materials that in the form and thickness used, neither exhibit a flame spread index greater than 25 nor evidence of continued progressive combustion when tested in accordance with ASTM E84 or ANSI/UL 723 and are of such composition that all surfaces that would be exposed by cutting through the material on any plane would neither exhibit a flame spread index greater than 25 nor exhibit evidence of continued progressive combustion when tested in accordance with ASTM E84 or ANSI/UL 723. [5000:7.1.4.2.2]

N 4.1.6.5 An alternate approach for a material to be considered a limited combustible material is where the material is tested in accordance with ASTM E2965, *Standard Test for Determination of Low Levels of Heat Release Rate for Materials and Products Using an Oxygen Combustion Calorimeter*, at an incident heat flux of 75 kW/m² for a 20-minute exposure, the peak heat release rate does not exceed 150 kW/m² for longer than 10 seconds, the total heat released does not exceed 8 MJ/m². [5000:7.1.4.2.3]

4.1.6.6 Where the term *limited-combustible* is used in this Code, it shall also include the term *noncombustible*. [5000:7.1.4.2.4]

4.2 Reserved.

4.3 Type I (442 or 332) and Type II (222, 111, or 000) Construction. [5000:7.2.3]

4.3.1 **Type I and Type II Construction.** Type I (442 or 332) and Type II (222, 111, or 000) construction shall be those types in which the fire walls, structural elements, walls, arches, floors, and roofs are of approved noncombustible or limited-combustible materials. [5000:7.2.3.1]

4.3.2 **Special Requirements — Type I and Type II Construction.** The special requirements in 4.3.2.1 through 4.3.2.16 shall apply to Type I and Type II construction. [5000:7.2.3.2]

4.3.2.1 **Wood Sleepers.** Where wood sleepers are used for installing wood flooring on noncombustible floors, the furring space shall be filled with noncombustible or limited-combustible material or shall be fireblocked so that there will be no open space exceeding 100 ft² (9 m²) in area under the flooring. [5000:7.2.3.2.1]

4.3.2.2 **Sleeper Space.** The furring spaces created by sleepers in 4.3.2.1 shall be filled solidly under all permanent partitions to prevent spread of fire under the flooring. [5000:7.2.3.2.2]

4.3.2.3 **Mezzanine Floors in Type I and Type II (222 or 111) Construction.** Mezzanine floors in Type I and Type II (222 or 111) construction shall have a fire resistance rating of not less than 1 hour. [5000:7.2.3.2.3]

4.3.2.4 **Mezzanine Floors in Type II (000) Construction.** Mezzanine floors in Type II (000) construction shall not be required to have a fire resistance rating. [5000:7.2.3.2.4]

4.3.2.5 **Platforms.** Permanent platforms shall be constructed of noncombustible or limited-combustible materials. [5000:7.2.3.2.5]

Δ 4.3.2.6 **Space Beneath Platforms.** When the space beneath any permanent platform is used for storage or any purpose other than equipment, wiring, or plumbing, the floor construction shall have a fire resistance rating not less than 1 hour. [5000:7.2.3.2.6]

4.3.2.7 **Fire-Retardant-Treated Wood Platforms.** Fire-retardant-treated wood shall be permitted for permanent platforms that do not exceed 3000 ft² (278 m²), that are not more than 30 in. (760 mm) above the floor, and that do not occupy more than 50 percent of the floor area of the room or space in which they are located. [5000:7.2.3.2.7]

4.3.2.8 **Roofs 20 ft (6100 mm) or More Above Any Floor.** In occupancies other than mercantile, industrial, or storage occupancies with ordinary or high hazard contents, or other occupancies with high hazard contents exceeding the maximum allowable quantities (MAQ) per control area as set forth in 34.1.3 of NFPA 5000, the fire-resistive protection of the roof/ceiling assembly required by Table 4.1.1 shall not be required where every part of the roof/ceiling assembly is 20 ft (6100 mm) or more above any floor immediately below. [5000:7.2.3.2.8]

4.3.2.9 **Fire-Retardant-Treated Wood Roof.** [5000:7.2.3.2.9]

4.3.2.9.1 Fire-retardant-treated wood members shall be permitted to be used for unprotected members specified in 4.3.2.8. [5000:7.2.3.2.9.1]

4.3.2.9.2 Fire-retardant-treated wood shall be permitted for roof construction, including girders and trusses, under the following conditions:

- (1) In Type II buildings
- (2) In Type I buildings where the number of stories is two or fewer
- (3) In Type I buildings where the number of stories is three or more when the vertical distance from the floor to the roof is 20 ft (6100 mm) or more [5000:7.2.3.2.9.2]

4.3.2.10 Heavy Timber Structural Elements. In all occupancies, heavy timber structural elements shall be permitted to be used for the roof construction where a 1-hour fire resistance rating or less is required. [5000:7.2.3.2.10]

4.3.2.11 Interior Nonbearing Walls. [5000:7.2.3.2.11]

4.3.2.11.1 Interior nonbearing walls shall be constructed of noncombustible or limited-combustible materials. [5000:7.2.3.2.11.1]

4.3.2.11.2 Interior nonbearing walls required to have a fire resistance rating of 2 hours or less shall be permitted to be fire-retardant-treated wood enclosed within noncombustible or limited-combustible materials, provided that such walls are not used as shaft enclosures. [5000:7.2.3.2.11.2]

4.3.2.12 Exterior Nonbearing Walls. Nonbearing exterior walls shall be constructed of noncombustible materials, limited-combustible materials, or materials specified in 4.3.2.12.1 or 4.3.2.12.2. [5000:7.2.3.2.12]

4.3.2.12.1 Fire-retardant-treated wood shall be permitted in exterior nonbearing walls when such walls are not required to have fire resistance ratings. [5000:7.2.3.2.12.1]

▲ **4.3.2.12.2** Exterior nonbearing walls tested in accordance with and meeting the conditions of acceptance of NFPA 285 shall be permitted. [5000:7.2.3.2.12.2]

▲ **4.3.2.13 Combustible Materials.** Combustible materials shall be permitted in accordance with the following:

- (1) Foamed plastic insulation complying with Section 48.4 of *NFPA 5000*
- (2) Metal composite material complying with Section 37.4 of *NFPA 5000*
- (3) Thermal and acoustical insulation, other than foamed plastic, complying with Section 8.16 of *NFPA 5000*
- (4) Interior floor finish and interior finish, trim, and millwork, such as doors, door frames, window sashes, and window frames
- (5) Light-transmitting plastic complying with Sections 38.11 and 48.7 of *NFPA 5000*
- (6) Class A, Class B, or Class C roof coverings
- (7) Blocking [5000:7.2.3.2.13]

▲ **4.3.2.14 Ceiling Cavity Plenums and Raised Floor Plenums.** [5000:7.2.3.2.14] For the purpose of this *Code*, the application of these provisions for ceiling cavity plenums and raised floor plenums shall apply to all buildings and shall not be subject to the limitations as set forth in Section 1.3 of NFPA 90A. [5000:7.2.3.2.14.2]

▲ **4.3.2.15 Plenum Materials Combustibility.** Materials exposed to the airflow within ceiling cavity plenums and raised floor plenums shall comply with NFPA 90A.

4.3.2.16 Ceiling Plenum Tested Assembly. Where the plenum is a part of a floor/ceiling or roof/ceiling assembly that has been tested or investigated and assigned a fire resistance rating of 1 hour or more, and the assembly contains air ducts and openings for air ducts, all the materials and the construction of the assembly, including the air duct materials and the size and protection of the openings, shall conform with the design of the fire resistance-rated assembly, as tested in accordance with ASTM E119, *Standard Test Methods for Fire Tests of Building Construction and Materials*; or ANSI/UL 263, *Standard for Fire Tests of Building Construction and Materials*. [5000:8.2.1.4]

4.4 Type III (211 or 200) Construction. [5000:7.2.4]

4.4.1 Type III Construction. Type III (211 or 200) construction shall be that type in which exterior walls and structural elements that are portions of exterior walls are of approved noncombustible or limited-combustible materials, and in which fire walls, interior structural elements, walls, arches, floors, and roofs are entirely or partially of wood of smaller dimensions than required for Type IV construction or are of approved noncombustible, limited-combustible, or other approved combustible materials. [5000:7.2.4.1]

4.4.2 Special Requirements — Type III Construction. The special requirements in 4.4.2.1 through 4.4.2.3 shall apply to Type III construction. [5000:7.2.4.2]

4.4.2.1 Fire-Retardant-Treated Wood. Approved fire-retardant-treated wood framing shall be permitted within the assembly of exterior walls having a required fire resistance rating of 2 hours or less and a horizontal separation of not less than 60 in. (1525 mm), provided that the fire resistance rating is maintained and the exposed outer and inner faces of such walls are constructed of limited-combustible or noncombustible materials. [5000:7.2.4.2.1]

4.4.2.2 Heavy Timber. Wood columns and arches conforming to heavy timber sizes shall be permitted where exterior walls are required to have a 1-hour fire resistance rating or less. [5000:7.2.4.2.2]

▲ **4.4.2.3 Exterior Nonbearing Walls.** Exterior nonbearing walls tested in accordance with, and meeting the conditions of acceptance of, NFPA 285 shall be permitted. [5000:7.2.4.2.3]

4.5 Type IV (2HH) Construction. [5000:7.2.5]

4.5.1 Type IV Construction. Type IV (2HH) construction shall be that type in which fire walls, exterior walls, and interior bearing walls and structural elements that are portions of such walls are of approved noncombustible or limited-combustible materials, except as allowed for exterior walls in 4.5.6.7. Other interior structural elements, arches, floors, and roofs shall be of solid or laminated wood or cross-laminated timber without concealed spaces or with concealed spaces conforming to 4.5.6.7 and shall comply with the allowable dimensions of 4.5.5. [5000:7.2.5.1]

4.5.2 Exterior Wall Separation. Exterior walls greater than 30 ft (9.1 m) from the property line shall be permitted to be of heavy timber construction, provided that the 2-hour rating as required by Table 4.1.1 is maintained and such walls contain no combustible concealed spaces. [5000:7.2.5.2]

4.5.3 Interior Columns, Arches, Beams, Girders, and Trusses.

Interior columns, arches, beams, girders, and trusses of approved materials other than wood shall be permitted, provided that they are protected to provide a fire resistance rating of not less than 1 hour. [5000:7.2.5.3]

4.5.4 Concealed Spaces. Certain concealed spaces shall be permitted in accordance with the following:

- (1) Concealed spaces in accordance with 4.5.5.3.4.
- (2) Concealed spaces within 1-hour fire resistance-rated interior walls and partitions in accordance with 4.5.6.3 do not require additional protection.
- (3) Concealed spaces in floors, roofs, or walls of cross-laminated timber construction in accordance with one or more of the following and which do not contain combustibles other than building elements and electrical, mechanical, fire protection, or plumbing materials and equipment:
 - (a) The building is sprinklered throughout and automatic sprinklers are also provided in the concealed space.
 - (b) The concealed space is filled completely with noncombustible insulation.
 - (c) Surfaces within the concealed space are fully sheathed with not less than ½ in. (12.7 mm) gypsum board or noncombustible materials.

[5000:7.2.5.4]

4.5.5 Type IV (2HH) Allowable Dimensions. All dimensions in 4.5.5 for solid sawn members shall be considered nominal. [5000:7.2.5.5]

4.5.5.1 Columns. [5000:7.2.5.5.3]

4.5.5.1.1 Wood columns supporting floor loads shall be not less than 8 in. (205 mm) in any dimension. [5000:7.2.5.5.3.1]

4.5.5.1.2 Wood columns supporting only roof loads shall be not less than 6 in. (150 mm) in width and not less than 8 in. (205 mm) in depth. [5000:7.2.5.5.3.2]

4.5.5.2 Beams. [5000:7.2.5.5.4]

4.5.5.2.1 Wood beams and girders supporting floor loads shall be not less than 6 in. (150 mm) in width and not less than 10 in. (255 mm) in depth. [5000:7.2.5.5.4.1]

4.5.5.2.2 Wood beams and girders and other roof framing supporting roof loads only shall be not less than 4 in. (100 mm) in width and not less than 6 in. (150 mm) in depth. [5000:7.2.5.5.4.2]

4.5.5.3 Arches. [5000:7.2.5.5.5]

4.5.5.3.1 Framed or glued laminated arches that spring from the finished ground level or the floor line, and timber trusses that support floor loads, shall be not less than 8 in. (205 mm) in width or depth. [5000:7.2.5.5.5.1]

4.5.5.3.2 Framed or glued laminated arches for roof construction that spring from the finished ground level or the floor line and do not support floor loads shall have members not less than 6 in. (150 mm) in width and not less than 8 in. (205 mm) in depth for the lower half of the member height, and not less than 6 in. (150 mm) in depth for the upper half of the member height. [5000:7.2.5.5.5.2]

4.5.5.3.3 Framed or glued laminated arches for roof construction that spring from the top of walls or wall abutments, and

timber trusses that do not support floor loads, shall have members not less than 4 in. (100 mm) in width and not less than 6 in. (150 mm) in depth. [5000:7.2.5.5.5.3]

4.5.5.3.4 Spaced members shall be permitted to be composed of two or more pieces not less than 3 in. (75 mm) in thickness where blocked solidly throughout their intervening spaces or where such spaces are tightly closed by a continuous wood cover plate not less than 2 in. (51 mm) in thickness that is secured to the underside of the members. [5000:7.2.5.5.5.4]

4.5.5.4 Splice Plates. Splice plates shall be not less than 3 in. (75 mm) in thickness. [5000:7.2.5.5.6]

Δ 4.5.5.5 Floors. Floors shall be constructed without concealed spaces and shall be permitted to be any of the following materials:

- (1) Materials shall be spline or tongue-and-groove plank not less than 3 in. (75 mm) in thickness that is covered with 1 in. (25 mm) tongue-and-groove flooring, laid crosswise or diagonally to the plank, or with ½ in. (12.7 mm) wood structural panel; or they shall be constructed of laminated planks not less than 4 in. (100 mm) in width, set close together on edge, spiked at intervals of 18 in. (455 mm), and covered with 1 in. (25 mm) tongue-and-groove flooring, laid crosswise or diagonally to the plank, or with ½ in. (12.7 mm) wood structural panel.
- (2) Cross-laminated timber complying with 4.5.5.7 of *NFPA 5000* shall be not less than 4 in. (100 mm) thick and shall be continuous between supports. Individual timbers shall be fastened to one another. Cross-laminated timbers shall be permitted to be connected to walls without shrinkage gaps provided dimensional changes are considered in design. Concealed spaces shall be permitted in accordance with 4.5.4.

[5000:7.2.5.5.7]

Δ 4.5.5.6 Roof Decks. Roof decks shall be permitted to be constructed of any of the following materials:

- (1) Spline or tongue-and-groove plank not less than 2 in. (51 mm) in thickness
- (2) Laminated planks not less than 3 in. (75 mm) in width, set close together on edge, and laid as required for floors
- (3) 1 ⅛ in. (29 mm) thick interior wood structural panel, exterior glue
- (4) Cross-laminated timber
- (5) Approved noncombustible or limited-combustible materials of equivalent fire durability

[5000:7.2.5.5.8]

4.5.6 Special Requirements — Type IV Construction. The special requirements in 4.5.6.1 through 4.5.6.8 shall apply to Type IV construction. [5000:7.2.5.6]

4.5.6.1 Structural Elements. Structural elements shall be of heavy timber members (sawn or glued-laminated), cross-laminated timber, or fire resistance-rated construction as set forth in Table 4.1.1 when materials other than heavy timber are used. [5000:7.2.5.6.1]

4.5.6.2 Columns, Arches, Beams, and Roof Decking. Where horizontal separation of 20 ft (6100 mm) or more is provided, wood columns, arches, beams, and roof decking conforming to the requirements for heavy timber in 4.5.5 shall be permitted to be used on the exterior of the building. [5000:7.2.5.6.2]

4.5.6.3 Partitions. Permanent partitions shall be permitted to be of solid wood construction formed by not less than two layers of matched boards of 1 in. (25 mm) nominal thickness or of 1-hour fire resistance-rated construction as set forth in Table 4.1.1. [5000:7.2.5.6.3]

4.5.6.4 Floors. Floors shall be permitted to be of heavy timber, masonry, concrete, wood, or steel and shall be constructed as required in Chapter 8 of *NFPA 5000*. [5000:7.2.5.6.4]

4.5.6.5 Roofs. Roofs of 1-hour fire resistance-rated construction shall be permitted. [5000:7.2.5.6.5]

4.5.6.6 Stairways. [5000:7.2.5.6.6]

4.5.6.6.1 Stairways shall be permitted to be constructed with wood treads and risers of not less than 2 in. (51 mm) nominal thickness. [5000:7.2.5.6.6.1]

4.5.6.6.2 Where built-on, laminated, or plank inclines are required for floors, stairways shall be permitted to be 1 in. (25 mm) nominal thickness or shall be permitted to be constructed as required for buildings of Type I or Type II construction. [5000:7.2.5.6.6.2]

4.5.6.7 Exterior Walls. Exterior walls having a required fire resistance rating of 2 hours or less shall be permitted to be constructed with any of the following materials: [5000:7.2.5.6.7]

- (1) Noncombustible material shall be permitted.
- (2) Limited-combustible material shall be permitted.
- (3) Fire-retardant-treated wood shall be permitted. Approved fire-retardant-treated wood framing shall be permitted within the assembly of exterior walls having a horizontal separation of not less than 60 in. (1525 mm), provided that the fire resistance rating is maintained and the exposed outer and inner faces of such walls are constructed of limited-combustible or noncombustible materials.
- (4) Cross-laminated timber complying with 45.5.7 of *NFPA 5000* shall be permitted provided the exterior surface of the cross-laminated timber is protected by one of the following:
 - (a) Fire-retardant-treated wood not less than $1\frac{15}{32}$ in. (12 mm) thick
 - (b) Gypsum board not less than $\frac{1}{2}$ in. (12.7 mm) thick
 - (c) Noncombustible material

4.5.6.8 Exterior Nonbearing Walls. Exterior nonbearing walls tested in accordance with, and meeting the conditions of acceptance of *NFPA 285* shall be permitted. [5000:7.2.5.6.8]

4.6 Type V (111 or 000) Construction. Type V (111 or 000) construction shall be that type in which structural elements, walls, arches, floors, and roofs are entirely or partially of wood or other approved material. [5000:7.2.6]

Chapter 5 Fire Resistance Rating Requirements for Structural Elements

5.1 Fire Resistance Rating Requirements.

5.1.1 The fire resistance ratings of structural elements and building assemblies shall be determined in accordance with Section 8.2 in *NFPA 5000* or 8.2.3 in *NFPA 101*.

5.1.2 Fire resistance protection shall be provided for structural elements as set forth in Chapter 5.

5.1.3 Structural elements shall meet the requirements of 5.1.3.1 through 5.1.3.3.

5.1.3.1 Structural elements, floors, and bearing walls shall have a fire resistance rating not less than the fire resistance rating required for the structural element, bearing or nonbearing wall, floor, or roof they support. [5000:7.2.7.2.1]

5.1.3.2 Structural elements, floors, and bearing walls shall be required to have only the fire resistance rating required for the construction classification of the building, provided that both of the following criteria are met:

- (1) The structural elements support nonbearing wall or partition assemblies having a required fire resistance rating of 1 hour or less.
- (2) The structural elements do not serve as exit enclosures, protection for vertical openings, or occupancy separations. [5000:7.2.7.2.2]

5.1.3.3 Structural elements, such as girders, beams, trusses, and spandrels, that have direct connections to columns carrying gravity loads, and that are essential to the stability of the building as a whole, shall have a fire resistance rating not less than that of the columns to which they are connected. [5000:7.2.7.2.3]

5.1.4 Structural elements required to have a fire resistance rating and that support more than two floors, one floor and roof, a bearing wall, or a nonbearing wall more than two stories high shall be individually protected on all sides for their full length with materials providing the required fire resistance rating. [5000:7.2.7.3]

5.1.5* Structural elements, other than those specified in 5.1.3, required to have a fire resistance rating shall be protected by individual encasement, or by membrane or ceiling protection in accordance with Section 8.6 of *NFPA 5000* or a combination of both. [5000:7.2.7.4]

5.1.6 In addition to the requirements of 5.1.3 and 5.1.4, columns shall meet the following requirements:

- (1) Where columns require a fire resistance rating, the entire column, including its connections to beams or girders, shall be individually protected.
- (2) Where the column extends through a ceiling, the fire-resistive protection provided for the column shall be continuous from the top of the floor through the ceiling space to the top of the column. [5000:7.2.7.5]

5.1.7 Structural elements complying with Section 4.5 shall not be required to comply with 5.1.4. [5000:7.2.7.6]

5.1.8 The required thickness and construction of fire-resistive materials or assemblies enclosing trusses shall be based on one of the following:

- (1) Results of full-scale tests or combinations of tests on truss components
- (2) Approved calculations based on such tests to verify that the assembly is provided with the required fire resistance rating in accordance with 8.2.3 of *NFPA 5000*

[5000:7.2.7.7]

5.1.9 The fire resistance rating required for external structural elements located beyond the perimeter of the building floor area shall be permitted to be calculated by using analytical methods in accordance with the provisions set forth in 8.2.3 of *NFPA 5000*. [5000:7.2.7.8]

5.1.10 Structural elements within exterior walls or located along the exterior perimeter of a building or structure shall have a fire resistance rating as required by Table 4.1.1 for exterior bearing walls based on the type of construction. [5000:7.2.7.9]

5.1.11* Structural elements within an exterior wall located where openings are not permitted, or where protection of openings is required in accordance with 7.3.5 of *NFPA 5000*, shall have a fire resistance rating based on protection against exterior fire exposure as required for exterior bearing walls or the structural element, whichever requires the greater fire resistance rating. [5000:7.2.7.10]

5.1.12 The edges of lugs, brackets, rivets, and bolt heads attached to structural elements shall be permitted to extend to within 1 in. (25 mm) of the surface of the fire-resistive protection. [5000:7.2.7.11]

5.1.13 Conduits, pipes, or ducts shall not be embedded within the required fire-resistive protection of any structural elements requiring individual encasement to achieve the required fire resistance rating. [5000:7.2.7.12]

5.1.14 Fire-resistive materials covering columns required to have a fire resistance rating, where exposed to impact damage by moving vehicles, by handling of merchandise, or by other means, shall be protected from damage. [5000:7.2.7.13]

5.1.15 In load bearing, light frame walls requiring a fire resistance rating, membrane protection shall not be required to extend beyond the edge or flange of the construction in openings that are framed or where doors or windows are installed. [5000:7.2.7.14]

Annex A Explanatory Material

Annex A is not a part of the requirements of this NFPA document but is included for informational purposes only. This annex contains explanatory material, numbered to correspond with the applicable text paragraphs.

▲ **A.1.1** It is necessary for the user to consider the influence of location, occupancy, exterior exposure, possibility of mechanical and physical damage to fire-resistant material, and other features that could impose additional requirements for safeguarding life and property, as commonly covered in building codes.

For information on the construction of fire walls and fire barrier walls, see NFPA 221. For the installation of opening protection, see NFPA 80 and NFPA 90A.

A.3.1 These definitions apply to the materials used in the construction of buildings but do not apply to furnishings, the contents of buildings, or the fire hazard evaluation of materials.

A.3.2.1 Approved. The National Fire Protection Association does not approve, inspect, or certify any installations, procedures, equipment, or materials; nor does it approve or evaluate testing laboratories. In determining the acceptability of installations, procedures, equipment, or materials, the authority having jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure, or use. The authority having jurisdiction may also refer to the listings or labeling practices of an organi-

zation that is concerned with product evaluations and is thus in a position to determine compliance with appropriate standards for the current production of listed items.

A.3.2.2 Authority Having Jurisdiction (AHJ). The phrase “authority having jurisdiction,” or its acronym AHJ, is used in NFPA documents in a broad manner, since jurisdictions and approval agencies vary, as do their responsibilities. Where public safety is primary, the authority having jurisdiction may be a federal, state, local, or other regional department or individual such as a fire chief; fire marshal; chief of a fire prevention bureau, labor department, or health department; building official; electrical inspector; or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the authority having jurisdiction. In many circumstances, the property owner or his or her designated agent assumes the role of the authority having jurisdiction; at government installations, the commanding officer or departmental official may be the authority having jurisdiction.

A.3.2.3 Listed. The means for identifying listed equipment may vary for each organization concerned with product evaluation; some organizations do not recognize equipment as listed unless it is also labeled. The authority having jurisdiction should utilize the system employed by the listing organization to identify a listed product.

A.3.3.2 Flame Spread Index. Under the criteria of ASTM E84, *Standard Test Method for Surface Burning Characteristics of Building Materials*, and ANSI/UL 723, *Standard for Test for Surface Burning Characteristics of Building Materials* the flame spread index is expressed numerically on a scale for which the zero point is fixed by the performance of inorganic-reinforced cement board and the 100 point (approximately) is fixed by the performance of untreated red oak flooring.

A.4.1.1 The system of designating types of construction also includes a specific breakdown of the types of construction through the use of Arabic numbers. These Arabic numbers follow the roman numeral notation where identifying a type of construction [e.g., Type I(442), Type II(111), Type III(200)] and indicate the fire resistance rating requirements for certain structural elements as follows:

- (1) First Arabic number — exterior bearing walls
- (2) Second Arabic number — columns, beams, girders, trusses and arches, supporting bearing walls, columns, or loads from more than one floor
- (3) Third Arabic number — floor construction

Table A.4.1.1 provides a comparison of similar types of construction for various model building codes.

[5000: A.7.2.1.1]

A.4.1.5.1 The provisions of 4.1.5.1 do not require inherently noncombustible materials to be tested in order to be classified as noncombustible materials. [5000: A.7.1.4.1]

A.4.1.5.1(1) Examples of such materials include steel, concrete, masonry, and glass. [5000: A.7.1.4.1.1(1)]

▲ **A.4.1.6** Material subject to increase in combustibility or flame spread index beyond the limits herein established through the effects of age, moisture, or other atmospheric condition is considered combustible. (See NFPA 259.)

Table A.4.1.1 Cross-Reference of Building Construction Types

NFPA 5000	I(442)	I(332)	II(222)	II(111)	II(000)	III(211)	III(200)	IV(2HH)	V(111)	V(000)
UBC	—	I FR	II FR	II 1 hr	II N	III 1 hr	III N	IV HT	V 1 hr	V N
B/NBC	1A	1B	2A	2B	2C	3A	3B	4	5A	5B
SBC	I	II	—	IV 1 hr	IV UNP	V 1 hr	V UNP	III	VI 1 hr	VI UNP
IBC	—	IA	IB	IIA	IIB	IIIA	IIIB	IV	VA	VB

UBC: *Uniform Building Code*.

FR: Fire rated.

N: Nonsprinklered.

HT: Heavy timber.

B/NBC: *National Building Code*.

SBC: *Standard Building Code*.

IBC: *International Building Code*.

UNP: Unprotected. [5000: Table A.7.2.1.1]

A.5.1.5 Fire resistance-rated bearing wall assemblies, floor/ceiling assemblies, and roof/ceiling assemblies that are not addressed by 5.1.4 can intersect and provide protection to each other to the extent that the same level of protection is provided by the individual protective elements that intersect.

▲ **A.5.1.11** It is not the intent to require protection of structural elements against exterior fire exposure due merely to the presence of fire sprinklers or an occupiable exterior space, such as a porch or balcony, unless specifically required by other codes, such as *NFPA 5000*.

Annex B Informational References

B.1 Referenced Publications. The documents or portions thereof listed in this annex are referenced within the informational sections of this standard and are not part of the requirements of this document unless also listed in Chapter 2 for other reasons.

B.1.1 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 80, *Standard for Fire Doors and Other Opening Protectives*, 2016 edition.

NFPA 90A, *Standard for the Installation of Air-Conditioning and Ventilating Systems*, 2018 edition.

NFPA 221, *Standard for High Challenge Fire Walls, Fire Walls, and Fire Barrier Walls*, 2018 edition.

NFPA 259, *Standard Test Method for Potential Heat of Building Materials*, 2013 edition.

NFPA 5000®, *Building Construction and Safety Code®*, 2018 edition.

B.1.2 Other Publications.

▲ **B.1.2.1 ASTM Publications.** ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

ASTM E84, *Standard Test Method for Surface Burning Characteristics of Building Materials*, 2015a.

B.1.2.2 UL Publications. Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096.

ANSI/UL 723, *Standard for Test for Surface Burning Characteristics of Building Materials*, 2008, revised 2013.

B.2 Informational References. (Reserved)

B.3 References for Extracts in Informational Sections.

NFPA 5000®, *Building Construction and Safety Code®*, 2018 edition.

Index

Copyright © 2017 National Fire Protection Association. All Rights Reserved.

The copyright in this index is separate and distinct from the copyright in the document that it indexes. The licensing provisions set forth for the document are not applicable to this index. This index may not be reproduced in whole or in part by any means without the express written permission of NFPA.

- A-
 - Administration**, Chap. 1
 - Equivalency, 1.5
 - Purpose, 1.2
 - Retroactivity, 1.4
 - Scope, 1.1, A.1.1
 - Units, 1.6
 - Primary and Equivalent Values, 1.6.2
 - SI Units, 1.6.1
 - Approved**
 - Definition, 3.2.1, A.3.2.1
 - Authority Having Jurisdiction (AHJ)**
 - Definition, 3.2.2, A.3.2.2
- F-
 - Fire Resistance Rating**
 - Definition, 3.3.1
 - Fire Resistance Rating Requirements for Structural Elements**, Chap. 5
 - Flame Spread Index**
 - Definition, 3.3.2, A.3.3.2
- L-
 - Limited-Combustible Material**
 - Definition, 3.3.3
 - Listed**
 - Definition, 3.2.3, A.3.2.3
- N-
 - Noncombustible Material**
 - Definition, 3.3.4
- R-
 - Referenced Publications**, Chap. 2
- S-
 - Shall**
 - Definition, 3.2.4
 - Should**
 - Definition, 3.2.5
 - Standard**
 - Definition, 3.2.6
- T-
 - Types of Construction**, Chap. 4
 - General, 4.1
 - Limited-Combustible Material, 4.1.6, A.4.1.6
 - Noncombustible Material, 4.1.5
 - Type I (442 or 332) and Type II (222, 111, or 000) Construction, 4.3
 - Special Requirements — Type I and Type II Construction, 4.3.2
 - Ceiling Cavity Plenums and Raised Floor Plenums, 4.3.2.14
 - Ceiling Plenum Tested Assembly, 4.3.2.16
 - Combustible Materials, 4.3.2.13
 - Exterior Nonbearing Walls, 4.3.2.12
 - Fire-Retardant-Treated Wood Platforms, 4.3.2.7
 - Fire-Retardant-Treated Wood Roof, 4.3.2.9
 - Heavy Timber Structural Elements, 4.3.2.10
 - Interior Nonbearing Walls, 4.3.2.11
 - Mezzanine Floors in Type I and Type II (222 or 111) Construction, 4.3.2.3
 - Mezzanine Floors in Type II (000) Construction, 4.3.2.4
 - Platforms, 4.3.2.5
 - Plenum Materials Combustibility, 4.3.2.15
 - Roofs 20 ft (6100 mm) or More Above Any Floor, 4.3.2.8
 - Sleeper Space, 4.3.2.2
 - Space Beneath Platforms, 4.3.2.6
 - Wood Sleepers, 4.3.2.1
 - Type I and Type II Construction, 4.3.1
 - Type III (211 or 200) Construction, 4.4
 - Special Requirements — Type III Construction, 4.4.2
 - Exterior Nonbearing Walls, 4.4.2.3
 - Fire-Retardant-Treated Wood, 4.4.2.1
 - Heavy Timber, 4.4.2.2
 - Type III Construction, 4.4.1
 - Type IV (2HH) Construction, 4.5
 - Concealed Spaces, 4.5.4
 - Exterior Wall Separation, 4.5.2
 - Interior Columns, Arches, Beams, Girders, and Trusses, 4.5.3
 - Special Requirements — Type IV Construction, 4.5.6
 - Columns, Arches, Beams, and Roof Decking, 4.5.6.2
 - Exterior Nonbearing Walls, 4.5.6.8
 - Exterior Walls, 4.5.6.7
 - Floors, 4.5.6.4
 - Partitions, 4.5.6.3
 - Roofs, 4.5.6.5
 - Stairways, 4.5.6.6
 - Structural Elements, 4.5.6.1
 - Type IV (2HH) Allowable Dimensions, 4.5.5
 - Arches, 4.5.5.3
 - Beams, 4.5.5.2
 - Columns, 4.5.5.1
 - Floors, 4.5.5.5
 - Roof Decks, 4.5.5.6
 - Splice Plates, 4.5.5.4
 - Type IV Construction, 4.5.1
 - Type V (111 or 000) Construction, 4.6